

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No. FG/DFS/MS/HSPTL/2017/86

Dated: 19/01/2017

FIRE SAFETY CERTIFICATE

Certified that M/s Sai Vishram Sadan (Dharamshala), Opposite AIIMS Complex, Aurobindo Marg, New Delhi-110029, comprised of ground plus three upper floors only (GF=1room+1dormatary, FF to TF=6rooms+1dormatary at each floor. Total 19 rooms and 04 dormatary), owned/occupied by All India Institute of Medical Sciences (AIIMS) was granted NOC by this department vide letter No. F6/DFS/MS/2002/1341, dated 19-08-2002. The premises was re-inspected by the officer concerned of this department on 03-01-2017 in the presence of Sh. Deepak Kumar, Dy. Chief Security Officer and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "A" Residential as above with effect from 19/01/.....2017 for a period of five years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 19/01/.....2017 at New Delhi by.

Vipin Kental

(Vipin Kental)

Chief Fire Officer

T.No.011-23412225

Copy to:- Sh. Deepak Kumar, Dy. Chief Security Officer, AIIMS Complex, Ansari Nagar, New Delhi.

Conditions for the validity of fire safety certificate are under:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate on form J, six month prior to its expiry.

1	Name & address of the building	M/s Sai Vishram Sadan (Dharamshala), Opposite AIIMS Complex, Aurobindo Marg, New Delhi-110029.
2	Type of Occupancy	Residential Building "A" (Hostel)
3	Building comprised of	Ground plus three upper floors. GF=1room+1dormitory, FF to TF=6rooms+1dormitory at each floor. Total 19 rooms and 04 dormitory.
3	Type of case	Renewal.
4	Details of previous NOC	No.F6/DFS/MS/2002/1341, Dated 19.08.2002.
5	Fire safety directives letter No	No.F6/MS/DFS/95/576, Dated 10.05.1995.
6	Date of inspection	03.01.2017.
7	Name of the inspecting Officers	ADO Vedpal
8	Name and designation of officers from the building side	Sh.Deepak Kumar Security Officer of the Hospital.
9	Year of construction	2000
10	Applicant's letter No.	Security/Fire/Inspection/2016, Dated 08.12.2016

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements/ Existing Fire Protection System	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	9m	9m	MR
	2) Gate width	5m	5m	MR
	3) Width of internal road	N/A	6m	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	01no.	01no.	MR
	2. Basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	90cm	1.10m	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	01no.	01no.	MR
	e. Width of corridor	1.2m	1.2m	MR
	f. Door size	1.2m	1.2m	MR
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	Required	Provided	MR
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	Basement	30 a/c per hour	N/A	N/A
	Upper floors	12 a/c per hour	Natural Ventilation	MR
5	Fire Extinguishers			
	Total numbers	08 Nos.	12 Nos.	MR
	Types	ABC, CO2 & WCO2	ABC, CO2 & WCO2	MR
	ISI marking	ISI	Provided	MR
6	First-Aid Hose Reels.			
	Total numbers on each floor	N/A	N/A	N/A
	Length of Hose reel hose	N/A	N/A	N/A
	Nozzle Diameter	N/A	N/A	N/A
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A

11	Internal Hydrants			
	Size of riser/down-corner	N/A		
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	house box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level	N/A	N/A	N/A
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	N/A	N/A	N/A
	b. head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	N/A	N/A	N/A
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	N/A	N/A	N/A
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A
17	Standby power supply	N/A	Provided	N/A
18	Refuge Area.			
	total area	N/A	N/A	N/A
	location	N/A	N/A	N/A
19	Fire control room			
	a. Detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: Electric Panels are provided with ABC & CO2 Type fire extinguishers. MR			

The fire protection systems provided in the building were checked and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the NOC issued vide letter No.F.6/DFS/MS/2002/1341, dated 19.08.2002 renewal under rule 37 of the Delhi Fire Service Rule 2010 is recommended. Accordingly DFA is put up for your approval and signature please.

[Signature] 9/1/17

Signature of the inspecting officer

Name Vedpal

Designation : Assistant Divisional Officer



D.O. (S.D.)

[Signature] 4/11/17

[Signature]

PTD

541/cfe s2
11/17/19/11