

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

Fax No. 011-23412593, Ph. 011-23412225

No. F6/DFS/MS/School/2017/SZ/ 89

Dated: 19/01/2017

FIRE SAFETY CERTIFICATE

Certified that the **Sant Nirankari Public School at T-23, Malviya Nagar, Khirki Village Road, New Delhi-110017**, comprised of Ground + 02 upper floors was granted Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2014/SZ/165 dated 31/01/2014. The premises was re-inspected by officer concerned of this department on 03.01.2017 in the presence of Smt. Harpreet Kaur (HOS) of the school and found that said school building have deemed complied with the fire prevention and fire safety arrangements in accordance DOE circular No. 262-362 dated 17.01.2005 issued by Director of Education Govt. of NCT of Delhi and that the building/premises is fit for occupancy class "**Educational Building, Group-B**" as above with effect from 19/01/2017 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 19/01/2017 at New Delhi by


(Vipin Kental)
Chief Fire Officer

Copy to: -

1. The HOS, Sant Nirankari Public School,
T-23, Malviya Nagar, Khirki Village Road, ND-17
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering the fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drill be conducted at regular interval and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye Laws.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & Address of the Building	Sant Nirankari Public School, T-23, Malviya Nagar, New Delhi-110017		
2	Type of Occupancy	Educational Building "Group-B" (School)		
3	Building Comprised of	Ground two upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2014/SZ/165 Dated 31/01/14		
6	Fire Safety Directives Letter No	DOE Circular No. 262-362 Dated 17/01/2005		
7	Date of Inspection	03/01/2017		
8	Name of the Inspecting Officers	ADO R.N. Singh		
9	Name & Designation of Officers from the building side	Smt. Harpreet Kaur (HOS)		
10	Year of construction	1993		
11	Applicant letter No.	SNPS/MN/2016/069 Dated 26.12.2016		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Dt. 24/03/2008 Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	1. Road width	Accessible	6 Mtr	MR
	2. Gate width	N/A	4.5 Mtr	N/A
	3. Width of internal road	N/A	N/A	N/A
2	Number, width, type and arrangements of exits.			
	a. Number of Staircase			
	1. Upper floors	2 No's	2 No's	MR
	2. Basement floor	N/A	N/A	N/A
	b. Width of Staircase			
	1. Upper floors	Required	1.08 m each	MR
	2. Basement floor	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	One	Two	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	N/A	N/A	N/A
3	Compartmentation.			
	1. Fire check door.	N/A	N/A	N/A
	2. Sealing of electrical shafts.	N/A	N/A	N/A
	3. Fire rating of shaft door.	N/A	N/A	N/A
	4. Water curtain	N/A	N/A	N/A
	5. Fire dampers.	N/A	N/A	N/A
4.	Smoke Management system.			
	1. Basement	N/A	N/A	N/A
	2. Upper floors	N/A	Natural Ventilation	N/A
5.	Fire Extinguishers.			
	1. Total numbers	ISI Marked	10 Nos.	MR
	2. Types		ABC-08, Co2-02	MR
	3. ISI Marking		Provided	MR
6.	First Aid Hose Reels.			
	1. Total numbers on each floor.	Hose reel	One	MR
	2. Length of hose-reel hose.		30 Mtr	MR
	3. Nozzle Diameter		05 mm	MR

Renewal

Sant Nirankari Public School, Malviya Nagar, ND-17

7	Automatic Fire Detection and Alarming System.			
	1. Type of detectors	N/A	N/A	N/A
	2. Location of Main Panel	N/A	N/A	N/A
	3. Location of Repeater Panel	N/A	N/A	N/A
	4. Alternate source of power	N/A	N/A	N/A
	5. Hooter's location	N/A	N/A	N/A
8.	MOEFA / SIREN	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1. Basement.	N/A	N/A	N/A
	2. Upper floors	N/A	N/A	N/A
	3. Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants.			
	1. Size of Riser/Down-comer	Required	100 mm	MR
	2. Number of Hydrant per floor	Required	One	MR
	3. Hose box.	Required	One	MR
12.	Yard Hydrants.			
	1. Total number of hydrants.	N/A	N/A	N/A
	2. Hose box.	N/A	N/A	N/A
13.	Pumping arrangements.			
	a) Ground Level			
	➤ Discharge of main pump.	N/A	N/A	N/A
	➤ Head of main pump.	N/A	N/A	N/A
	➤ Number of main pumps.	N/A	N/A	N/A
	➤ Jockey Pump output.	N/A	N/A	N/A
	➤ Jockey Pump head.	N/A	N/A	N/A
	➤ Standby Pump output.	N/A	N/A	N/A
	➤ Standby Pump head.	N/A	N/A	N/A
	➤ Auto Starting / Manual Stopping.	N/A	N/A	N/A
	➤ Pump house access.	N/A	N/A	N/A
	b) Terrace Level			
	➤ Discharge of pump.	220 LPM	450 LPM	MR
	➤ Head of pump.	40 Mtr	40 Mtr	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	Captive water storage for Fire Fighting.			
	1. Underground tank capacity.	N/A	N/A	N/A
	2. Draw-off connection.	N/A	N/A	N/A
	3. Fire Service Inlet.	N/A	N/A	N/A
	4. Access to tank.	N/A	N/A	N/A
	5. Overhead tank capacity.	5,000 Ltr	5,000 Ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	1. Pressurization of lift shaft.	N/A	N/A	N/A
	2. Pressurization of lift lobby.	N/A	N/A	N/A
	3. Communication in lift car.	N/A	N/A	N/A
	4. Fireman's switch.	N/A	N/A	N/A
	5. Lift signage.	N/A	N/A	N/A
17	Standby Power Supply	N/A	N/A	N/A
18.	Refuge Area			
	1. Total area	N/A	N/A	N/A
	2. Location	N/A	N/A	N/A

19.	Fire Control Room.			
	1. Detector System Panel.	N/A	N/A	N/A
	2. Flow Switch Panel.	N/A	N/A	N/A
	3. PA system Panel.	N/A	N/A	N/A
	4. Battery backup	N/A	N/A	N/A
	5. Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for the Protection of special Risk, if any.	Required	Provided one Co2 type Fire Ext. near electrical panel	MR

The Fire protection systems provided in the building were randomly checked /tested and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the circular of Directorate of Education dated 17/01/2011, FSC issued vide letter No. F6/DFS/MS/School/2014/SZ/165 dated 31/01/2014, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

R.N. Singh
06/10/17

Signature of the Inspecting Officer

Name : R.N. Singh

Designation: ADO

Renewal

Sant Nirankari Public School, Malviya Nagar, ND-17

0051702-6/11/17

Div. Officer (SD)

Anil Kumar
6/11/17

Sp. (SD)

Handwritten signature
9/11

FTM

Chd 5/11

m. scull

Handwritten signature
12/11



527/cfo s2
12/11/16/10/11