

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/Banquet/2017/WZ/ 106

Dated: 23 / 1 / 2017

**FIRE SAFETY CERTIFICATE**

Certified that The Maidens Crown Banquets (A unit of SRK Hospitality) at Plot No. B-1, Udyog Nagar Industrial Area, New Delhi-41 comprised of Basement + Ground + Two Upper Floors only owned / occupied by The Maidens Crown Banquets (A unit of SRK Hospitality), have complied with the Fire prevention and Fire Safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified the officer concerned of Fire Service on 09/01/2017 in presence of Sh. Rajiv Sharma (Manager) and that the building / premises is fit for occupancy class "Assembly" (Banquet Hall) /Group 'D' with effect from 23 / 01 /2017 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of conditions printed below.

Issued on ...23/1/17..... at New Delhi.

  
(ATUL GARG)  
CHIEF FIRE OFFICER.

23/1/17

Copy to :-

1. Sh. Rajiv Sharma (Manager), The Maidens Crown Banquets ( A unit of SRK Hospitality), Plot No. B-1, Udyog Nagar Industrial Area, New Delhi-110041.
2. Dy. Health Officer, Municipal Corporation, Rohini Zone, Sec.-5 Rohini, Delhi-11008.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

**INSPECTION REPORT**

Basement + G + 2 Upper Floors

1. Name & address of the building: The Maidens Crown Banquets  
( A unit of SRK Hospitality)  
Plot No. B-1, Udyog Nagar Industrial Area, New Delhi-41.
2. Type of Occupancy : Assembly (Banquet Hall)
3. Type of Case : New
4. Details of previous NOC : F6/DMS/MS/2013/413 dated 29/01/2013  
(For Industry)
5. Fire Safety directives Letter No. : NBC-IV
6. Date of inspection : 09/01/2017
7. Name of the Inspecting Officer : A.D.O. (Jwala Puri)
8. Name and designation of Officer  
from the building side : Mr. Rajeev Sharma
9. Year of Construction : 1996-Admn, Altrn.-2012
10. Applicant's letter No. : - Nil dated 03/11/2016

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC-IV Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12mtr	12mtr	MR
	• Gate width	5mtr	5mtr	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	3	MR
	• Basements	2	2 & 1 Ramp	MR
	b. Width of staircases			
	• Upper floors	2.00 mtr	2.00mtrx2, 1.50mtrx1	MR
	• Basements	1.50 mtr	2.00x1, 1.50x1 & 1 Ramp of 8.80 mtr width	MR (As basement is being used only for storage purpose)
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No of continuous staircase to terrace	1	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2mtr x 2	G.F.- 6.00mtrx1, 3.50mtrx1, 1.80mtrx1, 1.50mtrx1, 1.20mtrx1 1 <sup>st</sup> Floor- 2.00mtrx2, 1.50mtrx1, 1.15mtrx3. 2 <sup>nd</sup> Floor- 2.00mtrx2, 1.50mtrx1, 1.00mtrx1. Basement-2.00x1, 1.50x1, 8.80 mtr (Ramp)	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	12	20	M/R
		ISI	Provided	M/R



6.	First – Aid Hose Reels			
	• Total numbers on each floor	2	2	MR
	• Length of hose reel hose	30 Mtr.	30 Mtr.	MR
	• Nozzle diameter	5mm	5mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	Smoke	Provided	MR
	• Location of Main Panel	Ground Floor	Provided	MR
	• Location of Repeater Panel	Each Floor	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Each Floor	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants			
	• Size of riser/down-comer	150mm	150mm	MR
	• Number of hydrants per floor	2	2	MR
	• Hose Box	2	2	MR
12.	Yard Hydrants			
	• Total number of hydrants	Required	Provided (6)	MR
	• Hose Box	Required	Provided (6)	MR
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	2280LPM	2280LPM	MR
	➤ Head of main pump	70Mtr	70Mtr	MR
	➤ Number of main pumps	2	2	MR
	➤ Jockey pump out put	180LPM	180LPM	MR
	➤ Jockey pump head	70Mtr	70Mtr	MR
	➤ Standby Pump out put	2280LPM	2280LPM	MR
	➤ Standby Pump Head	70Mtr	70Mtr	MR
	➤ Auto Starting/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	900LPM	900LPM	MR
	➤ Head of the pump	70 Mtr	70 Mtr	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Under Ground Tank capacity	1,00,000 Ltr.	1,00,000 Ltr.	MR

N/26

15	Exit Signage	Required	Provided	M/R
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	Required	Provided	MR
	➤ Pressurization of lift lobby	Required	Provided	MR
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

Note:- Management has provided one external staircase made of iron having width 2.00 mtr & two internal staircases of concrete made (2.00 mtr x 1, 1.50mtr x1) going from 1<sup>st</sup> Floor to 2<sup>nd</sup> Floor. Total no. of staircases from 1<sup>st</sup> Floor to 2<sup>nd</sup> Floor are 3 No. (2.00 mtr x 2 & 1.50 mtr x 1).

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards of fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

D.O. (10)

*[Signature]*  
18/1/17

*[Signature]*  
9/1/2017

Signature of the Inspecting Officer

Name : Ashok Kumar Jaiswal

Designation : A.D.O. (Jwala Puri)

*[Signature]*  
19/1/17

FT/PLS

DD/W FT/FSL is put up for signature please.  
*[Signature]*