

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No. F6/DFS/MS/LPG/2017/SZ/120

Dated: 30/01/17

FIRE SAFETY CERTIFICATE

Certified that the M/s Prem Nath Motors Ltd. (Indian Gas Distributor), Plot No.4, West Kidwai Nagar, New Delhi-110029, comprised of ground floor only, owned/occupied by Prem Nath Motors Ltd was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/2013/LPG/SZ/1192, dated 12-11-2013. The premises was re-inspected by the officer concerned of this department on 20-01-2017 in the presence of Sh. Sabhajeet Pandey (Godown Incharge) and found that the said LPG godown building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Storage (LPG Godown) with effect from 30/01/2017 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 30/01/2017 at New Delhi by.


(Vipin Kental)
Chief Fire Officer
T.No.011-23412225

Copy to:-1. The Medical Officer Health, NDMC, Palika Kendra, New Delhi.

2. M/s Prem Nath Motors Ltd. (Indian Gas Distributor), Plot No.4, West Kidwai Nagar, New Delhi-110029.

Conditions for the validity of fire safety certificate are as under:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate on form J, six month prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : M/s Prem Nath Motors Ltd. (Indian Gas Distributor), Plot No.4, West Kidwai Nagar, New Delhi-110029.
2. Building is comprised of : Ground Floor only.
3. Type of Occupancy : Storage (LPG Godown).
4. Type of Case : Old Case
5. Details of Previous NOC : No.F.6/DFS/MS/2013/LPG/SZ/1192, dated-12.11.2013.
6. Fire Safety direction letter No : F6/DFS/MS/LPG/10/867, Dated 22.03.2010.
7. Date of Inspection : 20.01.2017
8. Name of the Inspecting Officers: : Vedpal (ADO)
9. Name and designation of officer from the building side : Sh. Sabhajeet Pandey (Godown Incharge)
10. Year of Construction : Not Known.
11. Applicant's letter No. : Nil, dated 09.01.2017.

S.No	Minimum Standards on fire prevention and fire safety U/R33	Requirements/ Existing Fire Protection System	Provided at Site	Remarks
1	Access to building			
	Road width	Accessible	9m	MR
	Gate width	N.A.	N.A.	N.A.
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits.			
a. Number of Staircases Upper Floor Basement B. Width of Staircases Upper Floor Basement c. Protection of exits Fire check door Pressurization e. No. of continuous staircases to terrace. g. Width of Corridor h. Door Size		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		1m	1m	MR
	3	Compartmentation		
Fire check door Sealing of electrical shafts Fire rating of shaft door Water curtain Fire Dampers		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
4	Smoke Management System.			
Basement Upper floor		30a/c per hour	N.A.	N.A.
		Lower level & upper Level wire mesh	Provided at Both levels.	MR
5.	Fire Extinguisher			
Total numbers types IS marking		02 nos.+3 sand Buckets	04 nos.+ 6 nos. Sand buckets	MR
		DCP	WCO ₂ & ABC	MR
		ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
Total numbers of each floor Length of hose reel hose Nozzle diameter		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
7	Automatic fire detection and alarming system.			
		N.A.	N.A.	N.A.

8	MOEFA	N.A.	N.A.	N.A.
9	Public address System.	N.A.	N.A.	N.A.
10	Automatic Sprinkler System.			
	Basement/Lower ground floor	N.A.	N.A.	N.A.
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	N.A.	N.A.	N.A.
	Number of hydrants per floor	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	• Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual Stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	• Terrace Level	N.A.	N.A.	N.A.
	➤ Discharge of pump	N.A.	N.A.	N.A.
	➤ Head of the Pump	N.A.	N.A.	N.A.
	➤ Power supply	N.A.	N.A.	N.A.
	➤ Auto Starting of pump	N.A.	N.A.	N.A.
14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	N.A.	N.A.	N.A.
15	Exit Signage. <i>Two emergency signages.</i>	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	N.A.	N.A.	N.A.
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.

N/A

M/s Prem Nath Motors Ltd. (Indian Gas Distributor), Plot No.4, West Kidwai Nagar, New Delhi-110029.

20	Special Fire Protection Systems for of special Risks, if any:	1.No electric Connection/point. 2. No smoking Sign boards	1.No electric connection Or point in godown area. 2. No smoking sign Boards provided.	MR
----	---	--	--	----

The fire protection systems provided in the building were test checked randomly and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the FSC issued vide letter No.F6./DFS/MS/2013/LPG/SZ/1192, dated 12.11.2013, renewed under rule 37 of the Delhi Fire Service Rule 2010 is recommended.


Accordingly reply letter in shape of DFA is put up for kind consideration and approval Please.


Signature of the Inspecting Officer


Name : Vedpal

Designation : ADO

~~D.O. (SD)~~


23/11/17

dy. ch. (C2)


24/11/17

556/Chosr
27/11/17
30/11/17

CFOS 27/11/17 FT 100.
M-SCM.

W
27/11