

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No F 6 / DFS / MS / 2017 / School / W 2 / 193

Dated: 3 / 2 / 2017

**FIRE SAFETY CERTIFICATE**

Certified that the **A-One International Public School located at B-Block, Inder Enclave Phase-I, Delhi-110086** comprised of basement + Ground and 03 upper floors (School is running at Basement + Ground & first floor only) owned/ occupied by Dayanand Trust / Regd. was granted Fire Safety Certificate vide this department letter no. F-6/DFS/MS/2012/School/2520 dated 13.07.2012, have deemed complied with the fire prevention and fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 23.12.2016 in the presence of **Mr. Dalbir / Manager** and that the building premises is fit for **occupancy class "Group B Educational" for basement + Ground & first floor only** with effect from ...3/2/17..... for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
8. This Fire Safety Certificate is valid for Ground and First Floor only.

Issued on ...3/2/17..... at New Delhi

  
(Atul Garg)

Chief Fire Officer  
Ph:-011-23414250

AK

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.

117

**INSPECTION REPORT**

1. Name & address of the building : A-One International Public School B-Block, inder Enclave Phase-I  
: Delhi-110086.
2. Type of Occupancy : Educational (B + G + 03 Upper floor) **School is running at B+G+01**
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2012/School/2520 dated: 13/07/2012 (B + G + 01)
5. Fire Safety directives letter No : Director of Education Circular dated 01.03.2011.
6. Date of inspection : 23/12/2016
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers  
from the building side : Mr. Dalbir (Manager)
9. Year of Construction : 2010-2014
10. Applicant's letter No. : Nil Dairy no. 11620 dated: 09/11/2016

**Total Area : 4100sqm    Covered Area :2974.93sqm    No. of Class Room :47    Nos of Studends:800**

|   | <b>Minimum Standards on fire prevention and fire safety U/R 33</b> | <b>Dir. Of Education Requirement</b> | <b>Provided at site</b> | <b>Remarks MR/NMR</b> |
|---|--|--------------------------------------|-------------------------|-----------------------|
| 1 | <b>Access to building</b>  |                                      |                         |                       |
|   | • Road width   | 6m.                                  | 12m                     | MR                    |
|   | • Gate width   | 4.5m                                 | 5m                      | MR                    |
|   | • Width of internal road   | 05                                   | 06m                     | MR                    |
| 2 | <b>Number, Width, Type &amp; Arrangement of Exits</b>              |                                      |                         |                       |
|   | <b>a. Number of staircases</b>                                     |                                      |                         |                       |
|   | • Upper Floors   | 02                                   | 02                      | MR                    |
|   | • Basements  | 02                                   | 02                      | MR                    |
|   | <b>b. Width of staircases</b>                                      |                                      |                         |                       |
|   | • Upper Floors   | 1.50 m                               | 1.25 & 1.50m(Old case)  | MR                    |
|   | • Basements  | 1.50m                                | 1.25 & 1.50m(old case)  | MR                    |
|   | <b>c. Protection of exits</b>                                      |                                      |                         |                       |
|   | • Fire check door  | NA                                   | NA                      | NA                    |
|   | • Pressurization   | NA                                   | NA                      | NA                    |

2/18

|   |  |                 |          |    |
|---|--|-----------------|----------|----|
|   | d. No. of continuous staircases to terrace           | 02              | 02       | MR |
|   | e. Width of Corridor                                 | Required        | 2.80m    | MR |
|   | f. Door Size   | 1m              | 1.05m    | MR |
| 3 | <b>Compartmentation.</b>                             |                 |          |    |
|   | • Fire check door                                    | NA              | NA       | NA |
|   | • Sealing of electrical shafts                       | NA              | NA       | NA |
|   | • Fire Rating of shaft door                          | NA              | NA       | NA |
|   | • Water Curtain                                      | NA              | NA       | NA |
|   | • Fire Dampers                                       | NA              | NA       | NA |
| 4 | <b>Smoke Management System.</b>                      |                 |          |    |
|   | • Basements  | 30 a/c per hour | NA       | NA |
|   | • Upper floors                                       | 12 a/c per hour | NA       | NA |
| 5 | <b>Fire Extinguishers</b>                            |                 |          |    |
|   | • Total numbers                                      | 12nos           | 12nos    | MR |
|   | • Types  | CO2/ ABC        | ABC-12   | MR |
|   | • ISI marking  | Yes             | Yes      | MR |
| 6 | <b>First-Aid Hose Reels.</b>                         |                 |          |    |
|   | • Total numbers on each floor                        | 01              | Provided | MR |
|   | • Length of hose reel hose                           | 30 m            | 30m      | MR |
|   | • Nozzle diameter                                    | 5mm             | 5mm      | MR |
| 7 | <b>Automatic fire detection and alarming system.</b> |                 |          |    |
|   | • Type of detectors                                  | NA              | NA       | NA |
|   | • Location of Main Panel                             | NA              | NA       | NA |
|   | • Location of Repeater Panel                         | NA              | NA       | NA |
|   | • Alternate source of power                          | NA              | NA       | NA |
|   | • Hooters' Location                                  | NA              | NA       | NA |
| 8 | <b>MOEFA</b>   | NA              | NA       | NA |
| 9 | <b>Public Address System.</b>                        | NA              | NA       | NA |

2/19

|    |   |            |             |    |
|----|---|------------|-------------|----|
| 10 | <b>Automatic Sprinkler System.</b>  |            |             |    |
|    | <ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>  | Required   | Provided    | MR |
|    |   | NA         | NA          | NA |
|    |   | NA         | NA          | NA |
| 11 | <b>Internal Hydrants</b>  |            |             |    |
|    | <ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>  | NA         | NA          | NA |
|    |   | NA         | NA          | NA |
|    |   | NA         | NA          | NA |
| 12 | <b>Yard Hydrants.</b>   |            |             |    |
|    | <ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>  | NA         | NA          | NA |
|    |   | NA         | NA          | NA |
| 13 | <b>Pumping Arrangements.</b>  |            |             |    |
|    | <ul style="list-style-type: none"> <li>• Ground Level <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/ Manual stopping</li> <li>➤ Pump House Access</li> </ul> </li> <li>• Terrace level <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul> </li> </ul> |            |             |    |
|    |   | NA         | NA          | NA |
|    |   | NA         | NA          | NA |
|    |   | NA         | NA          | NA |
|    |   | NA         | NA          | NA |
|    |   | NA         | NA          | NA |
|    |   | NA         | NA          | NA |
|    |   | NA         | NA          | NA |
|    |   | NA         | NA          | NA |
|    |   | 900 lpm    | 900 lpm     | MR |
|    |   | 40m        | 40m         | MR |
|    |   | Required   | Provided    | MR |
|    |   | Required   | Provided    | MR |
| 14 | <b>Captive Water Storage for fire fighting.</b>   |            |             |    |
|    | <ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>  | NA         | NA          | NA |
|    |   | NA         | NA          | NA |
|    |   | NA         | NA          | NA |
|    |   | NA         | NA          | NA |
|    |   | 15,000 ltr | 15,000 ltr. | MR |

2/20

|    |  |          |          |     |
|----|--|----------|----------|-----|
| 15 | <b>Exit Signage.</b>   | Required | Provided | MR  |
| 16 | <b>Provision of Lifts.</b>   |          |          |     |
|    | • Pressurization of Lift Shaft   | N/A      | N/A      | N/A |
|    | • Pressurization of Lift lobby   | N/A      | N/A      | N/A |
|    | • Communication In lift Car  | NA       | NA       | NA  |
|    | • Fireman's Grounding Switch   | NA       | NA       | NA  |
|    | • Lift Signage   | NA       | NA       | NA  |
| 17 | <b>Standby power supply</b>  | NA       | NA       | NA  |
| 18 | <b>Refuge Area.</b>  |          |          |     |
|    | ➤ Total Area   | NA       | NA       | NA  |
|    | ➤ Location   | NA       | NA       | NA  |
| 19 | <b>Fire Control Room</b>   |          |          |     |
|    | • Detector System Panel  | NA       | NA       | NA  |
|    | • Flow Switch Panel  | NA       | NA       | NA  |
|    | • PA System Panel  | NA       | NA       | NA  |
|    | • Battery backup   | NA       | NA       | NA  |
|    | • Building Floor Plans   | NA       | NA       | NA  |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any: |          |          |     |

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in Director of Education Circular dated 01.03.2011 the FSC issued vide letter of even no 2520 dated 13.07.2012 renewal under rule 35 of the Delhi Fire Service Rules, 2010 is recommended

11/11/2017

Signature of the Inspecting Officer

Name :- Rajesh Kumar

Designation:- ADO/RN

DD/N/20  
Slyh  
24/1/17  
Dueso/102

25/1/17