

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2017 / *School/WZ/145*

Dated: 3 / 2 / 2017

FIRE SAFETY CERTIFICATE

Certified that the **Sarvodaya Vidyalaya, New Police Lines Kingsway Camp, Delhi-09** comprised of **ground + three upper floors** owned/ occupied by **Sarvodaya Vidyalaya** was granted fire safety certificate vide this office letter no. **F.6/DFS/MS/School/2013/WZ/985** dated **27/09/2013** have deemed complied with the fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 20.01.2017 in the presence of **Mr. Rohtash Singh, Principal** and that the building/premises is fit for occupancy **Group B Educational** with effect from*3.12.17*..... for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

- 1 All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
- 2 Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 This certificate cannot be treated in any case for regularizations of unauthorized construction.
- 6 The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
- 7 The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on ...*3.12.17*..... at New Delhi

(Signature)
(Atul Garg)
Chief Fire Officer
Ph:-011-23414250
07/1

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 54.
2. The Principal, Sarvodaya Vidyalaya, New Police Lines Kingsway Camp, Delhi-09.

2/13

INSPECTION REPORT

1. Name & address of the building : Sarvodaya Vidyalaya, New Police Lines Kingsway Camp Delhi-110009.

2. Type of Occupancy : **Educational**

3. Type of Case : Renewal **(G + 3 upper floor)**

4. Details of previous NOC : F.6/DFS/MS/School/2013/WZ/985 Dated 27/09/2013

5. Fire Safety directives letter No : NBC Part-IV

6. Date of inspection : 20/01/2017

7. Name of the Inspecting Officers : ADO (R/N)

8. Name and designation of officers

from the building side : Sh. Rohtash Singh (Principal)

9. Year of Construction : 1982

10. Applicant's letter No. : SV/NPL/2016/840 dated 25/11/2016

Plot area-5540 Sq.yds. Covered area-4742Sq.yds No's of student-2001 No's of class room-37

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part-IV	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	9 mtr	18mtr	M/R
	• Gate width	4 mtr	5.05 mtr	M/R
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	M/R
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper Floors	1.5 mtr	1.42M both	M/R
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01	01	M/R
	g. Width of Corridor	1.5M	1.5 M	M/R
	h. Door Size (Each class rooms having two exit doors)	1 mtr	1mtr	M/R

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Water Curtain 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fire Dampers 	N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements 	30 a/c per hour	N/A	N/A
	<ul style="list-style-type: none"> • Upper floors 	12 a/c per hour	N/A	N/A
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	16	16	M/R
	<ul style="list-style-type: none"> • Types 		ABC / CO2	M/R
	<ul style="list-style-type: none"> • IS marking 	ISI marked	Yes	M/R
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor 	02	02	M/R
	<ul style="list-style-type: none"> • Length of hose reel hose 	30 m	30m	M/R
	<ul style="list-style-type: none"> • Nozzle diameter 	5 mm	5mm	M/R
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Location of Main Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Location of Repeater Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Alternate source of power 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Hooters' Location 	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Upper Floor 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	N/A	N/A	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	100 mm	Provided	M/R
	<ul style="list-style-type: none"> • Number of hydrants per floor 	02	02	M/R
	<ul style="list-style-type: none"> • Hose Box 	02	02	M/R

M11

12	Yard Hydrants.			
	• Total number of hydrants	N/A	Provided	N/A
	• Hose Box	N/A	Provided	N/A
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM	450 LPM	M/R
	➤ Head of the pump	40 m	Provided	M/R
	➤ Power Supply	N/A	N/A	N/A
	➤ Auto Starting of pump	Required	Provided	M/R
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 ltr	10,000 ltr	M/R
15	Exit Signage.		Required	Provided
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply		N/A	N/A

09/10

18	Refuge Area.			
	➤ Total Area-	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no **F.6/DFS/MS/School/2013/WZ/985 Dated 27/09/2013.** Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Name *Suresh Singh*

Designation *DO (R/P) D*

S Singh

25.1.17

Dy CPO (WZ)

Signature of the Inspecting Officer

Name *Rajesh Kumar*

Designation *ADO/RN*

[Signature]
25/1/17