

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2017 / *school/wz/139*

Dated: *3/2/2017*


**FIRE SAFETY CERTIFICATE**

Certified that the **Savita Public School, Opp. Gali No. -3, Main Road, Wazirabad Village, Delhi-84** comprised of **ground and 01 & Half floors** owned/ occupied by the **Savita Public School** was granted fire safety certificate vide this office letter no. **F.6/DFS/MS/School/WZ/1286** dated **05/12/2013** have deemed complied with the fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 16.01.2017 in the presence of **Mrs. Asha Shakoja, Principal** and that the building/premises is fit for occupancy **Group B Educational** with effect from *3/2/17*..... for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

Issued on *3/2/17*..... at New Delhi

  
(Atul Garg)  
Chief Fire Officer  
Ph:-011-23414250  
*of u*

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 54.
2. The Principal, Savita Public School, Opp. Gali No. -3, Main Road, Wazirabad Village, Delhi.

INSPECTION REPORT

1. Name & address of the building : Savita Public School, Opp. Gali No. - 3, Main Road, Wazirabad Village , Delhi-84.
2. Type of Occupancy : Educational
3. Type of Case : Renewal (Ground + 01 & Half floor)
4. Details of previous NOC : F6/DFS/MS/School/WZ/1286 Dated: 05/12/2013
5. Fire Safety directives letter No : Director of Education Letter dated 01.03.2011/ NBC Part 4.
6. Date of inspection : 16/01/2017
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers  
from the building side : Mrs. Asha Shakoja / Principal
9. Year of Construction : 2000
10. Applicant's letter No. : Nil dated 11/11/2016

Plot Area-2000sq.m Covered area --750sq.m No of student—450 nos, No.of class room --20nos

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	6m	6m	MR
	• Gate width	4.5m	3.86m(Old case)	MR(old case)
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02	03	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50 m	1.27m, 92cm & 1.37m	MR(Old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	02	MR
	e. Width of Corridor	Required	90cm	MR
f. Door Size	1.0m	95cm(Old case)	MR(Old case)	
3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA



1/18

	<ul style="list-style-type: none"> <li>Sealing of electrical shafts</li> <li>Fire Rating of shaft door</li> <li>Water Curtain</li> <li>Fire Dampers</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>Basements</li> </ul>	30 a/c per hour	No basement	NA
	<ul style="list-style-type: none"> <li>Upper floors</li> </ul>	12 a/c per hour	Natural Ventilated	MR
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> </ul>	6nos	7 nos	MR
	<ul style="list-style-type: none"> <li>Types</li> </ul>	ABC/Co2	ABC--7	MR
	<ul style="list-style-type: none"> <li>ISI marking</li> </ul>	Yes	Yes	MR
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>	01	01	MR
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	30m	30m	MR
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	5m	5m	MR
7	<b>Automatic fire detection and alarming system</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Hooters' Location</li> </ul>	NA	NA	NA
8	<b>MOEFA</b>	NA	NA	NA
9	<b>Public Address System.</b>	NA	NA	NA
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	NA	NA	NA
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	NA	NA	NA
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	NA	NA	NA
13	<b>Pumping Arrangements.</b>			

1/18

2/15

	<ul style="list-style-type: none"> <li>• Ground Level               <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/ Manual stopping</li> <li>➤ Pump House Access</li> </ul> </li> <li>• Terrace level               <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul> </li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		450lpm	450 lpm	MR
		30m	Provided	MR
		Required	Provided	MR
		Required	Not Provided	MR
14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		5,000ltr	5,000 ltr(old case)	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	<b>Standby power supply</b>	N/A	N/A	N/A
18	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A

M/18

	<ul style="list-style-type: none"><li>• PA System Panel</li></ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"><li>• Batter backup</li></ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"><li>• Building Floor Plans</li></ul>	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found in working conditions at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC art 4, the FSC issued vide letter of even no. 1286 dated 05.12.2013 renewed under rule 35 of the Delhi Fire Service rules 2010 is recommended.

M/ 23/1/17

Signature of the Inspecting Officer  
Name :- Rajesh Kumar  
Designation:- ADO/RN

DO / NW  
Shy  
23.1.17  
Dy CPO (WZ)  
CPO West / W  
27/1/17

25/1/17