

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

NO. F6/DFS/MS/CGHS/2017/SZ/ 176

Dated: 8/2/17

FIRE SAFETY CERTIFICATE

Certified that the Shama CGHS Ltd. located at Plot No. 32, Sector-10, Dwarka Phase-1, New Delhi-110075, comprised of three high rise blocks having stilt plus six/seven & Ground plus seven upper floors owned / occupied by Shama CGHS Ltd. was granted NOC by this department vide letter no. F6/MS/DFS/CGHS/2000/2281 dated 14.12.2000. The premises was re-inspected by the officers concerned of this department on 30.12.2016 in presence of Sh. Ranjeet Singh (Manager) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and that the premises / building is fit for occupancy of class A-4, Residential Building (Apartment) with effect from 8/2/17 for a period of **Five years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed overleaf.

Issued on ...8/2/17..... at New Delhi by


(Vipin Kental)
Chief Fire Officer


Copy to:

- 1 Secretary, The Shama CGHS Ltd. located at Plot No. 32, Sector-10, Dwarka Phase-1, New Delhi-110075
- 2 Joint Director, (L&I) DDA, Vikas Sadan, INA, New Delhi.

1	Name & address of the building	The Shama CGHS Ltd., Plot No.32, Sector-10, Dwarka, Phase-1, New Delhi-110075		
2	Type of Occupancy	Residential Building "A" (CGHS)		
3	Type of case	Renewal	Stilt plus 6/7 upper floors	& Ground +7 upper floors
4	Details of previous NOC	F6/MS/DFS/CGHS/2000/2281 Dated 14.12.2000		
5	Fire safety directives letter No	F6/MS/DFS/CGHS/96/944 dated 8.8.1996		
6	Date of inspection	31.12.2016		
7	Name of the inspecting Officers :	DO M K Chattoupadhyay, ADO SP Bhardwaj		
8	Name and designation of officers from the building side	Sh. Ranjeet Singh (Manager)		
9	Year of construction	2001		
10	Applicant's letter No. Nil dated 8.6.2016	Nil dated 26.11.2016	A & B Block G+7 upper floors, C Block Stilt + 6/7 upper floors	Three blocks

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	09 Mtrs.	12 Mtrs.	MR
	2) Gate width	4.5 Mtrs.	5 Mtrs.	MR
	3) Width of internal road	6 Mtrs.	6 Mtrs.	MR
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	4 Nos.	4 Nos.	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.25 Mtrs., 90 Cms.	A Block: 1.15 & .83 B Block: 1.18 C Block: 1.18 Mtrs. B & C Block interconnected at 3rd floor	MR being old case
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	One each block	One each block	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1 Mtr.	1 Mtr.	MR
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	Required	Provided	MR
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	N/A	N/A	N/A
	upper floors	Page	N/A	N/A

5	Fire Extinguishers			
	total numbers	2 Nos. each	48 Nos.	MR
	Types	floor each block	Co2 ABC	MR
	ISI marking	Co2, W. Co2 ISI Marked	ISI Marked	MR
6	First-Aid Hose Reels.			
	total numbers on each floor	One	One No. each block	MR
	Length of Hose reel hose	30 m	30 m	MR
	Nozzle Diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System.	N/A	Provided	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	100 mm	100 mm	MR
	Number of Hydrants per floor	One	One each block	MR
	Hose Box	Required	Provided	MR
12	Yard Hydrants.			
	Total number of hydrants	Four	One each block	MR
	Hose box	Four	Four	MR
13	Pumping arrangements			
	1. Ground level/			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	450 LPM each	450 LPM (Each block)	MR
	b. head of the pump	40 Mtrs. each	40 Mtrs. each	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	2,00, 000 Ltrs.	2,00,000 Ltrs.	
	a. Draw-off connection	Required	Provided	MR
	b. fire service inlet	Required	Provided	MR
	c. Access to tank	Required	Provided	MR
	Over head tank Capacity	10000 Ltrs.	10000Ltrs.(each Block)	MR

N/A

15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	Required	Provided	MR
	d. Fireman's grounding switch	Required	Provided	MR
	e. Lift signage	Required	Provided	MR
17	Standby power supply	Required	DG Set	MR
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. Detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	Provided	N/A
	d. Batter backup	N/A	Provided	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: near electric panel		Co2 fire etinguisher	MR

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, renewal of Fire Safety Certificate issued vide letter no. F6/MS/DFS/CGHS/2000/2281 Dated 14.12.2000 is recommended under rules 37 of the Delhi Fire Service Rules, 2010.

Accordingly DFA is put up for approval and signature please.

[Signature]
23/01/2017

signature of inspecting officer II

Name M K Chattopadhyay

Designation DO (South West)

[Signature]
10/1/17

Signature of the Inspecting Officer I

Name S.P Bhardwaj

Designation ADO (DWARKA)

[Signature]
DCFO (SZ)

[Signature]
25/1

F.T. letter

m. s. ceo

[Signature]
27/1

F.T. letter is put up for signature please



562/ds2
31/1/17/18/2
[Signature]