

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110 001


No. F6/DFS/MS/SCHOOL/2017/ W2/203

Dated: 10/02/17

FIRE SAFETY CERTIFICATE

Certified that the Deepanshu Public Sr. Sec. School located at Kamerdin Nagar, Nangloi, Delhi-41, in a building comprised of Ground + Two Upper Floors only, owned and occupied by Deepanshu Public Sr. Sec. School, has already been issued NOC / FSC by this department vide letter No. F.6/DFS/MS/School/2215 dated 1.8.2008. The premises was re-inspected by the officer concerned of this department on 18.01.2017 in the presence of Sh. Anil Kumar Yadav (Principal), and observed that Fire prevention and fire safety arrangements provided in the premises, found in good working condition. The premises have therefore, deemed complied with the fire prevention and fire safety requirements in accordance with the circular issued by Circular No. 262-362 dated 17/01/2005 and that the building / premises is fit for occupancy class Educational (Group B) with effect from 10/02/17 for a period of 3 (three) years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS Rules, 2010.

Issued on 10/02/17 at New Delhi by.


(ATUL GARG)
CHIEF FIRE OFFICER.

Copy to :-

1. Principal, Deepanshu Public Sr. Sec. School, Kamerdin Nagar, Nangloi, Delhi-41.

Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment's shall be maintained in perfect working conditions all the time and any lapse rendering non functional of fire safety measures, management shall be responsible.
4. Any deviation with regards to construction, electrical installation etc. may be got verified from the concerned authorities.
5. This NOC may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.

1. Name & address of the building: **Deepanshu Public Sr. Sec. School, Kamerdin Nagar, Nangloi, Delhi-41**
2. Type of Occupancy : Educational (G+2) (Total Area-3350m²)
3. Type of Case : Renewal (Covered Area-1079 m²)
4. Details of previous NOC : F6/DFS/MS/2008/2215 dated 1/8/2008
5. Fire Safety directives Letter No. : DOE Circular dated 17.01.2005
6. Date of inspection : 18/01/2017
7. Name of the Inspecting Officer : A. K. Jaiswal
8. Name and designation of Officer
from the building side : Sh. Anil Kumar Yadav (Principal)
9. Year of Construction : 1996
10. Applicant's letter No. : DPS/1110/16/69 dated 16/12/2016

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE. Circ. Dated 17/01/05 Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 mtr	6 mtr	MR
	• Gate width	5 mtr	5 mtr	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	3	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	150 mtr	1.76 mtr x 1 1.50 mtr x 1 1.30 mtr x 1	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1	1	MR
	e. Width Of Corridor	1.50 mtr	1.50 mtr	MR
	f. Door Size	1.00 mtr	1.00 mtr	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers			
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	4	10	MR
	• Types	ISI marked ABC/CO ₂	Provided	MR
	• IS marking	Required	Provided	MR

6.	First - Aid Hose Reels			
	• Total numbers on each floor	1	1	MR
	• Length of hose reel hose	30 Mtr.	30 Mtr.	MR
	• Nozzle diameter	6.5 mm	6.5 mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	1	1	MR
	• Hose Box	1	1	MR
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level	N/A		
	• Discharge of main pump	N/A	N/A	
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 Lit/Mint. X 1, 180 Lit/Mint. X 1	450 Lit/Mint. X 1, 180 Lit/Mint. X 1	MR
	➤ Head of the pump	40 Mtr. Head	40 Mtr. Head	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Under Ground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	Provided	N/A
	➤ Access to tank	N/A	N/A	N/A

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

Note:- No General requirements mentioned in the schools as per Director of Education circular dated 17/01/2005. However management must adhere following safety measures.

1. Escape routeClear.....
2. LPG cylinders in laboratoriesNil.....
3. Electric wiring ...Conduit Wiring..... MCB and ELCB Provided.....
Electric circuit
4. Electric meter boardNot under the staircase.....
5. Basement use as per BBL 1983NA.....
6. Emergency telephone no. boardDisplayed.....
7. Generator setNil.....

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. **F6/DFS/MS/2008/2215 dated 1/8/2008** renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

D.P./CO

Ashok Kumar Jaiswal
22/1/2017

Signature of the Inspecting Officer

Name : Ashok Kumar Jaiswal

Designation : A.D.O. (Jwala Puri)

Ashok Kumar Jaiswal
31/1/17

A.D.O. (W2)
AO work
3/2/17
CT DTC

Ashok Kumar Jaiswal
31/1/17

F.T. as put up for sign. please.