

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI

No.F6/DFS/MS/School/2017/MD2/198

Dated: 10/02/17

FIRE SAFETY CERTIFICATE

Certified that the **Nisheman Primary School** located at **21, Raj Niwas Marg, New Delhi-110054** comprised of **Ground floor** was granted NOC by this department vide letter No.F6/MS/DFS/2006/1293 dated **08/06/06**. The premises was re-inspected by the officer concerned of this department on **31/01/17** in the presence of **Mr. Maxwell (Supervisor)** and found that school added first floor and now building comprises ground & first floor, have deemed complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education dated 01.03. 2011 that the building is fit for occupancy, class **B "Educational Building"** with effect from10/02/17.....for a period of three years, subject to conditions printed below.

Issued on10/02/17..... at New Delhi.


(Vipin Kental)
Chief Fire Officer
Delhi Fire Service

Copy to:- (1) Nisheman Primary School,
21,Raj Niwas Marg,New Delhi-110054.
(2) Director of Education,
Old Secretariat, Delhi.

Conditions for the validity of fire safety certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire protections measures shall be maintained in perfect conditions all the time as seen during inspection.
3. All the staff members must know the correct method of operation of fire fighting system.
4. Any lapse rendering fire fighting system/equipment non-functional shall be the risk and responsibility of the management.
5. This inspection report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010.the form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

M-5
INSPECTION REPORT

Barrier - C.F. only
Presently - G.F. + F.F.

- | | |
|--|--|
| 1. Name & address of the building :- | Nisheman Primary School, 21, Raj Niwas Marg, New Delhi-110054. |
| 2. Type of occupancy:- | Group – B Education Building Gr. +1 |
| 3. Type of case:- | Renewal. |
| 4. Details of previous NOC:- | No.F6/MS/DFS/2006/1293 dated 08/06/06. |
| 5. Fire safety directives No.- | N/A |
| 6. Date of inspection:- | 31/01/17 |
| 7. Name of the inspecting officer:- | D.O. Gurmukh Singh. |
| 8. Name & designation of officer:-
From the building side:- | Mr. Maxwel (Supervisor). |
| 9. Year of construction:- | Old. |
| 10. Applicant's letter No:- | Nil. Dated 30/11/16 |

Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/Circular	As per Education Circular	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	Approachable	6 mtr.	MR
	2) Gate width	Required	4.5 mtr.	MR
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	2 no.	2 no.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.50 mtr.	2.18 mtr. & 2.40 mtr.	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace			
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1 mtr.	1 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 a/c per hour	N/A	N/A
	2) Upper floors	12 a/c per hour	Natural	MR
5.	Fire Extinguishers			

h

11-4

	1) Total numbers	08 Nos	08 Nos.	MR
	2) Types	ABC & co2	ABC & co2	MR
	3) ISI marking	ISI Marked	Yes	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	N/A	N/A	N/A
	2) Length of hose reel hose	N/A	N/A	N/A
	3) Nozzle diameter	N/A	N/A	N/A
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A

hr

N-5

	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	N/A	N/A	N/A
15.	Exit Signage.	N/A	N/A	N/A
16.	Provision of Lifts.	N/A	N/A	N/A
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:-			N/A

The fire protection system provided in the school were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No.F6/MS/DFS/2006/1293 dated 08/06/06, renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended.

Gurmukh Singh
1/2/17
Gurmukh Singh
Divisional Officer

221/cfo N D 2
2/2/17/9/2

Dy Cfo (N D 2)

3/2 F 7 181

C.F.P. m.s.c.u. 7/2

Letter is put up for signature