

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

NO.F6/DFS/MS/School/2017/SZ/ 207

Dated: 10/02/17

FIRE SAFETY CERTIFICATE

Certified that the Sant Public School, located at CD-127, Mahavir Enclave, New Delhi-110045 comprised of ground plus one upper floor was granted NOC by this department vide letter No.F6/DFS/MS/School/2013/224 dated 14.1.2013. The building was re-inspected by the officer concerned of this department on 27.1.2017 in presence of Sh. Vijay Kumar (Manager) and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education, GNCT of Delhi Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011, and that the building is fit for occupancy class B "Educational building" with effect from.....10/02/17 for a period of **three years**, subject to compliance of the conditions printed overleaf.

Issued on10/02/17..... at New Delhi by


(Vipin Kental)
Chief Fire Officer


Copy to:

1. Deputy Director (Education), GNCTD, Old Secretariat, New Delhi-110054.
2. Manager, Sant Public School, CD-127, Mahavir Enclave, New Delhi-110045.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	Sant Public School , CD-127, Mahavir Enclave, New Delhi-110045.		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	Renewal (Ground & First Floor)		
4	Details of previous NOC	F6/DFS/MS/School/2013/224 dated 14.1.2013.		
5	Fire safety directives letter No	Directorate Of Education Circular. No. F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011.		
6	Date of inspection	27.01.2017		
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Sh. Vijay Kumar (Manager)		
9	Year of construction	Before 2007		
10	Applicant's letter No.	SPS/62/2017 dated 10.01.2017	(Ground plus One upper floor.	
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	Fire safety requirements as DOE letter dated 01.03.2011	Fire safety systems provided as per letter dated 4.4.2007	Remarks MR / NMR
1	Access to building			
	1) Road width	6 Mtrs.	6 Mtrs.	MR
	2) Gate width	4.5 Mtrs.	Direct Accessible from road	MR
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	Two	Two	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.50 Mtrs. if less than 1.50 Mtrs. additional fire escape staircase of .75 Mtr. required	80 Cms. & .75 Cms.	MR being old case
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	One	One	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	Old case	83 Cms x 200 Cms.	MR being old case
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement		N/A	N/A
	upper floors	N/A	N/A	N/A
5	Fire Extinguishers			
	total numbers	5 Nos. Co2 OR ABC	5 Nos	MR
	Types	ISI Marked	ABC	MR

6	First-Aid Hose Reels.			
	total numbers on each floor	N/A	Provided	N/A
	Length of Hose reel hose	N/A	30 Mtrs.	N/A
	Nozzle Diameter	N/A	5 MM	N/A
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	180 LPM	N/A
	b. Head of main pump	N/A	30 Mtrs.	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	N/A	N/A	N/A
	b. head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	N/A	N/A	N/A
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	N/A	2500 Ltrs.	N/A
15	Exit Signage.	N/A	N/A	N/A
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

Suy

M/11

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	Total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any:	ABC Fire Extinguisher provided		MR

The fire protection systems provided in the building were checked and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F6/DFS/MS/School/2013/224 dated 14/01/2013, renewal under the Directorate of Education circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01-03-2011 is recommended.

Accordingly DFA is put up for your approval and signature please.

Sury
30/1/17
S.P. Bhardwaj
ADO (Dwarka)

~~*DOSW*~~

~~*dg*~~ 2/2/17

~~*DCFO (SZ)*~~



~~*depl*~~
2/2

Choc/sz M. stell FT/M. 1/2 3/2

FT letter is put up for signature please.

~~*Ch/sz*~~ M. stell 1/2 8/2

Sury
8/2/17