

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/2017/School/209

Dated: 10/02/17

FIRE SAFETY CERTIFICATE

Certified that the **Vanasthali Public School at Block - G, Preet Vihar, Delhi** comprised of Ground plus one upper floor was granted FSC by this department vide letter no. F6/DFS/MS/ School/2014/NDZ/160 dated 31/01/2014. The premises was re-inspected by the officer concerned of this department on 27/01/2017 in the presence of Mrs Seema Sachdeva (Head Mistress) and found that the school have complied with the fire prevention and fire safety requirements in accordance with the circular No. 262-362 dated 17/01/2005 issued by the Director of Education and found that the premises is fit for occupancy **Class - B (Educational Building)** with effect from 10/02/17 for a period of three years, subject to compliance of the conditions printed overleaf.

Issued on.....10/02/17.....at New Delhi by


(Vipin Kental)
Chief Fire Officer

To-
The Head Mistress ,
Vanasthali Public School,
Block - G, Preet Vihar, Delhi - 110092

Copy to-
The Dy. Director of Education
D-Block, Anand Vihar, Delhi.

CONDITIONS

1. All the means of escape shall be kept free of all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety Certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. All comments/ directions of the Licensing Department shall always be permitted and followed.
7. The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

IRN/11

- 1 Name & address of the building : Vanasthali Public School, G- Block, Preet Vihar, Delhi 110092.
- 2 Building is comprised of : Ground + one floor.
- 3 Type of Occupancy : Educational
- 4 Type of Case : Renewal
- 5 Details of Previous NOC letter : F6/DFS/MS/SCHOOL/2013/NDZ/1128
Dated 23.10.2013
- 6 Fire Safety direction letter No : Old requirements (Circular No. 262-362
dated 17/01/2005
- 7 Date of Inspection : 27/01/2017
- 8 Name of the Inspecting officers : DO S.K. Dua
- 9 Name and designation of Officer
from the building side : Mrs. Seema Sachdeva (Head Mistress)
- 10 Year of Construction : 2005
- 11 Applicant's letter No : letter no. Nil dated 04/01/2017

NO	Minimum Standards on fire prevention and fire safety U/R33	Old Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	• Road width	06 m	06 m	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	2 No.	3 No. ✓	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper Floor	1.50 M or Less	1.04Mtr, 1.02 Mtr, 1.02 Mtr	MR (old case)
	• Basement			
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	01No.	02 No.	MR
	h. Door Size	1.50	1.50	MR
		01 Mtr	01 Mtr	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	10 Nos.	10 Nos.	MR
	• types	ABC & Co2	ABC & Co2 WCo2	MR
	• IS marking	Required	Provided	MR

ERN/13

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	N/A	N/A	N/A
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

S.K. Dua
2/11

Signature of the Inspecting Officer

Name- S.K. Dua

Designation- DO(ED)

DCFO (NDZ)

[Signature]

108/CFON02
24/12/14/12

C.F.O - M. Seenu

FTM
2/2

... please.