

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001


NO F 6/DFS/MS/EH/2016/213

Dated: 14.02.2017

FIRE SAFETY CERTIFICATE

Certified that the M/S Darzi Bar (A unit of Radioactive hospitality LLP) located at H- 55, H-89, 1ST & 2nd floor, Connaught Place New Delhi New Delhi-110001 building comprised of ground + 2 upper floors, and restaurant is running at 1ST & 2nd floor only owned/occupied by M/S Darzi Bar (A unit of Radioactive hospitality LLP), has complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by officer concerned of Delhi Fire Service on 02/12/2016 in the presence is Sh. Abhishk (Partner) and that the building / premises is fit for occupancy class Assembly /Building Group D, restaurant is running at 1ST & 2nd floor only with effect from 14.02.2017 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire service rule 2010, printed below.

Issued 14.02.2017 at New Delhi by.


Sunil Chawdhary
DY. Chief Fire Officer
Delhi Fire Service

o/c

copy to:-

(1) Medical Officer of Health,
New Delhi Municipal Council,
Palika Kendra New Delhi.

(2) The Manager, M/S Darzi Bar (A unit of Radioactive hospitality LLP)
H- 55, H-89, 1ST & 2nd floor, Connaught Place New Delhi New Delhi-110001

Condition for the validity of fire safety certificate

1. All the fire safety arrangement provided therein shall be maintained in good working conditions at all times.
2. All the means of escape shall be kept unobstructed /unlocked & remain available for speedy evacuation of occupants in case of an emergency.
3. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
6. The fire safety certificate may not be treated in any case for regularization of unauthorized construction if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi fire service 2010. The form is available on www.dfs.delhigovt.nic.in.
8. The owner / occupier shall apply for renewal of this fire safety certificated to the director in Form 'J' [sub rule (1) of rule 37] alongwith a copy of this certificate, six months prior to it expiry.

INSPECTION REPORT

1. Name & address of the building:- M/S Darzi Bar (A Unit of Radioactive Hospitality Pvt. Ltd.) H-55, H-89, 1st & 2nd floor, Cannought Place, New Delhi.
2. Type of occupancy:- Group – D Assembly Building
Gr. + 2 upper floor
(Restaurant at 1st floor & 2nd floor only)
3. Type of case:- New Case
4. Details of previous FSC:- N/A
5. Fire safety directives No.- N/A
6. Date of inspection:- 02/12/16
7. Name of the inspecting officer:- Sh. Sunil Chaudhary Dy. CFO/NDZ,
Sh. G.S. Chauhan DO/CD &
Sh. Manoj Kumar Sharma ADO/CC
8. Name & designation of officer
From the building side:- Sh. Abhishk (Partner)
9. Year of construction:- Pre. 1983
10. Applicant's letter No:- Nil dated 03/11/16.

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement BBL / NBC Part - VI	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	09 mtr.	18 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02 Nos.	02 Nos.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	0.80 & 1.5 mtr.	1.50 mtr. & 0.90 mtr.	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace			
		N/A	N/A	N/A
	E. Width of corridor			
		N/A	N/A	N/A
	F. Door size			
		1X2.mtr & 1 mtr.	1X2.mtr & 1 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	12 a/c per	Natural	MR




5.	Fire Extinguishers			
	1) Total numbers	05 Nos.	07 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	ISI	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number	01	01	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	5 mm	5 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 mm	100 mm	MR
	2) Number of hydrants per floor	01	01	MR
	3) Hose box	01	01	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 LPM	MR
	b) Head of pump	30 mtr.	30 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A

	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	10,000 ltrs.	10,000 ltrs.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

Shortcomings communicated vide letter No. F6/DFS/MS/2016/2380 dated 06/10/2016 have been rectified.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, grant of fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 / is recommended please.

Signature of the Inspecting Officer  Name :- Sh. Sunil Chaudhary Designation :- DCFO (NDZ)	Signature of the Inspecting Officer  Name :- G.S Chauhan Designation :- DO (CD)	Signature of the Inspecting Officer  Name :- M.K. Sharma Designation :- ADO (CC)
--	---	--

165/CFR NDZ
8/12/16.

C.F.C. beentat
2/12/16.

R/W.

F.t. letter is put up for signature please 8/12