

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / School/2017 / 216

Dated: 15 / 02 / 2017

FIRE SAFETY CERTIFICATE

Certified that the **M.C.D Primary Co-ed School**, located at **J-Block, Sec-16, Rohini, Delhi** comprised of **Ground floor only** owned/occupied by **M.C.D Primary Co-ed School** was granted FSC by this department vide letter no. **No.F6/DFS/MS/2013/WZ/851** dated **05.09.2013**. The premises was re-inspected by the officer concerned of this department on 27.01.2017 in presence of **Mrs. Saroj Singhal, Principal** and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class Group B Educational with effect from 15/02/2017 for a period of three years, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on .. 15/02/2017 at New Delhi


(Atul Garg)

Chief Fire Officer
Ph:-011-23414250

Copy to :-

1. The Director, Education, North MCD, Civic Centre, New Delhi.
2. The Principal M.C.D Primary Co-ed School, J-Block, Sec-16, Rohini, Delhi

INSPECTION REPORT

1. Name & address of the building : M.C.D Primary Co-ed School, J-Block, Sec-16, Rohini, Delhi.
 2. Type of Occupancy : Educational
 3. Type of Case : Renewal (Ground floor only)
 4. Details of previous NOC : F6/DFS/MS/ 2013/WZ/851 Dated: 05/09/2013
 5. Fire Safety directives letter No : Director of Education Circular dated 01.03.2011
 6. Date of inspection : 27/01/2017
 7. Name of the Inspecting Officers : ADO (RN)
 8. Name and designation of officers
 from the building side : Mrs. Saroj Singhal (Principal)
 9. Year of Construction : 1989
 10. Applicant's letter No. : Nil dated: 29.11.2016

Plot Area-9389.5 sqm Covered Area: 1534.50 sqm No of class rooms -17 nos. No of students---650 nos.

	Minimum Standards on fire prevention and fire safety U/R 33	Director of Education	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	06m	MR
	• Gate width	4.5m	3.50m(old case)	MR(old case)
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	MR
	f. Door Size	1 m	1m	MR

2/16

3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	NA	NA
5	Fire Extinguishers			
	• Total numbers	04nos	06nos	MR
	• Types	ABC/Co2	ABC-06	MR
	• ISI marking	ISI Marked	Provided	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA

25/18

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in Director of Education Circular , the FSC issued vide letter of even no 851 dated 05.09.2013 renewal under rule 35 of the Delhi Fire Service Rules, 2010 is recommended

Handwritten signature and date: 01/02/2017

Signature of the Inspecting Officer
 Name :- Rajesh Kumar
 Designation:- ADO/RN

*DO / NSWD
 8/2/17
 2.2.17
 Dy SFO (WZ)*

Handwritten signature and date: 8/2/17

Handwritten signature and text: CFO next-4/

*Reason for delay my & my
 be stated by
 13/2/17*