

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No. F6/DFS/MS/2017/S2/225

Dated: 17/2/17

FIRE SAFETY CERTIFICATE

Certified that M/s Air India Ltd. Store for Poison and Chemicals located in work Shop, Near New Custom House, IGI Airport, New Delhi-110037, comprised of ground floor only, owned/occupied by Air India Ltd was granted No Objection Certificate by this department vide letter No. F6/DFS/MS/2014/2117, dated 08-09-2014. The premises was re-inspected by the officer concerned of this department on 01-02-2017 in the presence of Sh. Shyam Sunder Fandan (Store Incharge) and found that the said store building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Storage (Poison and Chemical Store) with effect from17/02/2017 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on..17/02/2017 at New Delhi by.


(Vipin Kental)
Chief Fire Officer
T.No.011-23412225

Copy to:-1. The Joint Commissioner of Police (Lic), Police Station, Defence Colony,
1st Floor, New Delhi.

2. The Dy. General Manager, Air India Ltd, Store Department, IGI Airport, New Delhi.

Conditions for the validity of fire safety certificate are as under:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate on form J, six month prior to its expiry.

Shop, Near New Custom House, IGI Airport, New Delhi-110037.

2. Building is comprised of : Single Ground Floor Room only in side work shop complex.
 3. Type of Occupancy : Storage (Poison and Chemicals in separate lockers of non Combustible construction).
 4. Type of Case : Old Case
 5. Details of Previous NOC : No.F.6/DFS/MS/2014/2117, dated-08.09.2014.
 6. Fire Safety direction letter No : Nil
 7. Date of Inspection : 01.02.2017
 8. Name of the Inspecting Officers: : Vedpal (ADO)
 9. Name and designation of officer from the building side : Sh. Shyam Sunder Fandan (Store Incharge)
 10. Year of Construction : Not Known.
 11. Applicant's letter No. : No. 20081-82/Jt.C.P./Lic.(Pet/Expl), dated 20.12.2016.

S.No	Minimum Standards on fire prevention and fire safety U/R33	Requirements/ Existing Fire Protection System	Provided at Site	Remarks
1	Access to building			
	Road width	Accessible	9m	MR
	Gate width	N.A.	N.A.	N.A.
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases	N.A.	N.A.	N.A.
	Upper Floor	N.A.	N.A.	N.A.
	Basement	N.A.	N.A.	N.A.
	B. Width of Staircases	N.A.	N.A.	N.A.
	Upper Floor	N.A.	N.A.	N.A.
	Basement	N.A.	N.A.	N.A.
	c. Protection of exits	N.A.	N.A.	N.A.
	Fire check door	N.A.	N.A.	N.A.
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace.	N.A.	N.A.	N.A.
	g. Width of Corridor	N.A.	N.A.	N.A.
	h. Door Size	1m	1m	MR
3	Compartmentation			
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	N.A.	N.A.	N.A.
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	30a/c per hour	N.A.	N.A.
	Upper floor	Lower level & upper Level wire mesh	Provided at Both levels.	MR
5.	Fire Extinguisher			
	Total numbers	03 nos.+6 sand Buckets	03 nos.+ 6 nos. Sand buckets	MR
	types	CO2 & Foam	CO ₂ & Foam	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	N.A.	N.A.	N.A.
	Length of hose reel hose	N.A.	N.A.	N.A.
	Nozzle diameter	N.A.	N.A.	N.A.
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A.	N.A.	N.A.

8	MOEFA	N.A.	N.A.	N.A.
9	Public address System.	N.A.	N.A.	N.A.
10	Automatic Sprinkler System.			
	Basement/Lower ground floor	N.A.	N.A.	N.A.
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	N.A.	N.A.	N.A.
	Number of hydrants per floor	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	• Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual Stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	• Terrace Level	N.A.	N.A.	N.A.
	➤ Discharge of pump	N.A.	N.A.	N.A.
	➤ Head of the Pump	N.A.	N.A.	N.A.
	➤ Power supply	N.A.	N.A.	N.A.
	➤ Auto Starting of pump	N.A.	N.A.	N.A.
14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	N.A.	N.A.	N.A.
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	N.A.	N.A.	N.A.
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.

N/7

M/s Air India Ltd. Store for Poison and Chemicals located in work Shop, IGI Airport, New Delhi.

20	Special Fire Protection systems for of special Risks, if any:	1. Spark Proof electric Connection/point. 2. No smoking Sign boards	1. Spark Proof electric Connection/point Provided in godown area. 2. No smoking sign Boards provided.	MR
----	---	--	--	----

The fire protection systems provided in the building were test checked randomly and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the NOC issued vide letter No.F6./DFS/MS/2014/2117, dated 08.09.20144, renewal under rule 37 of the Delhi Fire Service Rule 2010 is recommended.

Accordingly reply letter in shape of DFA is put up for kind consideration and approval Please.

[Handwritten Signature]
2/2/17

Signature of the Inspecting Officer
Name : Vedpal
Designation : ADO

~~D.O. (S.D.)~~

[Handwritten Signature]
2/2/17

[Handwritten Signature]
2/2/17

[Handwritten Signature]
2/2

Pl put up in shape of Pse as done in other cases.

Cfo (2)
m.scell

