

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001

No. F.6/DFS/MS/Industrial/SZ/2017/ 237

Dated: 20/02/17

FIRE SAFETY CERTIFICATE

Certified that the M/s **Bharti Exim Pvt. Ltd., Okhla Industrial Area, Phase-I, New Delhi-110020**, comprised of **Basement, Ground and 2 Upper Floors**. The building was inspected by the officer concerned of this department on **04/02/2017** in the presence of **Mr. Manas Kumar (Director)** & found to have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for occupancy **Group G "Industrial"** with effect ~~24.2~~ 2017 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010.

Issued on.....20/2/17.....at New Delhi by.


(Vipin Kental)
Chief Fire Officer
Ph:-011-23412225

Copy to:-

1. Sh. Manas Kumar (Director), M/s Bharti Exim Pvt. Ltd., Okhla Industrial Area, Phase-I, New Delhi-110020
2. The Executive Engineer (Bldg.), Building Department, South MCD, Civic Center, Minto Road, New Delhi-110002

Conditions for the validity of fire safety certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
5. This fire safety certificate may not in any way be treated as regularization of unauthorized construction, if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT

1. Name & address of the building: M/sBharti Exim Pvt. Ltd., Okhla Industrial Area, Phase-I, New Delhi-110020
2. Type of Occupancy : Industrial "Group-G"
3. Type of Case : Renewal [Basement + Ground + 2 Upper Floors]
4. Details of Previous NOC : F6/DFS/MS/2013/1378 dated 31/12/2013
5. Fire Safety directives letter No : F6/DFS/MS/BP/2013/2637 dated 06/12/13
6. Date of inspection : 04/02/2017
7. Name of Inspecting Officer : A. K. Malik
8. Name and designation from the building side : Mr. Manas Kumar (Director)
9. Year of Construction : 1985
10. Applicant's letter No. : Nil dated Nil, outdoor diary no. 537 dated 15/01/2017

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL/NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	6m 4.5m NA	9m 4.5m NA	MR MR NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	Two Two	Provided Provided	MR MR
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	1.25m 1.25m	1.25m & 0.90m 1.25m & 0.90m	MR(old case) MR(old case)
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	Required NA	Provided NA	MR NA
	d. No. of continuous staircases to terrace	Two	Two	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1m	1m (final exit)	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA Required NA NA NA	NA Provided NA NA NA	NA MR NA NA NA
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 ACPH 12 ACPH	Exhaust Fan Exhaust Fan	MR MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	16 No's ISI marked	16 Nos ABC/CO ₂ /W.CO ₂ - 8/4/4 Nos Yes	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	One 30m 5mm	Provided 30m 5mm	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	NA NA NA NA NA	Smoke Ground Floor NA Provided All floors	NA NA NA NA NA

10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basement 	Required	Provided	MR
	<ul style="list-style-type: none"> • Ground Floor 	Required	Provided	MR
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	Required	Provided	MR
11.	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	NA	NA	NA
	<ul style="list-style-type: none"> • Number of hydrants per floor 	NA	NA	NA
	<ul style="list-style-type: none"> • Hose Box 	NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> • Hose Box 	NA	NA	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/Manual Stopping ➤ Pump House Access 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
	<ul style="list-style-type: none"> • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	900 LPM	900 LPM	MR
		40m	40m	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity <ul style="list-style-type: none"> ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
	<ul style="list-style-type: none"> • Overhead Tank capacity 	10,000 Lts	10,000 Lts	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft 	NA	NA	NA
	<ul style="list-style-type: none"> • Pressurization of Lift lobby 	NA	NA	NA
	<ul style="list-style-type: none"> • Communication In lift Car 	NA	NA	NA
	<ul style="list-style-type: none"> • Fireman's Grounding Switch 	NA	NA	NA
	<ul style="list-style-type: none"> • Lift Signage 	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Location 	NA	NA	NA
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Flow Switch Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • PA System Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Batter backup 	NA	NA	NA
	<ul style="list-style-type: none"> • Building Floor Plans 	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	Required	2 ABC type Extinguishers are provided near electric Panel	MR

M/s Bharti Exim Pvt. Ltd., Okhla Industrial Area, Phase-I, New Delhi-110020

The shortcomings communicated vide letter no. F6/DFS/MS/Ind./2016/SZ/3028 dated 29/12/16 found complied. The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

Keeping in view of the above substantial compliance of the minimum standards of fire prevention and fire safety measures as required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Accordingly reply letter in shape of DFA is put up.

A. K. Malik
6/1/17

Signature of Inspecting Officer
Name: A. K. Malik
Designation: Divisional Officer

DY. CFO(SZ)

Signature
7/1

CFO (SZ)

FT m.

Signature
8/2

M.S.U.



609/CFO 22
9/1/17 Ro/2