

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

Fax No. 011-23412593, Ph. 011-23412225

No. F6/DFS/MS/School/2017/SZ/ 223

Dated: 17/02/17

FIRE SAFETY CERTIFICATE

Certified that the **N.P. Primary School No-2 & 5 located at Netaji Nagar, Near Market, New Delhi**, comprised of **Ground + one upper floor** was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2014/SZ/24 dated 08/01/2014. The premises was re-inspected by officer concerned of this department on 27/01/2017 in the presence of Mr. Sajjan Kumar (Fire Officer) and found that school have deemed complied with the fire prevention and fire safety arrangements in accordance with Directorate of Education circular No. 262-362 dated 17.01.2005 issued by Director of Education, Govt. of NCT Delhi and the building/premises is fit for occupancy class "**Educational Building Group-B**" as above with effect from 17/02/17 for a period of **Three years** subject to conditions as mentioned below.

Issued on 17/02/17 at New Delhi by


(Vipin Kental)
Chief Fire Officer

Copy to: -

1. Sh. Sajjan Kumar (Fire Officer), New Delhi Municipal Corporation, Palika Kendra, New Delhi.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering the fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drill be conducted at regular interval and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye Laws.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & Address of the Building	N.P. Primary School No-2 & 5, Netaji Nagar, Near Market, New Delhi		
2	Type of Occupancy	Educational Building "Group-B" (School)		
3	Building Comprised of	Ground + One Upper Floor		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/School/2014/SZ/24 dated 08/01/2014		
6	Fire Safety Directives Letter No	DOE circular No 262-362 dated 17/01/2005		
7	Date of Inspection	27/01/2017		
8	Name of the Inspecting Officers	ADO R.N. Singh		
9	Name & Designation of Officers from the building side	Mr. Sajjan Kumar (Fire Officer)		
10	Year of construction	1990		
11	Applicant letter No.	Nil dated 02/01/2017		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Dt. 21/12/2010 Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Approachable	9 mtr	MR
	• Gate width	NA	4 mtr	NA
	• Width of internal road	NA	NA	NA
2	Number, width, type & arrangement of exits			
	a. Number of Staircase			
	• Upper floors	Required	3 No's	MR
	• Basement floor	NA	NA	NA
	b. Width of Staircase			
	• Upper floors	1.50m / 0.75m	1.53 m × 2 1.23 m × 1	MR
	• Basement floor	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircase to terrace	Required	2 No's	MR
	e. Width of corridor	NA	NA	NA
	f. Door size	1 mtr	1 mtr	MR
3	Compartmentation.			
	• Fire check door.	NA	NA	NA
	• Sealing of electrical shafts.	NA	NA	NA
	• Fire rating of shaft door.	NA	NA	NA
	• Water curtain	NA	NA	NA
	• Fire dampers.	NA	NA	NA
4.	Smoke Management system.			
	• Basement	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers.			
	• Total numbers	8 No's Fire Extinguishers ISI Marked	8 Nos.	MR
	• Types		ABC- 05, Co2- 03	MR
	• ISI Marking		Yes	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	Hose reels	One	MR
	• Length of hose-reel hose.		30 m	MR
	• Nozzle Diameter		5 mm	MR

Renewal

N.P. Primary School No-2 & 5, Netaji Nagar, ND

for -

7	Automatic fire detection & alarming system.			
	1. Type of detectors	NA	NA	NA
	2. Location of Main Panel	NA	NA	NA
	3. Location of Repeater Panel	NA	NA	NA
	4. Alternate source of power	NA	NA	NA
	5. Hooter's location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1. Basement	NA	NA	NA
	2. Upper floors	NA	NA	NA
	3. Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants.			
	1. Size of Riser / Down-comer	NA	NA	NA
	2. Number of Hydrant per floor	NA	NA	NA
	3. Hose box.	NA	NA	NA
12.	Yard Hydrants.			
	1. Total number of hydrants.	NA	NA	NA
	2. Hose box.	NA	NA	NA
13.	Pumping arrangements.			
	a) Ground Level			
	➤ Discharge of main pump.	NA	NA	NA
	➤ Head of main pump.	NA	NA	NA
	➤ Number of main pumps.	NA	NA	NA
	➤ Jockey Pump output.	NA	NA	NA
	➤ Jockey Pump head.	NA	NA	NA
	➤ Standby Pump output.	NA	NA	NA
	➤ Standby Pump head.	NA	NA	NA
	➤ Auto Starting/Manual Stopping.	NA	NA	NA
	b) Terrace Level			
	➤ Discharge of pump.	Boosting	450 LPM	MR
	➤ Head of pump.	NA	38 m	NA
	➤ Power supply.	NA	NA	NA
	➤ Auto starting of pump.	NA	NA	NA
14.	Captive water storage for Fire Fighting.			
	• Underground tank capacity.	NA	NA	NA
	• Draw-off connection.	NA	NA	NA
	• Fire Service Inlet.	NA	NA	NA
	• Access to tank.	NA	NA	NA
	• Overhead tank capacity.	2,500 Ltr	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of lift shaft.	NA	NA	NA
	• Pressurization of lift lobby.	NA	NA	NA
	• Communication in lift car.	NA	NA	NA
	• Fireman's switch.	NA	NA	NA
	• Lift signage.	NA	NA	NA
17	Standby Power Supply	NA	NA	NA
18.	Refuge Area			
	• Total area	NA	NA	NA
	• Location	NA	NA	NA

Renewal

h

19.	Fire Control Room.			
	• Detector system panel.	NA	NA	NA
	• Flow switch panel.	NA	NA	NA
	• PA system panel.	NA	NA	NA
	• Battery backup.	NA	NA	NA
	• Building floor plan.	NA	NA	NA
20.	Special Fire Protection System for the Protection of special Risk, if any.	NA	NA	NA

The Fire Protection system provided in the building were checked/tested randomly and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the circular of Director of Education dated 17.01.2005, Fire Safety Certificate issued vide letter No. F6/DFS/MS/School/2014/SZ/24 dated 08/01/2014, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended

Accordingly DFA is put up for approval and signature please.

[Handwritten Signature]
2/2/17

Signature of the Inspecting Officer
Name: R.N. Singh
Designation: ADO

Renewal

N.P. Primary School No-2 & 5, Netaji Nagar, ND

Div. Officer (SD)

[Handwritten Signature]
3/2/17

[Handwritten Signature]
5/2/17

[Handwritten Signature]
3/2



596/CF-52
6/2

CFD S/S

M. S. K. F.T.D.
[Handwritten Signature]