

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI


No. F6/DFS/MS/cinema/2017/ 231

Dated: 17/02/2017

**FIRE SAFETY CERTIFICATE**

Certified that the PVR Cinema (Formerly known as D T Cinema)(Audi- 1to4) Shalimar Bagh Located at 3rd, 4<sup>th</sup> & 5<sup>th</sup> Floor ,DLF City Center Mall, A-Block, Community Centre Shalimar Bagh, New Delhi, comprised of Lower basement & Upper basement & ground+ five upper floor, was issued FSC vide Letter No F6/DFS/MS/cinema/2015/WZ/22578 dated 08-12-2015. FSC to the Mall is issued vide Letter no- F6/DFS/MS/2015/1035 Dated- 18/06/2015. The premises was re inspected by the officers concerned of this department on 30-01-2017 in the presence of Mr. Sachin (Manager Cinema) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class " Assembly Building" Group D with effect from 17/02/17 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on .....17/02/17..... at New Delhi by.

  
(Atul Garg)  
Chief Fire Officer,  
Delhi Fire Service

Copy to:

1. Sh Arun Gupta SDM (HQ-I)/Kanjhawala, District North West Kanjhawala, Delhi
2. Sh Sachin (Manager), PVR Cinema (D T Cinema) Shalimar Bagh Located at 3rd, 4<sup>th</sup> & 5<sup>th</sup> Floor ,DLF City Center Mall, A-Block, Community Centre Shalimar Bagh, New Delhi
3. Dy. Health Officer NDMC, Sec-5,Rohini Zone, Rohini Delhi-85.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
9. All the doors, Exits and internal roads must be kept free from any obstruction.

1. Name & address of the building: **PVR Cinema(Formerly known as D T Cinema)(Audi- 1to4) Shalimar Bagh** Located at **3rd, 4<sup>th</sup> & 5<sup>th</sup> Floor, DLF City Center Mall, A-Block, Community Centre Shalimar Bagh, New Delhi, in a building comprised of Lower basement & Upper basement & ground+ five upper floor.**

2. Type of Occupancy : Cinema (Assembly)

3. Type of Case : Renewal

4. Details of previous NOC : Letter No. F6/DFS/MS/cinema/2015/WZ/22578 dated 08-12-2015

5. Fire Safety directives Letter No. : Letter No. F6/DFS/MS/BP/2004/2443 dated 14-10-2004( To Mall)

6. Date of inspection : 31-01-2017

7. Name of the Inspecting Officer : Udai vir Singh ADO (WP)

8. Name and designation of Officer

from the building side : Sh. Sachin (Manager) & SDM(Saraswati vihar) & representatives of others departments as per letter of SDM(HQ-1) dated 27/01/2017

9. Year of Construction :

10. Applicant's letter No. : F.11/NW/Cinema/2015/1579-1593 Dated-27/01/2017

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 m	24mtr	MR
	• Gate width	4.5 m	5m Provided	MR
	• Width of internal road	6 m	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	4	8 Provided	MR
	• Upper floors	16	16 Provided	MR
	• Basements			
	b. Width of staircases	Old case	5x1.5m,1x1.93m,1x1.48m & 1x2m	MR
	• Upper floors	Old case	Provided	MR
	• Basements			
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No of continuous staircase to terrace	04nos	04nos	MR
	e. Width Of Corridor	Required	Required	Required
	f. Door Size	<b>04 Exit in each Audi</b>	Audi-1=2x182cm,1x176cm&1x193cm Audi-2=2x182cm,1x175cm & 1x171cm Audi-3=2x180cm,&2x175cm Audi-4=2x175cm,1x180cm&1x183cm	MR (Old case)
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR

	System			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	Required	Provided	MR
		Required	Provided	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	16(4 in each Audi) ABC, CO2 & WCO2 ISI marked	Provided Provided Provided	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	2each Audi 30m 5 mm	2 Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	Beam Detector Ground floor Ground floor Required Required	Provided Provided Provided Provided Provided	MR MR MR MR MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	Required Required Required	Provided Provided Provided	MR MR MR
11	Internal Hydrants			
	<ul style="list-style-type: none"> <li>Size of riser/down- comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	150 mm 2 each Audi Required	Provided Provided Provided	MR MR MR
12	Yard Hydrants( <b>Common With Mall</b> )			
	<ul style="list-style-type: none"> <li>Total number of hyds</li> <li>Hose Box</li> </ul>	6 6	Provided Provided	MR MR
13	Pumping Arrangements ( <b>Common With Mall</b> )			
	<ul style="list-style-type: none"> <li>Ground Level</li> <li>Discharge of main pump</li> <li>➤ Head of main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Staring/Manual stopping</li> <li>➤ Pump House Access</li> <li>Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power supply</li> <li>➤ Auto starting of pump</li> </ul>			
		4500lpm	Provided	MR
		60 m	Provided	MR
		3	Provided	MR
		Two180 lpm each	Provided	MR
		60 m	Provided	MR
		4500 lpm	Provided	MR
		60 mtr	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		450 lpm	Provided	MR
		40 m	Provided	MR
		Provided	Provided	MR
		Provided	Provided	MR
14	Captive water Storage for fire fighting( <b>Common With Mall</b> )			
	<ul style="list-style-type: none"> <li>Under ground tank cnty</li> </ul>	3,00,000 litres	Provided	MR

15	Exit Signage	Required	Provided	MR
16	Provision of Lifts			
	➤ Pressurization of Lift Shaft	Required	Provided	MR
	➤ Pressurization of lift lobby	Required	Provided	MR
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17	Standby power supply	Required	450 KVA	MR
18	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	Required	Provided	MR
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/cinema/2015/WZ/22578 dated 08-12-2015 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Officer

Name

Designation

Signature of the Inspecting

Name

Designation



Uday Vire Singh

ADDO/WP