

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001**




NO. F6/DFS/MS/School/2017/SZ / 226

Dated: 17/02/17

**FIRE SAFETY CERTIFICATE**

Certified that the Rishikul International School located at Pocket-3, Sector-7, Dwarka, New Delhi-110075, comprised of small basement ground plus two upper floors was granted NOC by this department vide letter no. F6/DFS/MS/School/2013/SZ/862 dated 5.9.2013. The premises was re-inspected by the officer concerned of this department on 02.02.2017 in presence of Mrs. Amita Sood (Principal) and found that the premises have deemed complied with fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service and that the school building is fit for occupancy class B "Educational building" with effect from....17/02/17 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed overleaf.

Issued on .....17/02/17..... at New Delhi by

  
(Vipin Kental)  
Chief Fire Officer  
  


Copy to:-

1. The Deputy Director (Education), Govt. of NCT of Delhi, Old Secretariat, New Delhi.
2. Chairman, Rishikul International School, Pocket-3, Sector-7, Dwarka, New Delhi-75.

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.



4115

## INSPECTION REPORT

1	Name & address of the building	Rishikul International School(Kapila Education Social & cultural Society) at Plot No. 3, Sector-7, Dwarka, New Delhi - 110075	
2	Type of Occupancy	Educational Building "B"	
3	Type of case	Renewal	
4	Details of previous NOC	F6/DFS/MS/School/2013/SZ/862 Dated 05.09.2013	
5	Fire safety directives letter No	Old Case	
6	Date of inspection	2.1.2017	
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj	
8	Name and designation of officers from the building side	Mrs. Amita Sood (Principal)	
9	Year of construction	2005, 2012	
10	Applicant's letter No.	Nil Dated 16.01.2017	<b>Small Basement ground plus two upper floors</b>

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirements/Old case	Provided at site	Remarks MR / NMR
<b>1</b>	<b>Access to building</b>			
	1) Road width	6 Mtrs.	30 Mtrs.	MR
	2) Gate width	4.5 Mtrs.	Direct accessible from road	MR
	3) Width of internal road	N/A	N/A.	N/A
<b>2</b>	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	Two	Two	MR
	2. basements	<u>One</u>	<u>One</u>	MR
	<b>b. Width of staircase</b>			
	1. Upper floors	1.5 Mtrs.	1.5 Mtrs.	MR
	2. basements	1.5 Mtrs.	1.5 Mtrs.	MR
	<b>c. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	One	One	MR
	e. Width of corridor	150 Cms.	154 Cms.	MR
	f. Door size	1 Mtr.	1 Mtr.	MR
<b>3</b>	<b>Compartmentation.</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
<b>4</b>	<b>Smoke Management system.</b>			
	basement	Required	Exhaust fans provided	MR
	upper floors		N/A	N/A
<b>5</b>	<b>Fire Extinguishers</b>			
	total numbers	2 Nos. each floor	9 Nos.	MR
	Types	Co2 OR ABC	ABC	MR
	ISI marking	ISI Marked	ISI Marked	MR



<b>6</b>	<b>First-Aid Hose Reels.</b>			
	total numbers on each floor	One	One	MR
	Length of Hose reel hose	30 m	30 m	MR
	Nozzle Diameter	5 mm	5 mm	MR
<b>7</b>	<b>Automatic fire detection and alarming system</b>			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
<b>8</b>	<b>MOEFA</b>	N/A	N/A	N/A
<b>9</b>	<b>Public Address System.</b>	N/A	Provided	N/A
<b>10</b>	<b>Automatic Sprinkler System.</b>			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
<b>11</b>	<b>Internal Hydrants</b>			
	Size of riser/down-corner	N/A	100 mm	N/A
	Number of Hydrants per floor	N/A	One	N/A
	hose Box	N/A	Provided	N/A
<b>12</b>	<b>Yard Hydrants.</b>			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
<b>13</b>	<b>Pumping arrangements</b>			
	<b>1. Ground level</b>			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	<b>2. Terrace level</b>			
	a. Discharge of pump	450 LPM	450 LPM	MR
	b. head of the pump	35 Mtrs.	35 Mtrs.	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	provided	MR
<b>14</b>	<b>Captive water storage for fire fighting</b>			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	10000 Ltrs.	10000 Ltrs.	MR
<b>15</b>	<b>Exit Signage.</b>	Required	Provided	MR
<b>16</b>	<b>Provision of lifts.</b>			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A



N/A

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.		Not Required	
	total area			
	location			
19	Fire control room	N/A	N/A	N/A
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Battery backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any:	ABC extinguisher near electric pannel MR		

The fire protection provided in the building were checked & found functional at the time of inspection. The shortcomings vide letter no. F6/DFS/MS/School/2016/SZ/2291 dated 23.9.2016 found rectified. ✓  
 Keeping in view deemed compliance of the minimum standards of fire and safety requirements under the rules, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/2013/SZ/862 dated 5.9.2013, is recommended under rule 37 of the Delhi Fire Service 2010.

Accordingly DFA is put up for approval and signature please.

*[Signature]*  
 Signature of the Inspecting Officer  
 Name S.P. Bhardwaj  
 Designation ADO (Dwarka)

~~DCSW~~

*[Signature]*  
9/2/17

DCSW/50  
08/02/17

~~DCFO(SZ)~~

*[Signature]*  
13/2



6/14/17/2  
16/2/17/2 Cfo (SZ)

M-Scell FT 10/11  
*[Signature]*  
14/2

FT letter is put up for signature please.

~~Cfo/SZ~~ M-Scell *[Signature]*  
17/2

*[Signature]*  
17/2/17