

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

Fax No. 011-23412593, Ph. 011-23412225

No. F6/DFS/MS/Club/2017/SZ/ 224

Dated: ...17/02/17

FIRE SAFETY CERTIFICATE

Certified that M/s **Sarva Priya Club at Sarva Priya Vihar, New Delhi-110016**, comprised of basement, ground, mezzanine floor plus two upper floors was granted FSC by this department vide letter No. F6/DFS/MS/Club/2013/SZ/1101 dated 17/10/2013. the premises was re-inspected by the officer concerned of this department on 02.02..2017 in the presence of Mr. Yasvinder Singh (Asstt. Admin) of the club and observed that the said building/premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fir for occupancy class-D "Assembly Building (Club)" as above with effect from 17/02/17 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 17/02/17 at New Delhi by


(Vipin Kental)
Chief Fire Officer

Copy to :-

1. Mr. Ashok Barua (GM) M/s Sarva Priya Club at Sarva Priya Vihar, New Delhi-16
2. The Joint C.P. (Lic.), 1st floor, PS Defence Colony, New Delhi-110049

Conditions for the validity of Fire Safety Certificate

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering the fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drill be conducted at regular interval and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye Laws.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT


1	Name & Address of the Building	Sarva Priya Club, Sarva Priya Vihar, New Delhi-110016		
2	Type of Occupancy	Assembly Building "Group-D"		
3	Building Comprised of	Basements, ground, mezzanine plus two upper floors.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/Club/2013/SZ/1101 dated 17.10.2013		
6	Fire Safety Directives Letter No	F.6/DFS/MS/BP/2000/857 dated 15/05/2000		
7	Date of Inspection	02.02.2017		
8	Name of the Inspecting Officers	ADO R.N. Singh		
9	Name & Designation of Officers from the building side	Mr. Yasvinder Singh, (Asstt Admin)		
10	Year of construction	Nil		
11	Applicant letter No.	Nil Dated 16/01/2017		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Dt. 14.12.2004 & Directives Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	1. Road width	Accessible	6 mtr	MR
	2. Gate width	5 mtr	5 mtr	MR
	3. Width of internal road	NA	NA	NA
2	Number, width, type & arrangement of exits			
	a. Number of Staircase			
	1. Upper floors	Two	Two provided	MR
	2. Basement floor	01 + 01 Ramp	Two Staircase provided	MR
	b. Width of Staircase			
	1. Upper floors	5 feet & 4'-3"	1.35m, 1.45 & 0.90m	MR (old case)
	2. Basement floor	01 + 01 Ramp	1.36m & 1.40m	MR (old case)
	c. Protection of exits			
	1. Fire check door	Required	Provided (basement0)	MR
	2. Pressurization	NA	NA	NA
	d. No. of continuous staircase to terrace	One	Two	MR
	e. Width of corridor	NA	NA	NA
	f. Door size	1.5 m	1.5 m	MR
3	Compartmentation.			
	1. Fire check door.	Required	Provided	MR
	2. Sealing of electrical shafts.	Required	Provided	MR
	3. Fire rating of shaft door.	NA	NA	NA
	4. Water curtain	NA	NA	NA
	5. Fire dampers.	NA	NA	NA
4.	Smoke Management system.			
	1. Basement	Required	Exhaust fan provided	MR
	2. Upper floors	NA	Natural Ventilation	NA
5.	Fire Extinguishers.			
	1. Total numbers	15 No's Fire Extinguisher	15 No's	MR
	2. Types	ISI marked	ABC- 10, W.Co2- 05	MR
	3. ISI Marking		Provided	MR
6.	First Aid Hose Reels.			
	1. Total numbers on each floor.	Hose Reel	One	MR
	2. Length of hose-reel hose.		30 mtr	MR
	3. Nozzle Diameter		05 mm	MR

Renewal

Sarva Priya Club, Sarva Priya Vihar, New Delhi-16

7	Automatic fire detection & alarming system.			
	1. Type of detectors	NA	Smoke.	NA
	2. Location of Main Panel	NA	Ground floor	NA
	3. Location of Repeater Panel	NA	NA	NA
	4. Alternate source of power	NA	Battery backup	NA
	5. Hooter's location	NA	Each floor	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	1. Basement	Required	Provided	MR
	2. Upper floors	NA	NA	NA
	3. Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants.			
	1. Size of Riser/Down-comer	Required	100 mm	MR
	2. Number of Hydrant per floor	Required	One	MR
	3. Hose box.	Required	One	MR
12.	Yard Hydrants.			
	1. Total number of hydrants.	NA	NA	NA
	2. Hose box.	NA	NA	NA
13.	Pumping arrangements.			
	a) Ground Level			
	➤ Discharge of main pump.	1050 LPM	1050 LPM	MR
	➤ Head of main pump.	NA	37 mtr.	NA
	➤ Number of main pumps.	One	One	MR
	➤ Jockey Pump output.	NA	NA	NA
	➤ Jockey Pump head.	NA	NA	NA
	➤ Standby Pump output.	NA	NA	NA
	➤ Standby Pump head.	NA	NA	NA
	➤ Auto Starting / Manual Stopping.	NA	NA	NA
	b) Terrace Level			
	➤ Discharge of pump.	Required	450 LPM	MR
	➤ Head of pump.	Required	35 mtr	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	Captive water storage for Fire Fighting.			
	1. Underground tank capacity.	25,000 Ltr.	25,000 Ltr.	MR
	2. Draw-off connection.	Required	Provided	MR
	3. Fire Service Inlet.	Required	Provided	MR
	4. Access to tank.	Required	Provided	MR
	5. Overhead tank capacity.	12,500 Ltr.	12,500 Ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	1. Pressurization of lift shaft.	NA	NA	NA
	2. Pressurization of lift lobby.	NA	NA	NA
	3. Communication in lift car.	NA	Provided	NA
	4. Fireman's switch.	NA	Provided	NA
	5. Lift signage.	NA	Provided	NA
17	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	1. Total area	NA	NA	NA
	2. Location	NA	NA	NA

N/19

19.	Fire Control Room.			
	1. Detector System Panel.	NA	NA	NA
	2. Flow Switch Panel.	NA	NA	NA
	3. PA system Panel.	NA	NA	NA
	4. Battery backup	NA	NA	NA
	5. Building floor plan	NA	NA	NA
20.	Special Fire Protection System for the Protection of special Risk, if any :			NA
<p>The Fire protection systems provided in the building were randomly checked and found functional at the time of inspection. Shortcomings communicated vide letter dated 02/12/2016 have been complied.</p> <p>Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F6/DFS/MS/Club2013/SZ/1101 dated 17/10/2013, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.</p> <p>Accordingly, DFA is put up for approval and signature please.</p> <p style="text-align: right;">  Signature of the Inspecting Officer Name : R.N. Singh Designation: ADO </p>				

Renewal

Sarva Priya Club, Sarva Priya Vihar, New Delhi-16

Div. Officer (SD)



Similar
012/17
Dy. Officer (S2)

606/Chs 82
10/2/17-15/2

Lamp
9/2