

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No. F6/MS/DFS/School/2017/w2) 227

Dated: 17/02/2017

**FIRE SAFETY CERTIFICATE**

Certified that the **SD Public School** Located at **PU Block Pitampura Delhi – 110034** comprised of Ground + 03 Upper Floors was issued FSC vide Letter No. **F6/MS/DFS/School/2013/1072 Dated 14-10-2013**. The premises was re inspected by the officer concerned of this department on 25-10-2016 in the presence of **Mr. Inder Kumar (Caretaker)** and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance DOE **circular Dated-17/01/2005** and that the premises is fit for occupancy class "Educational" Group B with effect from 17/02/17 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on .....17/02/17 at New Delhi by.

  
(Atul Garg)

Chief Fire Officer  
Delhi Fire Service

Copy to:

The Principal,  
**SD Public School, PU Block Pitampura Delhi – 110034.**

  
16/2/17

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

1. Name & address of the building: **SD Public School Located at PU Block Pitampura Delhi - 110034.**
2. Type of Occupancy : **Educational ( Ground + 3 Upper Floor)**
3. Type of Case : **Renewal**
4. Details of previous NOC : **F6/MS/DFS/School/2013/1072 Dated 14-10-2013**
5. Fire Safety directives Letter No. : **circular Dated-17/01/2005**
6. Date of inspection : **27 -01-2017**
7. Name of the Inspecting Officer : **Udaivir Singh,ADO (WP)**
8. Name and designation of Officer  
from the building side : **Mr. Inder Kumar (Caretaker)**
9. Year of Construction : 1994
10. Applicant's letter No. : **SDPS/2016/7144 Dated -NIL**

No. of Students=1603
No. of class rooms=42
Plot area=4000 sqm
Covered area=4555.36sqm

S No	Minimum standards on fire prevention and fire safety U/R 33	Cr.No. dated- 17-01-05	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	6 mtr 5.0 mtr NA	5m Provided 365 cm NA	MR(old case) MR NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases <ul style="list-style-type: none"> <li>• Upper floors</li> <li>• Basements</li> </ul> b. Width of staircases <ul style="list-style-type: none"> <li>• Upper floors</li> <li>• Basements</li> </ul> c. Protection of exits <ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul> d. No of continuous staircase to terrace	2 NA 1.5mtrs each NA NA NA 2 1.5 mtr 1.0 mtr	4 NA 2x130cm & 2x143 cm NA NA NA Provided 228 cm 110 cm	MR NA MR NA NA MR MR
3.	Compartmentation			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	NA NA	NA NA	NA NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	16 nos. ABC & CO <sub>2</sub> ISI marked	Provided Provided Provided	MR MR MR

	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	2 30m 5mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	NA NA NA	NA NA NA	NA NA NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	Required 2 2	Provided Provided Provided	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	NA NA	NA NA	NA NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> <li>Ground Level</li> <li>Discharge of main pump</li> <li>Head of main pump</li> <li>Number of main pumps</li> <li>Jockey pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Staring/Manual stopping</li> <li>Pump House Access</li> <li>Terrace level</li> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power supply</li> <li>Auto starting of pump</li> </ul>	NA NA NA NA NA NA NA NA NA NA NA 1X450 lpm 1x220 lpm 40Mtr Required Required	NA NA NA NA NA NA NA NA NA NA NA Provided Provided Provided Provided	NA NA NA NA NA NA NA NA NA NA NA MR MR MR MR
14.	Captive water Storage for firefighting:			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> <li>Draw off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> <li>Overhead Tank capacity</li> </ul>	NA NA NA NA 5000 ltr	NA NA Provided NA Provided	NA NA NA NA MR MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of lift lobby</li> <li>Communication in lift Car</li> <li>Fireman's Grounding</li> </ul>	NA NA NA NA	NA NA NA NA	NA NA NA NA

