

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

NO. F6/DFS/MS/School/2014/SZ/ 249

DATED: 22/2/17

FIRE SAFETY CERTIFICATE

Certified that the Jain Model Public School located at 56-B, Vaishali Colony, Janakpuri-Palam Road, New Delhi-110045, comprised of ground floor only with partial basement under one room segregated from school building having separate entrance, having total 07 rooms (including class rooms, office & store etc.) was granted NOC by this department vide letter no. F6/DFS/MS/School/2014/SZ/90 dated 22.01.2014. The school building was re-inspected by the officer concerned of this department on 27.01.2017 in presence of Mrs. Sneha (Principal) and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education GNCT of Delhi Circular No. Estate/CC/Fire Safety/2011/3298 dated 01.03.2011 and that the school building is fit for occupancy of class B "Educational Building" for ground floor only with effect from 22/2/17 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on 22/2/17 at New Delhi by

VK
20/2

(Vipin Kental)

DK Chief Fire Officer

Copy to:-

- 1 Dy. Director, (Education) GNCT of Delhi, Old Secretariat, New Delhi-110054.
- 2 Manager, Jain Model Public School, 56-B, Vaishali colony, Janakpuri-Palam Road, New Delhi-110045.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	Jain Model Public School , 56B, Vaishali Colony, Janakpuri Palam Road, New Delhi-110045.		
	Type of Occupancy	Educational Building "B"		
2	Type of case	Renewal (Ground Floor Only)		
3	Details of previous NOC	F6/DFS/MS/School/2014/SZ/90 dated 22.01.2014		
4	Fire safety directives letter No	Directorate Of Education Circular. No. F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011.		
5	Date of inspection	27.1.2017		
6	Name of the inspecting Officers :	ADO S.P. Bhardwaj		
7	Name and designation of officers from the building side	Mrs. Sneha (Principal)		
8	Year of construction	1985		
9	Applicant's letter No.	Nil Dated 01.12.2016		Ground floor only
10				

S. NO.	Minimum Standards on fire prevention and fire safety	Dir.Edu.Cir. Dated 01.03.2011.	Provided at site	Remark MR / NMR
1	Access to building			
	1) Road width	6 Mtrs.	8 Mtrs.	MR
	2) Gate width	4.5 Mtrs.	Direct Accessible from road	MR
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	N/A	N/A	N/A
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	N/A	N/A	N/A
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	N/A	N/A	N/A
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1 Mtr.	77 to 112 Cms.	MR being Old case
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	N/A	N/A	Small basement is separate from school
			N/A	N/A

5	Fire Extinguishers	2 Nos. Co2 OR ABC ISI Marked	2 Nos.	MR
	total numbers		ABC	MR
	Types		ISI Marked	MR
	ISI marking			
6	First-Aid Hose Reels.		N/A	N/A
	total numbers on each floor	N/A	N/A	N/A
	Length of Hose reel hose	N/A	N/A	N/A
	Nozzle Diameter	N/A	N/A	N/A
7	Automatic fire detection and alarming system		N/A	N/A
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	
9	Public Address System.			N/A
10	Automatic Sprinkler System.		N/A	N/A
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants		N/A	N/A
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	Yard Hydrants.		N/A	N/A
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level		N/A	N/A
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level		N/A	N/A
	a. Discharge of pump	N/A	N/A	N/A
	b. head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
d. Auto starting of pump	N/A	N/A	N/A	
14	Captive water storage for fire fighting		N/A	N/A
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	N/A	N/A	N/A
15	Exit Signage.			

M/10

16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any:	N/A		

The fire protection system provided in the building were checked & found functional at the time of inspection. Keeping in view deemed compliance of the minimum standards on fire prevention & fire safety required under the rules, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/2014/SZ/90 dated 22.01.2014 is recommended under rule 37 of the Delhi Fire Service Rules 2010.

Accordingly DFA is put up for approval and signature please.

Sury
Signature of the Inspecting Officer

Name S.P. Bhardwaj

Designation ADO (Dwarka)

44/DOCSW
30/01/17

DO/SW

30/1/17

DCFO(SZ)

3/1

