

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

Fax No. 011-23412593, Ph. 011-23412225

No. F6/DFS/MS/Cinema/2017/SZ/ 285

Dated: 01/03/17

**FIRE SAFETY CERTIFICATE**

Certified that the **Cinapolis India Pvt Ltd at Plot No. A-4, Distt Centre, DLF Place Mall Saket, New Delhi (Audi 1 to 6) at 1<sup>st</sup>, 2<sup>nd</sup> & 3<sup>rd</sup> floor**, building comprised of three tier basement, ground + 7 upper floors was granted FSC by this department vide letter No. F6/MS/DFS/2009/Cinema/646 dated 04.03.2009. The premises was re-inspected by the officer concerned of this department on 15.01.2017 in the presence of Mr. Anshul (Manager) of the Cinapolis India Pvt. Ltd and found that the said building/premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fir for occupancy class "Assembly Building, Group-D" as above with effect from 01/03/2017 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 01/03/17 at New Delhi by

(Vipin Kental)  
Chief Fire Officer

Copy to: -

1. The Manager, M/s Cinapolis India Pvt Ltd at Plot No. A-4, Distt Centre, DLF Place Mall Saket, New Delhi-110017
2. The Joint Commissioner of Police (Lic.), 1<sup>st</sup> floor, PS Defence Colony, New Delhi-49

**Conditions for the validity of Fire Safety Certificate**

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering the fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drill be conducted at regular interval and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye Laws.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

## INSPECTION REPORT

S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Dt 04/03/2009 Requirement	Provided at Site	Remarks MR/NMR
1	<b>Access to Building.</b>	F.6/DFS/MS/Mall/2015/SZ/1954 Dated 30/10/2015		
	1. Road width	Approachable	As above	MR
	2. Gate width	NA	As above	NA
	3. Width of internal road	NA	As above	NA
2	<b>Number, width, type &amp; arrangement of exits.</b>	Provided & Maintained by DLF Mall, Saket		
	<b>a. Number of Staircase</b>			
	1. Upper floors	Required	As above	MR
	2. Basement floor	NA	As above	NA
	<b>b. Width of Staircase</b>	Provided & Maintained by DLF Mall, Saket		
	1. Upper floors	Required	As above	MR
	2. Basement floor	NA	As above	NA
	<b>c. Protection of exits</b>			
	1. Fire check door	NA	As above	NA
	2. Pressurization	NA	As above	NA
	<b>d. No. of continuous staircase to terrace</b>	Required	As above	MR
	<b>e. Width of corridor</b>	NA	NA	NA
	<b>f. Door size /Exits</b>	1.5 m	1.5 m in each Audi	MR
3	<b>Compartmentation.</b>	Provided & Maintained by DLF Mall, Saket		
	1. Fire check door.	NA	NA	NA
	2. Sealing of electrical shafts.	Required	Provided	MR
	3. Fire rating of shaft door.	NA	NA	NA
	4. Water curtain	NA	NA	NA
	5. Fire dampers.	NA	NA	NA
4.	<b>Smoke Management system.</b>	Provided & Maintained by DLF Mall, Saket		
	1. Basement	NA	As above	NA
	2. Upper floors	Required	Provided	MR
5.	<b>Fire Extinguishers.</b>			
	1. Total numbers	Fire Extinguishers	74 No's	MR
	2. Types		Co2-44, W. Co2-22, ABC-9,	MR
	3. ISI Marking	ISI marked	Yes	MR
6.	<b>First Aid Hose Reels.</b>			
	1. Total numbers on each floor.	Hose Reel	Two in each Audi	MR
	2. Length of hose-reel hose.		30 m	MR
	3. Nozzle Diameter		5 mm	MR

Renewal

Cinepolis India Pvt Ltd, DLF Place Mall, Saket, ND-17

h

7	<b>Automatic fire detection &amp; alarming system.</b>	Provided & Maintained by DLF Mall, Saket		
	1. Type of detectors	Required	Beam & smoke	MR
	2. Location of Main Panel	NA	As above	NA
	3. Location of Repeater Panel	NA	As above	NA
	4. Alternate source of power	Required	As above	MR
	5. Hooter's location	Required	As above	MR
8.	<b>MOEFA</b>	Required	Provided	MR
9.	<b>Public Address System</b>	Required	Provided	MR
10.	<b>Automatic Sprinkler System</b>	Provided & Maintained by DLF Mall, Saket		
	1. Basement	NA	As above	NA
	2. Upper floors	Required	Provided in each Audi	MR
	3. Sprinkler above false ceiling	NA	NA	NA
11.	<b>Internal Hydrants.</b>	Provided & Maintained by DLF Mall, Saket		
	1. Size of Riser/Down-comer	Required	As above	MR
	2. Number of Hydrant per floor	Required	As above	MR
	3. Hose box.	Required	As above	MR
12.	<b>Yard Hydrants.</b>	Provided & Maintained by DLF Mall, Saket		
	1. Total number of hydrants.	NA	As above	NA
	2. Hose box.	NA	As above	NA
13.	<b>Pumping arrangements.</b>	Provided & Maintained by DLF Mall, Saket		
	<b>a) Ground Level</b>			
	➤ Discharge of main pump.	NA	As above	NA
	➤ Head of main pump.	NA	As above	NA
	➤ Number of main pumps.	NA	As above	NA
	➤ Jockey Pump output.	NA	As above	NA
	➤ Jockey Pump head.	NA	As above	NA
	➤ Standby Pump output.	NA	As above	NA
	➤ Standby Pump head.	NA	As above	NA
	➤ Auto Starting/Manual Stopping.	NA	As above	NA
	<b>b) Terrace Level</b>			
	➤ Discharge of pump.	Required	As above	MR
	➤ Head of pump.	Required	As above	MR
	➤ Power supply.	Required	As above	MR
	➤ Auto starting of pump.	Required	As above	MR
14.	<b>Captive water storage for Fire Fighting.</b>	Provided & Maintained by DLF Mall, Saket		
	1. Underground tank capacity.	Required	As above	MR
	2. Draw-off connection.	Required	As above	MR
	3. Fire Service Inlet.	Required	As above	MR
	4. Access to tank.	Required	As above	MR
	5. Overhead tank capacity.	Required	As above	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>	Provided & Maintained by DLF Mall, Saket		
	1. Pressurization of lift shaft.	NA	NA	NA
	2. Pressurization of lift lobby.	NA	NA	NA
	3. Communication in lift car.	Required	As above	MR
	4. Fireman's switch.	Required	As above	MR
	5. Lift signage.	Required	As above	MR
17	<b>Standby Power Supply</b>	Required	Provided	MR
18.	<b>Refuge Area</b>			
	1. Total area	NA	NA	NA
	2. Location	NA	NA	NA

19.	<b>Fire Control Room.</b> 1. Detector System Panel. 2. Flow Switch Panel. 3. PA system Panel. 4. Battery backup 5. Building floor plan	Provided & Maintained by DLF Mall, Saket				
		Required	As above	MR		
		NA	As above	NA		
		Required	As above	MR		
		Required	As above	MR		
	NA	As above	NA			
20.	<b>Special Fire Protection System for the Protection of special Risk, if any:</b>	Required	Co2 flooding provided near electrical panel	MR		
<b>Details of Seating Capacity &amp; Exits are as below: -</b>						
Audi	1	2	3	4	5	6
Seats	156	156	133	169	169	169
Exits	3	3	3	3	3	3
<p>The Fire protection systems provided in the cinema building were randomly checked/ tested and found functional at the time of inspection.</p> <p>Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rule, FSC issued vide letter No. F6/DFS/MS/Cinema/2009/646 dated 04/03/2009, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.</p> <p>Accordingly, DFA is put up for approval and signature please.</p>						
						<p style="text-align: right;"><i>R.N. Singh</i> 8/2/17</p> <p>Signature of Inspecting Officer Name : R.N. Singh Designation: ADO</p>

Renewal

Cinepolis India Pvt Ltd, DLF Place Mall, Saket, ND-17

D.O. (SD)

*Pl Speak about the Configuration of building & FSC of mall is also not enclosed.*

*ADD  
R.N.S.*

*spoken,*

*Anilash  
19/2/17*

*Sir. FSC of DLF Place mall placed on C-222 for above reference file - *R.N. Singh*  
14/2*

*DD/SD*

*Anilash  
14/2/17*