


No. F6/DFS/MS/2017/SZ/272

Dated: 28/02/17

FIRE SAFETY CERTIFICATE

Certified that M/s M.L.Bhartia Auditorium building at 72, Lodhi Estate, New Delhi-110003, comprised of basement, ground plus three upper floors but Auditorium is at ground floor only without balcony, owned/occupied by M.L.Bhartia Auditorium was granted Fire Safety Certificate by this department vide letter no. F6/DFS/MS/2014/SZ/301, dated 04.03.2014. The premises was re-inspected by the officer concerned of this department on 15.02.2017 in the presence of Sh. Arshad, Manager Admn. and found that the auditorium building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for **Occupancy Class-D Assembly Building(Auditorium)** at ground floor only with effect from...28/02/2017 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...28/02/2017 at New Delhi by



(Vipin Kental)

Chief Fire Officer

T.No.011-23412225



Copy To:- 1. Joint C.P.Licensing, PS Defence Colony, New Delhi.
2. M/s M.L.Bhartia Auditorium building at 72, Lodhi Estate, New Delhi-110003.

Conditions for the validity of fire safety certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate in form J, six month prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	M/s M.L.Bhartia Auditorium building at 72, Lodhi Estate, New Delhi-110003.		
2	Type of Occupancy	Group "D" Assembly Building.		
3	Building Comprised of	Basement (storage & services), ground plus three upper floors but Auditorium is at ground floor only having 112 seats. Others floors are used as offices and classrooms.		
4	Type of case	Renewal		
5	Details of previous NOC	F6/DFS/MS/2014/SZ/301, dated 04.03.2014.		
6	Fire safety directives letter No	F6/DFS/MS/BP/2002/113, dated 22.07.2002.		
7	Date of inspection	15.02.2017.		
8	Name of the inspecting Officers	ADO Vedpal		
9	Name and designation of officers from the building side	Sh. Arshad, Manager Admn.		
10	Year of construction	2004		
11	Applicant's letter No.	No.297-302/Joint C.P/Lic (Amst.), Dated 04.02.2017.		
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements/ Existing Fire Protection System	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	9m	12m	MR
	2) Gate width	5m	5m	MR
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	02nos.	03nos.+1ramp	MR
	b. Width of staircase			
	1. Upper floors	N/A	N/A	N/A
	2. basements	Required	1.77m, 1.5, 1m & ramp=3.30m	MR
	c. Protection of exits			
	1. Fire check door	Required	Provided at basement floor only	MR(old case)
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	01no.	01no.	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	Required	03 Exits=2m each & 1Exit=87cm	MR
3	Compartmentation.			
	1. Fire check door	Required	Provided at basement floor only	MR(old case)
	2. Sealing of electrical shafts	Required	Provided	MR
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	Basement	30 a/c per hour 12 a/c per hour	Exhaust Fans Provided	MR
	Upper floors		Exhaust Fans Provided	MR
5	Fire Extinguishers			
	Total numbers	12Nos	14 Nos. Provided	MR
	Types	ABC, CO2 & WCO2 ISI	ABC, W CO2 & CO2	MR
	ISI marking		Provided	MR
6	First-Aid Hose Reels.			
	Total numbers on each floor	02nos.	02nos near auditorium	MR
	Length of Hose reel hose	30m	30m	MR
	Nozzle Diameter	5mm	5mm	MR


k

INSPECTION REPORT

7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	Location of Main Panel	N/A	N/A	N/A
	Location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	Provided	N/A
9	Public Address System.	N/A	Provided	N/A
10	Automatic Sprinkler System.			
	Basement	Required	Provided	MR
	Upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	150mm	150mm	MR
	Number of Hydrants per floor	01no.	01no.	MR
	hose Box	01no.	01no.	MR
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	house box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	1620LPM	1620LPM	MR
	b. Head of main pump	70m	70m	MR
	c. Number of main pumps	01no.	01no.	MR
	d. jockey pump out put	180LPM	10LPM	MR
	e. jockey pump head	70m	70m	MR
	f. Standby Pump output	1620LPM	1620LPM	MR
	g. Stanby Pump head	70m	70m	MR
	h. Auto Starting/Manual stopping	Required	Provided	MR
	pump house access	Required	Provided	MR
	2. Terrace level			
	a. Discharge of pump	900LPM	900LPM	MR
	b. head of the pump	40m	40m	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	50,000 ltr	50,000 Ltr Provided	MR
	a. Draw-off connection	Required	Provided	MR
	b. fire service inlet	Required	Provided	MR
	c. Access to tank	Required	Provided	MR
	Over head tank Capacity	20000 ltr	20,000 ltr Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	total area	N/A	N/A	N/A
	location	N/A	N/A	N/A
19	Fire control room			
	a. Detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A

N/27

INSPECTION REPORT

20	Special Fire Protection systems for protection of special risks, if any: ABC & CO2 Fire Extinguishers provided for electric panel.
<p>The fire protection systems provided in the building were checked and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the FSC issued vide letter No.F.6/MS/DFS/2014/SZ/301, dated 04.03.2014 renewal under rule 37 of the Delhi Fire Service Rule 2010 is recommended.</p> <p>Accordingly DFA is put up for kind consideration please</p>	
<p style="text-align: center;">  Signature of the Inspecting Officer Name: Vedpal Designation: ADO(SJ) </p>	

~~DO (S.D)~~

~~Anilash~~
17/2/17

~~dy CFO (S2)~~

~~dy CFO~~
12/2

641/CFO S2
22/2/17/28/2




CFO (S2)

M.Sc.Eng

FT letter

17/2

FT letter is put up for sign please


22/2/17
ADO(SJ)

CFO (S2)

M.Sc.Eng 17/2