

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No. F-6/DFS/MS/SCHOOL/WZ/2017/ 295

Dated: 02/03/2017

**FIRE SAFETY CERTIFICATE**

Certified that the **S. D. M. C. Primary School**, Located at **Tatar Pur, New Delhi-110027**, comprised of Ground + 01 Upper Floors was inspected by the officer concerned of this department on 03-02-2017 in the presence of Ms. Sarita Routela (V. Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore complied with the fire prevention and fire safety requirements in accordance DOE 3298-3398 dated 1-3-11 and that the premises is fit for occupancy class "Educational" Group B with effect from 02/03/17 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.


Issued on ...02/03/17... at New Delhi by.

  
( Atul Garg)

Chief Fire Officer,  
Delhi Fire Service

Copy to:

Ms. Sarita Routela (V. Principal)  
**S. D. M. C. Primary School, Tatar Pur, New Delhi-110027.**

  
23/2/17

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

## INSPECTION REPORT

2. Name & address of the building: S.D.M.C. Primary School, Located at Tatar Pur, New Delhi-110027.
3. Type of Occupancy : Educational (Ground +1 Upper Floor)
4. Type of Case : New
5. Details of previous NOC : New case ( **Earlier FSC was issued to old building that has been demolished**)
6. Fire Safety directives Letter No. : DOE 3298-3398 dated 1-3-11
7. Date of inspection : 03/02/2017
8. Name of the Inspecting Officer : Udai vir Singh, ADO (WP)
9. Name and designation of Officer  
from the building side :Ms. Sarita Routela (V Principal)
10. Year of Construction : 2014
11. Applicant's letter No. : Nil Dated- 04-01-2017

No. of Students=258
No. of class rooms=6
Plot area=38000sq.ft
Covered area=8000 Sq.ft

S No	Minimum standards on fire prevention and fire safety U/R	DOE 3298-3398 dated 1-3-11	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	6 mtr Accessible NA	7m Provided 396cm Provided NA	MR MR NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper floors</li> <li>• Basements</li> </ul>	2 NA	2 NA	MR NA
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper floors</li> <li>• Basements</li> </ul>	1.5 m NA	2x150cm Provided NA	MR NA
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	NA NA	NA NA	NA NA
	d. No of continuous staircase to terrace			
	e. Width Of Corridor	1.5m	210cm Provided	MR
	f. Door Size	1 mtr	1.6cm Provided	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	NA NA	NA NA	NA NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	8 nos. ABC & CO <sub>2</sub> ISI marked	8 Provided Provided Provided	MR MR MR





19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbers

..... Nil .....

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Name

Designation

Designation