

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

No. F6/DFS/MS/Banquet/2017/319

Dated: 06/03/17

FIRE SAFETY CERTIFICATE

Certified that the Govindam Bhawan Banquet Hall running on ground plus first floor of the building comprised of ground plus two upper floors at 1447-48/4, Durgapuri Chowk, Loni Road, Delhi -110093 owned/occupied by M/s AVM Exports Pvt. Ltd. was issued FSC vide letter No-F6/DFS/MS/Banquet/2014/NDZ/127 dated 30/01/14. The premises was re-inspected by officer concerned of this department on 13/02/17 in the presence of Mr. Alok Narula, Owner of the Banquet Hall and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and found that the ground plus first floor of Banquet Hall building is fit for occupancy Group "D" Assembly Building with effect from ...06/03/17. for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, subject to conditions printed overleaf.

Issued on.....06/03/17.....at New Delhi by

  
(Vipin Kental)  
Chief Fire Officer

To,

Mr. Alok Narula (Owner),  
M/s Govindam Bhawan Banquet hall  
(Aunit of AVM Export Pvt. Ltd.  
1447-48/4, Durgapuri Chowk, Loni Road,  
Delhi- 110093

Copy:-

The Dy. Health Officer,  
East Delhi Muncipal Corporation,  
Health Department, Karkardooma,  
North Zone,Shahdara, Delhi.

### CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry

APD (Mrs Yadav)



1. Name & address of the building : Govindam Bhawan Banquet hall,  
1447-48/4, Loni Road, Durgapuri, Delhi-110053
2. Building is comprised of : Ground plus two upper floors  
**(Banquet Hall is running on G+ 1<sup>st</sup> floor only)**
3. Type of Occupancy : Assembly Building (Banquet Hall)
4. Type of Case : **Renewal**
5. Details of Previous FSC letter : F6/DFS/MS/Banquet/2014/NDZ/127 dt-30/01/14
6. Fire Safety directives letter No : F16/DFS/MS/BP/2013/2296 dated-22/10/13
7. Date of Inspection : 13/02/2017
8. Name of the Inspecting officers : ADO V. B. Yadav
9. Name and designation of Officer  
from the building side : Mr. Alok Narula, Owner
10. Year of Construction : 2013
11. Applicant's letter No : Letter No.--Nil, Dated-10/01/2017

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Requirement as per guidelines	Provided at Site	Remarks MR/NMR
01	Access to Building			
	• Road width	12 mtr.	30 mtr.	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper floor	02 nos.	03 nos.	MR
	• Basement	N/A	N/A	N/A
	b. Width of Staircases			
	• Upper floor	02 mtr.	2.0 & 1.50 mtr, 1.0 mtr	MR
	• Basement	N/A	N/A	N/A
	c. Protection of Exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	02 no.	02 no.	MR
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	02 mtr.	02 mtr.	MR
03	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	N/A	N/A (wiring concealed)	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	Required	Provided	MR
05.	Fire Extinguishers			
	• Total numbers	08 nos.	10 nos.	MR
	• types	ABC /CO <sub>2</sub>	ABC /CO <sub>2</sub>	MR
	• IS marking	ISI marked	ISI marked	MR




06	First-Aid-Hose Reels.			
	Total numbers on each floor	01 nos.	01 nos.	MR
	• Length of hose reel hose	30 mtrs	30 mtrs	MR
	• Nozzle diameter	05mm	05mm	MR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	Required	Provided	MR
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	100mm	MR
	• Number of hydrants per floor	01 nos.	01 nos.	MR
	• Hose box	01 nos.	01 nos.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting /manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	900 LPM	900 LPM	MR
	• Head of the pump	40 M	40 M	MR
	• Power supply	Required	Provided	MR
	• Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead tank capacity	15,000 ltrs.	15,000 ltrs	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	• Pressurization of lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17	Standby Power Supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, it is recommended to grant Fire Safety Certificate.

  
 Signature of the Inspecting Officer  
 Name- V. B. Yadav  
 Designation- A.D.O (Tahirpur)

~~DO (ED)~~

*live*  
 24/2

*DEFO (MMS)*

*25/2*

120/CP/102  
 6/8/17

C.F.P. - m.s.c.u F.T.M.

*46*