

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001**

No. F.6/DFS/MS/EH/2017/ N02/310

Dated 3/3/17

FIRE SAFETY CERTIFICATE

Certified that the **M/S DELHI KNIGHTERS RESTAURANT & CATERS (A Unit of Delhi Knights Restaurant & Caters Pvt. Ltd.)** located at **Plot No-4, R.G. Complex, AG-1,2,5,7,9,10,11,12,16,17,18,19 & 20, Motia Khan, New Delhi-110055** with restaurant on ground floor owned/occupied by Delhi Knighter's restaurant & Caters Pvt. Ltd. was issued FSC by this department vide letter F.6/DFS/MS/EH/2013/NDZ/1278 dated 05/12/2013. The restaurant was re-inspected by the officer concerned of this department on 26.02.2017 in the presence of **Sh. Tika Ram (manager)** and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the building/premises is fit for occupancy class **Assembly Group- D** with effect from 3/3/17 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 mentioned below.

Issued on3/3/17..... at New Delhi by.


3/3
(Vipin Kental)
Chief Fire Officer
Delhi Fire Service

Copy to:- M/S Delhi Kinghters Restaurant & Caters,(A unitof Delhi Knights Restaurant & Caters Pvt. Ltd.) Plot No. 4, R.G. Complex, Motia Khan, New Delhi – 110055.

Following fire safety directives may be adhered to:-

1. All fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. The means of escape shall be kept unobstructed/unlocked & remain available for speedy evacuation of occupants in case of an emergency.
3. Any loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
4. Any deviation with regard to construction, electric shall be verified by the concerned building sanctioning authority.
5. The trained fire fighting staff should be available round the clock.
6. This fire safety certificate may not be treated in any case for regularizations of unauthorized construction if any.
7. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.Delhigovt.nic.in.
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Plot No.4, R.G Complex AG- 1,2,5,7,9,10,11,1216,17,18,19,20
Motia khan, New Delhi (Knighter's Restaurant & Caters pvt. Ltd)
2. Building is comprised of : B+G+2 (2nd floor found closed)
3. Type of Occupancy : Restaurant (Assambly) at G. floor
4. Type of Case : Renewal
5. Details of Previous NOC : Letter no. F6/DFS/MS/EH/2013/NDZ/1278 dated 05.12.2013
6. Fire Safety direction letter No :
7. Date of Inspection : ~~03.12.2014~~ 26-2-17 
8. Name of the Inspecting Officers: : Sunil Chawdhary (Dy.CFO)
9. Name of the designation of Officer
from the building side : Mr. Tika Ram(Manager)
10. Year of Construction : 2005
11. Applicant's letter No : 62086-91/joint.C.P/Lic.(Amst.) dated delhi the 09.10.2013

S.No	Minimum Standards on fire prevention and fire safety U/R33	BBL Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	9 mt	MR
	Gate width	1.5 mt	2 mt	MR
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits	1500 mm	2000,1250&1000mm.	MR
	a. Number of Staircases			
	Upper Floor	N.A.	N.A.	N.A.
	Basement	N.A.	N.A.	N.A.
	B. Width of Staircases			
	Upper Floor	N.A.	N.A.	N.A.
	Basement	N.A.	N.A.	N.A.
	c. Protection of exits			
	Fire check door	N.A.	N.A.	N.A.
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	N.A.	N.A.	N.A.
	g. Width of Corridor	N.A.	N.A.	N.A.
	h. Door Size	1500 mm	2000 mm	MR
3	Compartmentation.			
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	N.A.	N.A.	N.A.
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	30a/c per hour	N.A.	N.A.
	Upper floor	12a/c per hour	NATURAL	MR

5.	Fire Extinguisher			
	Total numbers	06 no.	10 no.	MR
	types	CO ₂ &	Provided	MR
	IS marking	ABC,Wco ₂		
		ISI marked	Provided	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	01 no.	Provided	MR
	Length of hose reel hose	30 mt	Provided	MR
	Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	Smoke	Provided	MR
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters's location	N.A.	N.A.	N.A.
8	MOEFA	N.A.	N.A.	N.A.
9	Public address System.	N.A.	N.A.	N.A.
10	Automatic Sprinkler System.			
	basement	N.A.	N.A.	N.A.
	upper floor	YES	Provided	MR
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	N.A.	N.A.	N.A.
	Number of hydrants per floor	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	Ground Level	N.A.	N.A.	N.A.
	Discharge of main Pump	N.A.	N.A.	N.A.
	Head of Main Pump	N.A.	N.A.	N.A.
	Number of main pumps	N.A.	N.A.	N.A.
	Jockey pump out put	N.A.	N.A.	N.A.
	Jockey pump head	N.A.	N.A.	N.A.
	Standby pump out put	N.A.	N.A.	N.A.
	Standby pump Head	N.A.	N.A.	N.A.
	Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	Pump House Access	N.A.	N.A.	N.A.
	Terrace Level	R	Provided	MR
	Discharge of pump	1680,450LPm	Provided	MR
	Head of the Pump	30 mtrs	Provided	MR
	Power supply	N.A.	N.A.	N.A.
	Auto Starting of pump	N.A.	N.A.	N.A.

14	Captive Water Storage for Fire Fighting.	N.A.	N.A.	N.A.
	Underground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	YES	Provided	MR
	Overhead Tank capacity	80,000 Liters	80,000 Liter	MR
15	Exit Signage.	YES	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	NA.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	N.A.	N.A.	N.A.
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	YES	ABC,CO ₂	MR

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

Keeping In view of the Substantial compliance of the compliance of the minimum standards on fire prevention and fire safety measures as required under the Rule it is recommended to grant fire safety Certificate under rule 35 of the Delhi Fire Service Rule 2010/ Restaurant is at ground floor recommended for FSC please.



Signature of the Inspecting Officer

Name Sunil Chawdhary

Designation DY. CFO(NDZ)

C.F.P.

FTD.

W
3/3

M.Scell.