

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001



NO. F6/DFS/MS/School/2017/SZ /305

Dated: 3 /03 /17

FIRE SAFETY CERTIFICATE

Certified that the SDMC Primary School, Village Nasirpur, New Delhi-110045, comprised of ground & ground plus one upper floor was granted NOC by this department vide letter no. F6/DFS/MS/School/2014/SZ/206 dated 10.2.2014. The Premises was re-inspected by the officer concerned of this department on 21.02.2017 in presence of Smt. Manju Shrivastava (Incharge) and found that the premises have deemed complied with fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Directorate of Education, Govt. of NCT of Delhi and that the premises/building is fit for occupancy class B "Educational building" with effect from 03/3/17 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 subject to compliance of the conditions under rule 38 of the Delhi fire service, printed overleaf.

Issued on 03/03/2017 at New Delhi by


3/3
OC (Vipin Kental)
Chief Fire Officer


Copy to:-

1. The Director (Education), SDMC, 23rd floor, Civic Centre, Minto Road, New Delhi.
2. The Principal, SDMC Primary School, Village Nasirpur, New Delhi-45.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	SDMC Primary School, Village Nasirpur, New Delhi-110045.		
2	Type of Occupancy	Educational Building "B" (Ground plus First floor)		
3	Type of case	Renewal		
4	Details of previous NOC	F6/DFS MS/School/2014/SZ/206 dated 10.2.2014		
5	Fire safety directives letter No	Edu. Circular. No. F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011.		
6	Date of inspection	21.02.2017		
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Mrs. Manju Shrivastava (Incharge)		
9	Year of construction	2006		
10	Applicant's letter No.	Nil dated 3.2.2017	Ground & ground plus one upper floor	
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	6 Mtrs.	9 Mtrs.	MR
	2) Gate width	4.5 Mtrs.	Direct Accessible from road	MR
	3) Width of internal road	N/A	N/A	M/R
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	Two	Two	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.5 Mtrs. if less than 1.5 Mtr. additional Stairecase required of .75 Mtr.	1.5 Mtrs. & 1.25 Mtrs.	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	N/A	N/A	N/A
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1 Mtr.	1 Mtr.	MR
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	N/A	N/A	N/A
	upper floors		N/A	N/A
5	Fire Extinguishers			
	total numbers	1 Co2 OR ABC For every 300 Sq. Mtrs. ISI Marked	7 Nos.	MR
	Types		ABC	MR
	ISI marking		Provided	MR

417

6	First-Aid Hose Reels.			
	total numbers on each floor	N/A	N/A	N/A
	Length of Hose reel hose	N/A	N/A	N/A
	Nozzle Diameter	N/A	N/A	MR
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	N/A	N/A	N/A
	b. head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	N/A	N/A	N/A
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	N/A	N/A	N/A
15	Exit Signage.	Required say	provided say	MR say
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

418

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any:	ABC		

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, renewal of FSC issued vide letter no. F6/DFS/MS/School/2014/SZ/206 dated 10.2.2014 is recommended under rules 37 of the Delhi Fire Service Act 2007 & Rules 2010.

Accordingly DFA is put up for approval and signature please.

S.P. Bhardwaj
21/2/17
Signature of the Inspecting Officer

Name S.P. Bhardwaj

Designation ADO (Dwarka)

102/DOCSW
23/02/2017

DO(SA)

[Signature]
22/2/17

DCFO(SZ)