

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI-110001**

No. F6/DFS/MS/Business/SZ/2017/338

Dated: 8/3/17

FIRE SAFETY CERTIFICATE

Certified that the **Excel Infotech Limited, situated at 3 LSC, Pamposh Enclave, G.K.-I, New Delhi-110048**, comprised of **2 tier Basement, Ground Floor & 4 Upper floors** has already been issued FSC by this department vide letter No. F6/MS/DFS/2005/HR/2506/Com/HV/592 dated 26/10/2005. The premises was re-inspected by the officer concerned of this department on **21/02/2017** in the presence of **Mr. P. Pradhan (Executive Technical)** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Group-E "Business"** Building with from **8/3/17**.....for a period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on**8/3/17**..... at New Delhi by

(Vipin Kental)
Chief Fire Officer
Tel: 011-23412225

Copy to :-

1. The Authorized Signatory, Excel Infotec Limited, 910, Ansal Bhawan, 16 K. G. Marg, New Delhi-110001
2. The Executive Engineer (Bldg.), Building Department, South MCD, Civic Center, Minto Road, New Delhi-110002.

Conditions for the validity of fire safety certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
5. This fire safety certificate may not in any way be treated as regularization of unauthorized construction, if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT

1. Name & address of the building : Excel Infotech Limited, 3 LSC, Pamposh Enclave, G.K.-I, New Delhi-110048
2. Type of Occupancy : Class-E "Business"
3. Type of Case : Renewal
4. Details of Previous NOC : No. F6/MS/DFS/2005/HR/2506/Com/HV/592 dated 26/10/2005
5. Fire Safety directives letter No : 12 points of 1986 Act
6. Date of inspection : 21/02/2017
7. Name of Inspecting Officer : A. K. Malik
8. Name and designation of officers
From the building side : Mr. P. Pradhan (Executive Technical)
9. Year of Construction : 2005 [2 tier Basement + GF + 4 Upper floors]
10. Applicant's letter No. : Nil dated 23/01/2017, outdoor diary no. 749 dated 23/01/17

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	12 Fire Safety Points	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Approachable NA NA	Provided (Two sides) Boundary less building NA	MR (old case) MR MR
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	Required	2 Nos	MR
		Required	2 in Upper Basement 1 in Lower Basement	MR (old case)
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor 	Required	1.08-1.25m (Lower basement to terrace) & 0.73m (Upper basement to 4 th Floor)	MR (old case)
	<ul style="list-style-type: none"> • Basements 	Required	1.08-1.25m & 0.73m in upper basement & 1.08m in Lower Basement	MR (old case)
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace	One	One	MR
	e. Width of Corridor	-NA-	-NA-	-NA-
	f. Door Size	-NA-	1m (final exit)	-NA-
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	Required	Provided	MR
		Required	Provided	MR
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> • Upper floors 	-NA-	-NA-	-NA-
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types 	Portable Appliances	60 No's	MR
			ABC/W. CO ₂ /CO ₂ -10/10/10 No's	MR
	<ul style="list-style-type: none"> • IS marking 		Yes	MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	Required	Two	MR
		Required	30m	MR
		Required	5mm	MR

	<ul style="list-style-type: none"> Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Required -NA- Required Required	Ground Floor -NA- Provided All floors	MR -NA- MR MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	Required Required -NA-	Provided Provided -NA-	MR MR -NA-
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	Required Required Required	100mm Two Two	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	-NA- -NA-	-NA- -NA-	-NA- -NA-
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access 	-NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA-	900LPM 53m Two -NA- -NA- -NA- -NA- -NA- Provided Provided	-NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA-
	<ul style="list-style-type: none"> Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	900 LPM & Jockey 42m Required Required	900 LPM & 2 x 180 LPM 53m & 2 of 35m Provided Provided	MR MR MR MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	Required Required Required Required Required	50,000 Lts Provided Provided Provided 15,000 Lts.	MR MR MR MR MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	-NA- -NA- -NA- Required -NA-	-NA- -NA- Provided Provided Provided	-NA- -NA- -NA- MR -NA-
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	<ul style="list-style-type: none"> Total Area Location 	-NA- -NA-	-NA- -NA-	-NA- -NA-
19.	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel Flow Switch Panel PA System Panel Battery backup 	-NA- -NA- Required Required	-NA- -NA- Provided Provided	-NA- -NA- MR MR

-N/7-

Excel Infotech Limited, 3 LSC, Pamposh Enclave, G.K.-I, New Delhi-110048

	• Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of special Risks, if any:	-NA-	CO ₂ & DCP extinguishers are provided near LT Panel	-NA-

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, It is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Accordingly reply letter in shape of DFA is put up.

A. K. Malik
23/2/12

Signature of Inspecting Officer
Name: A. K. Malik
Designation: Divisional Officer

DY. CFO (SZ)

668/CFO/SZ
23/2/12

[Signature]
23/2



CFO/SZ

M. Scell

RTM.

[Signature]
23/2

Soln R.T. is put up for sig. please.