

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE

NEW DELHI- 110 001

No. F6/DFS/MS/2017/ND2/322

Dated 8/3/17

FIRE SAFETY CERTIFICATE

Certified that the Gobind Banquet 512/2-B, JheelKhuranja, Geeta Colony Chowk, Delhi-51 owned/occupied by Gobind Banquet was granted FSC vide letter No. F6/DFS/MS/BNQT/2014/1402/96 dt 24.01.14. The Premises was re-inspected by the officer concerned of this department on 13/02/2017 in the presence of Mr.Desraj (Owner) and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules, 2010 and found that the building is fit for occupancy class "D (Assembly building)" with effect from ... 8/3/17 for a period of three years , subject to conditions printed overleaf.

Issued on ... 8/3/17 at New Delhi by

VK
7/3.
(Vipin Kental)
Chief Fire Officer

O/C
CS

To,

Shri Desraj,
Gobind Banquet 512/2-, JheelKhuranja,
Geeta Colony Chowk, Delhi-51,

Copy to-

The Deputy Health Officer,
Shahdara (South) Zone, EDMC,
Health Department, Shahdara South Zone, Delhi

Conditions

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
6. This FSC may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. Basement shall be used as per BBL
8. The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"
9. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

1. Name & address of the building : Gobind Banquet, 512/2-,JheelKhuranja,Geeta Colony Chowk, Delhi-51.
2. Building is comprised of :Ground floor
3. Type of Occupancy : Assembly(Banquet Hall)
4. Type of Case : Renewal
5. Details of Previous FSC : F6/DFS/MS/BNQT/2014/1402/96 dt 24.01.14
6. Fire Safety direction letter No : F6/DFS/MS/BP/2013/2202 Dated-10/09/13
7. Date of Inspection : 13/02/2017
8. Name of the Inspecting Officers: : R.K.Yadav ADO
9. Name of the designation of Officer from the building side : Mr.Desraj (Owner)
10. Year of Construction : 1976
11. Applicant's letter No : Nil Dated19/01/17

Sr. no.	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	06 m	17 m	MR
	Gate width	N/A	N/A	N/A
	Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	Upper Floor	2 nos.	2 nos.	MR
	Basement	N/A	N/A	N/A
	b. Width of Staircases			
	Upper Floor	1.5 m	1.5 m each	MR
	Basement	N/A	N/A	N/A
	c. Protection of exits			
	Fire check door	N/A	N/A	N/A
	Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	2 m	3.2m, 2m,2m	MR
	i. No. of door	3 Nos	3 Nos	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	30a/c per hour	N/A	N/A
	• Upper floor	12a/c per hour	N/A	N/A

5.	Fire Extinguisher			
	• Total numbers	03 nos.	8 Nos.	MR
	• Types	CO ₂ + ABC	Provided	MR
	• ISI marking	ISI marked	Provided	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	01 no.	Provided	MR
	Length of hose reel hose	30 m	Provided	MR
	Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	N/A	N/A	N/A
	Location of main panel	N/A	N/A	N/A
	Location of repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	Hooter's location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floor	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	size of riser/down-comer	100 mm	Provided	MR
	Number of hydrants per floor	1 no.	Provided	MR
	Hose Box	1 no.	Provided	MR
12	Yard Hydrants.			
	Total number of hydrants	N/A	N/A	N/A
	Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	450LPM	Provided	MR
	➤ Head of the Pump	40 M	Provided	MR
	➤ Power supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A

(Sovind Pangret, Jheel Khuranga)

(Sovind Bangpet, Jhel (Chungga))

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N/A	N/A	N/A
	Draw-off connection	N/A	N/A	N/A
	Fire service inlet	N/A	N/A	N/A
	Access to tank	N/A	N/A	N/A
	Overhead Tank capacity	10,000 Liters	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N/A	N/A	N/A
	Pressurization of Lift lobby	N/A	N/A	N/A
	Communication in lift car	N/A	N/A	N/A
	Firemen's grounding switch	N/A	N/A	N/A
	Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	Total area	N/A	N/A	N/A
	Location	N/A	N/A	N/A
19	Fire Control Room			
	Detector system panel	N/A	N/A	N/A
	Flow switch panel	N/A	N/A	N/A
	PA system panel	N/A	N/A	N/A
	Batter backup	N/A	N/A	N/A
	Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	Required	Co ₂ local application in electrical panel provided	MR

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The fire safety certificate issued vide letter no. F6/DFS/MS/BNQT/2014/1402/96 dt 24.01.14 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Name :-R.K.Yadav

Designation :-ADO(LN)

DO(ED)

Signature
29/2