

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No.

F6/DFS/MS/2017/SZ/365

Dated:

14/03/17

FIRE SAFETY CERTIFICATE

Certified that **M/s Auditorium building at India Islamic Cultural Centre located at 87-88, Lodhi Road, New Delhi-110003**, comprised of lower ground, ground plus one upper floor but Auditorium is at first floor only, owned/occupied by India Islamic Cultural Central was granted Fire Safety Certificate by this department vide letter no. **F6/DFS/MS/2014/SZ/448, dated 04.04.2014**. The premises was re-inspected by the officer concerned of this department on 03.03.2017 in the presence of Sh. Mohd. Nausherawan, Junior Engineer and found that the auditorium building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for **Occupancy Class-D Assembly Building(Auditorium)** at ground and first floor only with effect from.....14.03.2017 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on14.03.2017 at New Delhi by


(Vipin Kental)

Chief Fire Officer

T.No.011-23412225

Copy To:- 1. Joint C.P.Licensing, PS Defence Colony, New Delhi.
2. Sh. Mohd. Nausherawan, India Islamic Cultural Centre located at 87-88, Lodhi Road, New Delhi-110003.

Conditions for the validity of fire safety certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate in form J, six month prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	M/s Auditorium building at India Islamic Cultural Centre located at 87-88, Lodhi Road, New Delhi-110003.		
2	Type of Occupancy	Group "D" Assembly Building.		
3	Building Comprised of	Lower ground, ground plus one upper floor. (Auditorium at first floor only having 300 seats).		
4	Type of case	Renewal		
5	Details of previous NOC	F6/DFS/MS/2014/SZ/448, dated 04.04.2014.		
6	Fire safety directives letter No	No. F6/DFS/MS/95/4336, Dated 10.04.95		
7	Date of inspection	03.03.2017.		
8	Name of the inspecting Officers :	ADO Vedpal		
9	Name and designation of officers from the building side	Sh. Mohd. Nausherawan, Junior Manager		
10	Year of construction	2006		
11	Applicant's letter No.	No. 440-42/Joint C.P/Lic.(Amst), Dated 09.02.2017		
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements/ Existing Fire Protection System	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	9m	20m	MR
	2) Gate width	5m	5m	MR
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	05nos.	05nos.	MR
	2. Basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	Required	03nos=1.5m, 01no=2m & 01no=1.25m	MR(old case)
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	01no.	01no.	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	Required	03 Exit gates (2nos=1.50m, & 1no= 96cm)	MR(old case)
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	Required	Provided	MR
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	Basement	30 a/c per hour	N/A	N/A
	Upper floors	12 a/c per hour	Exhaust Fans Provided	MR
5	Fire Extinguishers			
	Total numbers	06Nos	10 Nos. Provided	MR
	Types	ABC, CO2 & WCO2	ABC, W CO2 & CO	MR
	ISI marking	ISI	Provided	MR

N/35

INSPECTION REPORT

6	First-Aid Hose Reels.	(Fire fighting system is common for entire building)		
	Total numbers on each floor	02nos.near auditorium	04nos. Near auditorium	MR(old case)
	Length of Hose reel hose	30m	30m	MR
	Nozzle Diameter	5mm	5mm	MR
7	Automatic fire detection and alarming system			
	Type of detectors	Smoke	Somke	MR
	Location of Main Panel	Ground Floor	Ground Floor	MR
	Location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	Required	Battery Backup Provided	MR
	Hooter's location	All Areas	All Areas	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	Basement	N/A	N/A	N/A
	Upper floors	Required	Provided	MR
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants	(Fire fighting system is common for entire building)		
	Size of riser/down-corner	100mm	100mm	MR
	Number of Hydrants per floor	01no. Near auditorium	01no. Near auditorium	MR(old case)
	hose Box	01no.	01no.	MR
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	house box	N/A	N/A	N/A
13	Pumping arrangements	(Fire fighting system is common for entire building)		
	1. Ground level			
	a. Discharge of main Pump	2800LPM	2800 LPM	MR
	b.Head of main pump	70m	70m	MR
	c.Number of main pumps	01no.	01no.	MR
	d.jockey pump out put	180PM	180LPM	MR
	e.jockey pump head	70m	70m	MR
	f. Standby Pump output	2800LPM	2800LPM	MR
	g.Stanby Pump head	70m	70m	MR
	h.Auto Starting/Manual stopping	Required	Provided	MR
	pump house access	Required	Provided	MR
	2.Terrace level			
	a. Discharge of pump	N/A	N/A	N/A
	b. head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	N/A	N/A	N/A
14	Captive water storage for fire fighting	(Fire fighting system is common for entire building)		
	1. Underground tank capacity	100,000 ltr	100,000 Ltr	MR
	a. Draw-off connection	Required	Provided	MR
	b. fire service inlet	Required	Provided	MR
	c.Access to tank	Required	Provided	MR
	Over head tank Capacity	30000 ltr	30,000 ltr	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	total area	N/A	N/A	N/A
	location	N/A	N/A	N/A

N/36

INSPECTION REPORT

19	Fire control room	(Fire fighting system is common for entire building)		
	a. Detector system Panel	Required	Provided	MR
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	Required	Provided	MR
	d. Batter backup	Required	Provided	MR
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: ABC & CO2 Fire Extinguishers provided for electric panel. MR			

The fire protection systems provided in the building were checked and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the FSC issued vide letter No.F.6/MS/DFS/2014/SZ/448, dated 04.04.2014 renewal under rule 37 of the Delhi Fire Service Rule 2010 is recommended.

Accordingly DFA is put up for your approval and signature please.

[Signature] 9/3/17
Signature of the Inspecting Officer
Name: Vedpal
Designation: ADO(SJ)

~~D.O. (S.D.)~~
[Signature]
 6/3/17

~~Dy. CFO (SZ) / on MR~~
~~CFO (SZ)~~
 m.s cell

FTD.
 W
 9/3.

699/CFO(SZ)
 14.3.17