

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2017 / *club/wz/358*

Dated *14/03/17*

FIRE SAFETY CERTIFICATE

Certified that the **Roshanara Club Ltd, located at Roshanara Garden, Delhi- 110084** comprised of basement, ground and one upper floors owned/ occupied by **Roshanara Club Ltd** was granted Fire Safety Certificate by this department vide letter no. **F6/DFS/MS/Club/2013/WZ/1297 dated 10.12.2013**. The premises was re-inspected by the officers concerned of this department on 25.02.2017 in the presence of **Col. K. B. Sharma** and found the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010. Hence the NOC is renewed and premises is fit for **Class -D(Assembly)** occupancy with effect from *14/03/17* for a period of **03 (Three) years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on ...*14.03.17*..... at New Delhi by

(Signature)
(Atul Garg)

Chief Fire Officer
Ph-011-23414250

Copy to:-

1. The Secretary, Roshanara Club Ltd., Roshanara Garden, Delhi-110084.

INSPECTION REPORT

1. Name & address of the building : Roshanara Club Ltd., Roshanara Garden, Delhi- 110084.
2. Type of Occupancy : Assembly (Basement+G+01 upper floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/Club/2013/WZ/1297 dated 10.12.2013
5. Fire Safety directives letter No : F6/DFS/MS/BP/93/1516 dated 09.09.1993
6. Date of inspection : 25/02/2017
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers
from the building side : Col. K.B. Sharma
9. Year of Construction : 1993
10. Applicant's letter No. : Nil dated 14.01.2017

	Minimum Standards on fire prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	06m	MR
	• Gate width	5m	5m	MR
	• Width of internal road	5m	5m	MR
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	03	03	MR
	• Basements	02	02	MR
	b. Width of staircases			
	• Upper Floors	1.50m	150m, 1.45m & 75 cm Iron staircase	MR(Old case)
	• Basements	1.50m	1.20m & 1.10m	MR(Old case)
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	01	MR
e. Width of Corridor	1.2m	1.2m	MR	
f. Door Size	1.5m	1.70m each exits	MR	

3	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	30 a/c per hour	Exhaust fan	MR
	• Upper floors	12 a/c per hour	Natural Ventilated	MR
5	Fire Extinguishers			
	• Total numbers	16 W.Co2, & 10 Co2	30nos	MR
	• Types	ABC/Co2	W.Co2- 08, DCP-16 & Co2-6	MR
	• ISI marking	Yes	Yes	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	04	04	MR
	• Length of hose reel hose	30 m	30m	MR
	• Nozzle diameter	5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	Required	Provided	MR
	• Location of Main Panel	GF	Provided	MR
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			

	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	150mm	150mm	MR
		02	02	MR
		02	02	MR
12	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	02	02	MR
		Required	Provided	MR
13	Pumping Arrangements			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	450 lpm	NA
		NA	180 lpm	NA
		NA	40m	NA
		NA	Provided	NA
14	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	1,00,000 ltr	1,00,000 ltr.	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		50,00 ltr	50,00 ltrs	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby 	NA	NA	NA
		NA	NA	NA

	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	NA	Provided	NA
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	Provided in Lobby	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested/ checked and found some in working order at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. 1297 dated 10.12.2013 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Rajesh Kumar

Signature of the Inspecting Officer
Name: - Rajesh Kumar
Designation:- ADO/RN

DOIN/60
Singh
5.3.17

Dy. Insp. Fire

Chd. Insp. Fire
9/3/17

FT P/S

ADO/RN

As approved, F.T. letter is put up for your signature of *1/11/17*

10/3