

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

NO.F6/DFS/MS/School/2017/SZ/ 390

Dated: 16.03.2017

FIRE SAFETY CERTIFICATE

Certified that the Delhi English Academy School, located at Village Dhool Siras, Sector-25, Dwarka, New Delhi-110077, comprised of ground floor only having 24 class rooms was granted NOC by this department vide letter no. F6/DFS/MS/School/2014/SZ247 dated 19.2.2014. The premises was re-inspected by the officer concerned and found that management has constructed one more block comprised of Ground plus one upper floor (having 6 class rooms at each floor) and have complied with fire prevention & fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Directorate of Education, Govt. of NCT of Delhi, and that the building is fit for occupancy class B "Educational building" with effect from...16.03.2017 for a period of **three** years, in accordance with rule 36 unless renewed 37 or sooner cancelled under rule 40 subject to compliance of the conditions under rule 38 of the Delhi Fire Service, Rules 2010, printed overleaf.

Issued on16.03.2017..... at New Delhi by

15/3
qc (Vipin Kental)
Chief Fire Officer
Suy

Copy to:-

1. The Deputy Director (Education) GNCT of Delhi, Old Secretariat, New Delhi-110054.
2. Principal, Delhi English Academy School, located at Village Dhool Siras, Sec-25, Dwarka, New Delhi-110077,

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	Delhi English Academy School, Village Dhool Siras, Sector-25, Dwarka, New Delhi-110077		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	Renewal/ Addition of New Block G+1 having 6 rooms at each floor		
4	Details of previous NOC	No.F6/DFS/MS/School/2014/247 dated 19.2.2014		
5	Fire safety directives letter No	D.O.E Circular. No. F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011.		
6	Date of inspection	4.3.2017		
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Sh. Rajesh Kumar Sharma (Principal)		
9	Year of construction	Old Block 1996 New Block 2016		
10	Applicant's letter No.	DEA/2017/02/NOC/B Dated 14.2.2017	Old Block Ground floor only	
			Newly Constructed Block Ground plus one upper floor (6 Class rooms at ground & 6 class rooms at first floor)	
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	DOE Cir. Dated 1.3.2011	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	6 Mtrs.	6 Mtrs.	MR
	2) Gate width	4.5 Mtrs.	5 Mtrs.	MR
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	One	Two	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.50 Mtrs.	1.50 Mtrs. each	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	Two	Two	MR
	e. Width of corridor	1.50 Mtrs.	2.25 Mtrs.	MR
	f. Door size	1 Mtr.	1 Mtr.	MR
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	30 a/c per hour 12 a/c per hour	N/A	N/A
	upper floors		Natural Vent.	MR
5	Fire Extinguishers			
	total numbers	One Co2 OR ABC For every 300 Sq. Mtrs.	14 Nos.	MR
	Types	ISI	Co2 & ABC Provided	MR
	ISI marking	ISI		MR

6	First-Aid Hose Reels.			
	total numbers on each floor	N/A	N/A	N/A
	Length of Hose reel hose	N/A	N/A	N/A
	Nozzle Diameter	N/A	N/A	N/A
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	N/A	N/A	N/A
	b. head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	N/A	N/A	N/A
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	N/A	N/A	N/A
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A


N/A

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: ABC Fire Extinguisher provided near electric panel MR			

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view compliance of minimum standards on fire prevention and fire safety required as per Directorate of Education Cir. No. F16/Estate/CC/Fire Safety/2011/3298 dated 1.3.2011, Fire safety certificate is recommended under rules 35 of the Delhi Fire Service Rules, 2010.

Accordingly DFA is put up for approval and signature please.


Signature of the Inspecting Officer
Name S.P. Bhardwaj
Designation ADO (Dwarka)

~~DO/SW~~

~~dy~~
6/3/17

~~DCFO (SZ)~~

~~dy~~
8/3

164/DO/SW
6/3/2017

702/CH/SZ
9/2/16/3/17