

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No. F6/DFS/MS/School/SZ/ 2017/406

Dated: 17/03/17

FIRE SAFETY CERTIFICATE

Certified that M/s Delhi National Public School, located at 101-102, Main Palam Vihar Road, Bijwasan, New Delhi-110061, comprised of lower ground and upper ground floor only, owned/occupied by Delhi National Public School, was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2014/SZ/22, dated 08-01-2014. The premises was re-inspected by the officer concerned of this department on dated 06.03.2017 in the presence of Mr. Rajiv Singh, teacher of the school and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education dated 01.03.2011 and that the premises is fit for occupancy class "B" educational building with effect from17/03/2017 for period of three years.

Issued17/03/2017 at New Delhi by.

(Vipin Kental)

Chief Fire Officer

T.No.011-23412225

To:- 1. The Principal, Delhi National Public School, located at 101-102, Main Palam Vihar Road, Bijwasan, New Delhi-110061.

2. The Director of Education, GNCTD, Old Sect, Delhi.

Conditions for the validity of fire safety certificate are as under:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. The employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All fire fighting equipments shall be maintained in perfect working condition all time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate in form J, six month prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	M/s Delhi National Public School, located at 101-102, Main Palam Vihar Road, Bijwasan, New Delhi-110061.		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	Renewal		
4	Details of previous NOC	No.F6/DFS/MS/School/2014/SZ/22, Dated 08.01.2014.		
5	Fire safety directives letter No	As per Director of Education Circular, dated 01.03.2011.		
6	Date of inspection	06.03.2017.		
7	Name of the inspecting Officers :	A.D.O. Vedpal.		
8	Name and designation of officers from the building side	Mr. Rajiv Singh, Teacher of the school.		
9	Building Comprised of	Lower ground plus upper ground floor. (Both floors are directly accessible from ground)		
10	Year of construction	2005		
11	Applicant's letter No.	No. DFS/DNPS/08-17, Dated 14.02.2017.		
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per Director Education Circular Dt 01.03.2011	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	Accessible	9m	MR
	2) Gate width	N/A	4m	N/A
	3) Width of internal road	N/A		N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	05nos	05nos.	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.5m & 75cm	LGF to terrace = 1.8mX02nos. LGF to UGF = 1.20, 1.10 & 1.5m	MR(old case)
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	01no.	02nos.	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1 Mtr	1Mtr Provided	MR
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	30 a/c per hour	N/A	N/A
	Upper Floors	12 a/c per hour	Natural Ventilation	MR
5	Fire Extinguishers			
	total numbers	12nos.	12nos.	MR
	Types	ABC & WCO2	ABC & Water CO2	MR
	ISI marking	ISI Mark	ISI Mark	MR
6	First-Aid Hose Reels.			
	total numbers on each floor	N/A	03nos. At LGF	N/A
	Length of Hose reel hose	N/A	30m	N/A
	Nozzle Diameter	N/A	5mm	N/A

Automatic fire detection and alarming system			
7	Type of detectors	N/A	N/A
	location of Main Panel	N/A	N/A
	location of Repeater panel	N/A	N/A
	Alternate source of power	N/A	N/A
	hooter's location	N/A	N/A
8	MOEFA	N/A	Provided
9	Public Address System.	N/A	
10	Automatic Sprinkler System.		
	basement	N/A	N/A
	upper floors	N/A	N/A
	sprinkler above false ceiling	N/A	N/A
11	Internal Hydrants		
	Size of riser/down-corner	N/A	N/A
	Number of Hydrants per floor	N/A	N/A
	hose Box	N/A	N/A
12	Yard Hydrants.		
	total number of hydrants	N/A	N/A
	hose box	N/A	N/A
13	Pumping arrangements		
	1. Ground level	N/A	N/A
	a. Discharge of main Pump	N/A	N/A
	b. Head of main pump	N/A	N/A
	c. Number of main pumps	N/A	N/A
	d. jockey pump out put	N/A	N/A
	e. jockey pump head	N/A	N/A
	f. Standby Pump output	N/A	N/A
	g. Stanby Pump head	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A
	pump house access	N/A	N/A
	2. Terrace level		
	a. Discharge of pump	N/A	450LPM
	b. head of the pump	N/A	30m
	c. Power supply	N/A	Provided
	d. Auto starting of pump	N/A	N/A
14	Captive water storage for fire fighting		
	1. Underground tank capacity	N/A	N/A
	a. Draw-off connection	N/A	N/A
	b. fire service inlet	N/A	N/A
	c. Access to tank	N/A	N/A
	Over head tank Capacity	N/A	2500 Liters
15	Exit Signage.	Required	Provided
16	Provision of lifts.		
	a. Pressurization of lift shaft	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A
	c. communication in lift car	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A
	e. Lift signage	N/A	N/A
17	Standby power supply	N/A	N/A
18	Refuge Area.	Not Required	
	total area	N/A	N/A
	location	N/A	N/A
19	Fire control room		
	a. detector system Panel	N/A	N/A
	b. Flow switch Panel	N/A	N/A
	c. PA system Panel	N/A	N/A
	d. Batter backup	N/A	N/A
	e. Building floor plans	N/A	N/A

n/a

20 Special Fire Protection systems for protection of special risks, if any: N/A

The fire protection systems provided in the building were test checked at random and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under circular of Director of Education dated 01.03.2011, the FSC issued vide letter No: F6/DFS/MS/School/2014/SZ/22, dated 08.01.2014, renewal under rule 37 of the Delhi Fire Service Rule 2010 is recommended.

Accordingly DFA is put up for your approval and signature please.

[Handwritten Signature]
8/1/17

Signature of the inspecting officer

Name: Vedpal

Designation : ADO

~~D.O. (S.D)~~

[Handwritten Signature]
8/1/17

[Handwritten Signature]

709/cf s2
15/3/17-17/3/17

[Handwritten Signature]
14/3

[Handwritten Signature]

m-scell *[Handwritten Signature]*
15/3

