

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

Fax No. 011-23412593, Ph. 011-23412225

No. F6/DFS/MS/EH/2017/SZ/ 401

Dated: 16/03/17

FIRE SAFETY CERTIFICATE

Certified that M/s Mughal Cuisine Foods Pvt. Ltd. located at D-23, 24, Kalindi Kunj Road, Abul Fazal Enclave-I, Jamia Nagar, New Delhi-110025, running at Ground floor (seating capacity of 80 persons) of a building comprised of Basement, Ground + three upper floors was granted FSC by this department vide letter No. F.6/DFS/MS/EH/2013/SZ/1050 dated 09/10/2013. The premises was re-inspected by the officer concerned of this department on 25.02.2017 in the presence of Mr. Rizwan ul Hasan (Director) of the restaurant and observed that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class-D "Assembly Building" (Restaurant) as above with effect from 16/03/17 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 16/03/17 at New Delhi by


(Vipin Kental)
Chief Fire Officer

Copy to: -

1. The Joint C.P. (Lic.), First Floor, PS Defence Colony, New Delhi-110049
2. The DHO (Central Zone), South MCD, Health Deptt, Lajpat Nagar, New Delhi-24
3. The Director, M/s Mughal Cuisine Foods Pvt. Ltd., D-23, 24, Kalindi Kunj Road, Abul Fazal Enclave-I, Jamia Nagar, New Delhi-110025

Conditions for the validity of Fire Safety Certificate

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering the fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drill be conducted at regular interval and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye Laws.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.


INSPECTION REPORT

1	Name & Address of the Building	M/s Mughal Cuisine Foods Pvt. Ltd located at D-23 & 24, Kalindi Kunj Road, Abul Fazal Enclave-I, Jamia Nagar, New Delhi-110025		
2	Type of Occupancy	Assembly Building "Group-D" Restaurant		
3	Building Comprised of	Basement, Ground + three upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/EH/2013/SZ/1050 Dated 09/10/2013		
6	Fire Safety Directives Letter No	DFS Act-2007 & Rules-2010		
7	Date of Inspection	25.02.2017		
8	Name of the Inspecting Officers	ADO R.N. Singh		
9	Name & Designation of Officers from the building side	Mr. Rizwan ul Hasan (Director)		
10	Year of construction	2005	Restt running at Ground Floor of the building	
11	Applicant letter No.	Nil dated 24.01.2017, ODD No. 888 dated 27.01.17		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC 09/10/2013 Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Required	9 mtr	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, width, type & arrangement of exits			
	a. Number of Staircase			
	• Upper floors	N/A	N/A	N/A
	• Basement floor	Two	Two	MR
	b. Width of Staircase			
	• Upper floors	N/A	N/A	N/A
	• Basement floor	1.5 mtr	2.10 mtr × 2	MR
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	N/A	N/A	N/A
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	Required	2.0 mtr & 1.5 mtr (Final Exit)	MR
3	Compartmentation.			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4.	Smoke Management system.			
	• Basement	Required	Exhaust fans provided	MR
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers.			
	• Total numbers	ISI marked	12 No's	MR
	• Types		ABC-09, Co2-03	MR
	• ISI Marking		Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	Hose-reel	02 provided in Restt.	MR
	• Length of hose-reel hose.		30 m	MR
	• Nozzle Diameter		05 mm	MR

Renewal

Mughal Cuisine Foods Pvt. Ltd, Abul Fazal Enclave-I, Jamia Nagar, New Delhi-25


7	Automatic fire detection & alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Upper floors	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants.			
	• Size of Riser/Down-comer	N/A	N/A	N/A
	• Number of Hydrant per floor	N/A	N/A	N/A
	• Hose box.	N/A	N/A	N/A
12.	Yard Hydrants.			
	• Total number of hydrants.	N/A	01 provided	N/A
	• 2. Hose box.	N/A	01 provided	N/A
13.	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	N/A	N/A	N/A
	➤ Head of main pump.	N/A	N/A	N/A
	➤ Number of main pumps.	N/A	N/A	N/A
	➤ Jockey Pump output.	N/A	N/A	N/A
	➤ Jockey Pump head.	N/A	N/A	N/A
	➤ Standby Pump output.	N/A	N/A	N/A
	➤ Standby Pump head.	N/A	N/A	N/A
	➤ Auto Starting / Manual Stopping.	N/A	N/A	N/A
	➤ Access to pump house	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump.	Required	900 LPM	MR
	➤ Head of pump.	Required	40 mtr	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	Captive water storage for Fire Fighting.			
	• Underground tank capacity.	N/A	N/A	N/A
	➤ Draw-off connection.	N/A	N/A	N/A
	➤ Fire Service Inlet.	N/A	N/A	N/A
	➤ Access to tank.	N/A	N/A	N/A
	• Overhead tank capacity.	Required	10,000 Ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of lift shaft.	N/A	N/A	N/A
	• Pressurization of lift lobby.	N/A	N/A	N/A
	• Communication in lift car.	N/A	N/A	N/A
	• Fireman's switch.	N/A	N/A	N/A
	• Lift signage.	N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A

19.	Fire Control Room.	N/A		N/A
	• Detector System Panel.	N/A		N/A
	• Flow Switch Panel.	N/A		N/A
	• PA system Panel.	N/A		N/A
	• Battery backup	N/A		N/A
	• Building floor plan	N/A		N/A
20.	Special Fire Protection System for the Protection of special Risk, if any :	Required	01 Co2 type fire extinguisher provided near electrical panel	MR
<p>The Fire protection systems provided in the building were test checked and found functional at the time of inspection.</p> <p>Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F.6/DFS/MS/EH/2013/SZ/1050 Dated 09/10/2013, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.</p> <p>Accordingly, DFA is put up for approval and signature please.</p> <div style="text-align: right;">  Signature of the Inspecting Officer Name : R.N. Singh Designation: ADO </div>				

Renewal

Mughal Cuisine Foods Pvt. Ltd, Abul Fazal Enclave-I, Jamia Nagar, New Delhi-25

Div. Officer (SD)


6/3/17

Dy. Cfo (S2) / on MR


685/CF S2
9/3/15/12

CFOS2
miscell 9/3

F.T letter is put up for sign plz

CFOS2

M. SCEL 14/3


10/3