

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001  
Fax No. 011-23412593, Ph. 011-23412225

No. F6/DFS/MS/School/2017/SZ/ 403

Dated: 16/03/17

**FIRE SAFETY CERTIFICATE**

Certified that the **Panchsheel Public School, H-Block, Saurabh Vihar, Jaitpur, Near Gurudwara, Badarpur, New Delhi**, comprised of **Ground + 02 upper floors** Owned/Occupied by Panchsheel Public school was granted FSC by this department vide letter No. F6/DFS/MS/School/2013/208 dated 11/01/2013. The premises was re-inspected by officer concerned of this department on 16/02/2017 in the presence of Mr. Girish Vohra (Manager) of the school and found that school have deemed complied with the fire prevention and fire safety arrangements in accordance with circular No. 262-362 dated 17.01.2005 issued by Director of Education, Govt. of NCT of Delhi and the building/premises is fit for occupancy class "**Educational Building Group-B**" as above with effect from 16/03/17 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the condition under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 16/03/17 at New Delhi by

16/3  
(Vipin Kental)  
Chief Fire Officer

**Copy to: -**

1. The Principal, Panchsheel Public School,  
H-Block, Saurabh Vihar, Jaitpur, Badarpur, New Delhi-110044
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering the fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drill be conducted at regular interval and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye Laws.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).



INSPECTION REPORT				
1	Name & Address of the Building	Panchsheel Public School, H-Block, Saurabh Vihar, Jaitpur near Gurudwara, Badarpur, New Delhi-44		
2	Type of Occupancy	Educational Building "Group-B" (School)		
3	Building Comprised of	Ground plus two upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/School/2013/208 Dated 11/01/2013		
6	Fire Safety Directives Letter No	DOE Circular dated 17.01.2005		
7	Date of Inspection	16.02.2017		
8	Name of the Inspecting Officers	ADO R.N. Singh		
9	Name & Designation of Officers from the building side	Mr. Girish Vohra (Manager)		
10	Year of construction			
11	Applicant letter No.	Nil dated 10/01/2017 ODD No. 709 dt 20/01/2017		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	DOE Circular Dt 17/01/2005	Provided at Site	Remarks MR/NMR
1	<b>Access to Building.</b>			
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	<ul style="list-style-type: none"> <li>Accessible</li> <li>NA</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>5 mtr</li> <li>5 mtr</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>MR (old case)</li> <li>NA</li> <li>NA</li> </ul>
2	<b>Number, width, type and arrangements of exits.</b>			
	<b>a) Number of Staircase</b>			
	> Upper floors	2 No's	3 No's	MR
	> Basement floor	NA	NA	NA
	<b>b) Width of Staircase</b>			
	> Upper floors	1.5 m / 0.75 m	1.8 mtr each	MR
	> Basement floor	NA	NA	NA
	<b>c) Protection of exits</b>			
	> Fire check door	NA	NA	NA
	> Pressurization	NA	NA	NA
	<b>d) No. of continuous staircase to terrace</b>	One	Three	MR
	<b>e) Width of corridor</b>	NA	NA	NA
	<b>f) Door size</b>	1 m	1 m	MR
3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>Fire check door.</li> <li>Sealing of electrical shafts.</li> <li>Fire rating of shaft door.</li> <li>Water curtain</li> <li>Fire dampers.</li> </ul>	<ul style="list-style-type: none"> <li>NA</li> <li>NA</li> <li>NA</li> <li>NA</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>NA</li> <li>NA</li> <li>NA</li> <li>NA</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>NA</li> <li>NA</li> <li>NA</li> <li>NA</li> <li>NA</li> </ul>
4.	<b>Smoke Management system.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper floors</li> </ul>	<ul style="list-style-type: none"> <li>NA</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>NA</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>NA</li> <li>NA</li> </ul>
5.	<b>Fire Extinguishers.</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>ISI Marking</li> </ul>	ISI marked	<ul style="list-style-type: none"> <li>12 No's</li> <li>ABC-08, Co2-04 No</li> <li>Yes</li> </ul>	<ul style="list-style-type: none"> <li>MR</li> <li>MR</li> <li>MR</li> </ul>
6.	<b>First Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor.</li> <li>Length of hose-reel hose.</li> <li>Nozzle Diameter</li> </ul>	<ul style="list-style-type: none"> <li>02 No's</li> <li>30m</li> <li>5mm</li> </ul>	<ul style="list-style-type: none"> <li>02 No's</li> <li>30 mtr</li> <li>05 mm</li> </ul>	<ul style="list-style-type: none"> <li>MR</li> <li>MR</li> <li>MR</li> </ul>

Renewal


Panchsheel Public School, H-Block, Saurabh Vihar, Jaitpur, Badarpur

f2.



7	<b>Automatic Fire Detection and Alarming system.</b>			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooter's location	NA	NA	NA
8.	<b>MOEFA</b>	NA	NA	NA
9.	<b>Public Address System</b>	NA	NA	NA
10.	<b>Automatic Sprinkler System</b>			
	• Basement	NA	NA	NA
	• Upper floors	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	<b>Internal Hydrants.</b>			
	• Size of Riser/Down-comer	NA	100 mm	NA
	• Number of Hydrant per floor	NA	Two	NA
	• Hose box.	NA	Two	NA
12.	<b>Yard Hydrants.</b>			
	• Total number of hydrants.	NA	NA	NA
	• Hose box.	NA	NA	NA
13.	<b>Pumping arrangements.</b>			
	<b>a) Ground Level</b>			
	➤ Discharge of main pump.	NA	NA	NA
	➤ Head of main pump.	NA	NA	NA
	➤ Number of main pumps.	NA	NA	NA
	➤ Jockey Pump output.	NA	NA	NA
	➤ Jockey Pump head.	NA	NA	NA
	➤ Standby Pump output.	NA	NA	NA
	➤ Standby Pump head.	NA	NA	NA
	➤ Auto Starting/Manual Stopping.	NA	NA	NA
	<b>b) Terrace Level</b>			
	➤ Discharge of pump.	450 LPM	450 LPM	MR
	➤ Head of pump.	40 mtr	40 mtr	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	<b>Captive water storage for Fire Fighting.</b>			
	• Underground tank capacity.	NA	NA	NA
	• Draw-off connection.	NA	NA	NA
	• Fire Service Inlet.	NA	NA	NA
	• Access to tank.	NA	NA	NA
	• Overhead tank capacity.	5,000 Ltr	5,000 Ltr	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	• Pressurization of lift shaft.	NA	NA	NA
	• Pressurization of lift lobby.	NA	NA	NA
	• Communication in lift car.	NA	NA	NA
	• Fireman's switch.	NA	NA	NA
	• Lift signage.	NA	NA	NA
17	<b>Standby Power Supply</b>	NA	NA	NA
18.	<b>Refuge Area</b>			
	• Total area	NA	NA	NA
	• Location	NA	NA	NA



19.	<b>Fire Control Room.</b>				
		• Detector System Panel.	NA	NA	NA
		• Flow Switch Panel.	NA	NA	NA
		• PA system Panel.	NA	NA	NA
		• Battery backup	NA	NA	NA
	• Building floor plan	NA	NA	NA	
20.	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>			NA	
<p>The Fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection. The shortcomings communicated vide letter No. F.6/DFS/MS/School/2016/1897 dated 04/08/2016 has been complied. ✓</p> <p>Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the circular of Directorate of Education dated 17/01/2005, FSC issued vide letter No. F6/DFS/MS/School/2013/SZ/208 dated 11/01/2013, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.</p> <p>Accordingly DFA is put up for approval and signature please.</p> <div style="text-align: right;">                   Signature of the Inspecting Officer                  Name: R.N. Singh                  Designation: ADO             </div>					

Renewal

Panchsheel Public School, H-Block, Saurabh Vihar, Jaitpur, Badarpur

Div. Officer (SD)

*[Signature]*  
28/12/17

*[Signature]*

680/cfse  
23/12/17

*[Signature]*  
1/3



Cfo & M. S. K. FTM.  
7/3