

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/School/2017/WZ/ 428

Dated: 21/03/2017

FIRE SAFETY CERTIFICATE

Certified that the **S.D.M.C. Primary Co-Ed School**, Located at **Punjabi Bagh Extn, New Delhi-110026**, comprised of **Ground + 01 Upper Floors** only was issued FSC vide Letter No. F6/DFS/MS/School/2014/WZ/252 Dated-21/02/2014. The premises was re inspected by the officer concerned of this department on 02-03-2017 in the presence of **Mr. Amit Kumar Choudary (Incharg)** All the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance DOE 3298-3398 dated 1-3-2011 and that the premises is fit for occupancy class "Educational" Group B with effect from 21/03/17 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 21/03/17 at New Delhi by.


(Atul Garg)

Chief Fire Officer,
Delhi Fire Service.

21/03/17

Copy to:

1. **The Principal,
S.D.M.C. Primary Co-Ed School, Punjabi Bagh Extn, New Delhi-110026.**

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

2. Name & address of the building : **Punjabi Bagh Extn, New Delhi-110026.**
3. Type of Occupancy : Educational (Ground +1 Upper Floor)
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/School/2014/WZ/252 Dated-21/02/2014
6. Fire Safety directives Letter No. : DOE 3298-3398 dated 1-3-11
7. Date of inspection : 02/03/2017
8. Name of the Inspecting Officer : Udai vir Singh, ADO (WP)
9. Name and designation of Officer
from the building side : Mr. Amit Kumar Choudary (Incharg)
10. Year of Construction : 2010
11. Applicant's letter No. : Nil Dated- 09-02-2017

No. of Students=550
No. of class rooms=16
Plot area= 8903.455sqm
Covered area=563.015 Sqm

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE 3298-3398 dated 1-3-11	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 mtr	7m Provided	MR
	• Gate width	Accessible	367cm Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	NA	2	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5	1x150cm&1x122cm Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	1.5m	185cm Provided	MR
	f. Door Size	1 mtr	2x113cm Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	5 nos.	5 Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First - Aid Hose Reels			
	• Total numbers on each	NR	NR	NA

7. Automatic fire detection and alarming system				
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location			
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage	NA	NA	NA
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift car	NA	NA	NA
	➤ Fireman's Emergency Switch	NA	NA	NA
	➤ Exit Signage	NA	NA	NA

S.D.M.C. Primary Co-Ed School, Punjabi Bagh Extn, New Delhi-110026.

19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide Letter No.

F6/DFS/MS/School/2014/WZ/252 Dated-21/02/2014 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer
 Name *Uday Kumar Singh*
 Designation *ADD/WP*

Signature of the Inspecting Officer
 Name
 Designation

Dofw

Uday Kumar Singh 8/3/17

[Signature] 10/3/17

Dy. (WZ)

CFO West / [Signature] 15/3/17

*FTA/s
ADD/WP*

Sir AT letter is put up for safe plr

CFO / [Signature] 21/3/17

[Signature]