

No.F.6/DFS/MS/ *School/21/03/2017*

Dated: *21/03/2017*

FIRE SAFETY CERTIFICATE

Certified that the Adarsh Public School located at F-75,76, Bali Nagar, New Delhi-15 comprised of Ground + Three upper floors only owned /Occupied by Adarsh Public School, was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2013/WZ/689 dated 08/08/2013. The premises was re-inspected by the officer concerned of Fire Service on 08.03.2017 in the presence of Smt. Neha Sehgal (Teacher) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with DOE Cir. 3298-3398 dated 01/03/2011 / NBC (Part-IV), and that the building / premises is fit for occupancy class Educational (Group-B) with effect from *21/03/2017* for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on *21/03/17* at New Delhi by.

*Atul Garg*  
*20/3/17*  
(ATUL GARG)  
CHIEF FIRE OFFICER.

Copy to :-

1. Principal, Adarsh Public School, F-Block, Bali Nagar, New Delhi-15. *AM o/c*

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)



1. Name & address of the building: Adarsh Public School, F-75,76, Bali Nagar, New Delhi-15
2. Type of Occupancy : Educational (G+3)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2013/WZ/687 dated 08/08/2013
5. Fire Safety directives Letter No. : DOE Circular 3298-3398 dated 01.03.2011
6. Date of inspection : 08/03/2017
7. Name of the Inspecting Officer : A. K. Jaiswal
8. Name and designation of Officer  
from the building side : Smt. Neha Sehgal (Teacher)
9. Year of Construction : 1980
10. Applicant's letter No. : APS/BN/3011 dated 17/02/2017

Plot Area-470.72 m <sup>2</sup>
Covered Area-389.60 m <sup>2</sup>
No. of Rooms 23

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE Cir.1.3.11 Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	1	2	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.50 mtr	1.25 mtr x 1 0.75 mtr x 1	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	2	2	MR
	e. Width Of Corridor	1.50 mtr	No Corridor	MR
	f. Door Size	1.00 mtr	1.00 mtr	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers			
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	6	12	MR
	• Types	ISI marked ABC/CO <sub>2</sub>	Provided	MR
			Provided	MR



6.	First – Aid Hose Reels			
	• Total numbers on each floor	1	1	MR
	• Length of hose reel hose	30 Mtr.	30 Mtr.	MR
	• Nozzle diameter	5 mm	5 mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor (M.P. Hall stage)	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	NR	100 mm	NR
	• Number of hydrants per floor	NR	1	NR
	• Hose Box	NR	1	NR
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level	N/A		
	• Discharge of main pump	N/A	N/A	
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 Lit/Mint.	450 Lit/Mint	MR
	➤ Head of the pump	40 Mtr. Head	40 mtr. Head	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Under Ground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire hydrant	N/A	N/A	N/A

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	Provided	N/A
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

Note:- General requirements mentioned in the schools as per Director of Education circular dated 1/03/2011.

1. Escape route ..... Clear.....
2. LPG cylinders in laboratories ..... Nil.....
3. Electric wiring ...Conduit Wiring..... MCB and ELCB Provided.....  
Electric circuit .....
4. Electric meter board .....Not under the staircase.....
5. Basement use as per BBL 1983 .....NA.....
6. Emergency telephone no. board .....Displayed.....
7. Generator set ..... Nil.....

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/School/2013/WZ/687 dated 08/08/2013 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

D.O/A(w)  
*[Handwritten signature]* 9/3/12  
*[Handwritten signature]* 14/3/17  
 CTO West  
*[Handwritten signature]* 14/3/17  
 F.I.P.F.

*[Handwritten signature]* 8/3/17  
 Signature of the Inspecting Officer  
 Name : Ashok Kumar Jaiswal  
 Designation : A.D.O. (Jwala Puri)