

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

Fax No. 011-23412593, Ph. 011-23412225

No. F6/DFS/MS/EH/2017/SZ/ 432

Dated: 22/3/17

FIRE SAFETY CERTIFICATE

Certified that M/s Hype (A Unit of First Face Entertainment P. Ltd.) located at ground floor of S-1, Hotel Intercontinental Eros, Nehru Place, New Delhi, was inspected by the officer concerned of this department on 03.03.2017 in the presence of Mr. A.K. Sharma (Manager) of the restaurant and observed that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class-D "Assembly-Discotheque" as above with effect from 22/3/17 for a period of Three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 22/3/17 at New Delhi by


(Vipin Kantal)
Chief Fire Officer

Copy to: -

1. The Joint C.P. (Lic.), First Floor, PS Defence Colony, New Delhi-110049
2. The DHO (Central Zone), South MCD, Health Deptt, Lajpat Nagar, New Delhi-24
3. The Director, M/s Hype (A Unit of First Face Entertainment P. Ltd.),
S-1, GF, Hotel International Eros, Nehru Place, New Delhi-110019

Conditions for the validity of Fire Safety Certificate

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering the fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drill be conducted at regular interval and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye Laws.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT				
1	Name & Address of the Building	Hype (A Unit of First Face Entertainment P Ltd) located at S-1, GF, Hotel Intercontinental Eros, Nehru Place, New Delhi		
2	Type of Occupancy	Assembly Building "Group-D" Restaurant		
3	Building Comprised of	Two tier basement, ground + 15 upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/2014/SZ/72 Dated 17/01/2014		
6	Fire Safety Directives Letter No	N/A		
7	Date of Inspection	03.03.2017		
8	Name of the Inspecting Officers	ADO R.N. Singh		
9	Name & Designation of Officers from the building side	Mr. A.K. Sharma (Manager)		
10	Year of construction	1994 Restt running at Ground Floor of the building		
11	Applicant letter No.	Nil dated Nil, ODD No. 1341 dated 07.01.2017		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC 15/11/2010 Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.	F.6/DFS/MS/Hotel/2015/SZ/1587 dated 02/09/2015		
	• Road width	Required	9 mtr	MR
	• Gate width	Required	6 mtr	MR
	• Width of internal road	Required	6 mtr	MR
2	Number, width, type & arrangement of exits			
	a. Number of Staircase	Provided & Maintained by Hotel		
	• Upper floors	Located at GF	N/A	N/A
	• Basement floor	N/A	N/A	N/A
	b. Width of Staircase	Provided & Maintained by Hotel		
	• Upper floors	Located at GF	N/A	N/A
	• Basement floor	N/A	N/A	N/A
	c. Protection of exits	Provided & Maintained by Hotel		
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	N/A	N/A	N/A
	e. Width of corridor	N/A	2.0 mtr	N/A
	f. Door size	Required	2.0 mtr & 1.10 mtr (Final Exit)	MR
3	Compartmentation.	Provided & Maintained by Hotel		
	• Fire check door.	N/A	Provided by Hotel International Eros	N/A
	• Sealing of electrical shafts.	N/A	As above	N/A
	• Fire rating of shaft door.	N/A	As above	N/A
	• Water curtain	N/A	As above	N/A
	• Fire dampers.	N/A	As above	N/A
4.	Smoke Management system.	Provided & Maintained by Hotel		
	• Basement	N/A	As above	N/A
	• Upper floors	N/A	As above	N/A
5.	Fire Extinguishers.			
	• Total numbers	ISI marked	06 No's	MR
	• Types		ABC-04, Co2-02	MR
	• ISI Marking		Provided	MR
6.	First Aid Hose Reels.	Provided & Maintained by Hotel		
	• Total numbers on each floor.	Hose-reel	02 provided in Restt.	MR
	• Length of hose-reel hose.		30 m	MR
	• Nozzle Diameter		05 mm	MR

Renewal

Hype Restt at S-1, Hotel Intercontinental Eros, Nehru Place, ND

7	Automatic fire detection & alarming system	Provided & Maintained by Hotel		
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System	Provided & Maintained by Hotel		
	• Basement	N/A	As above	N/A
	• Upper floors	N/A	As above	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants.	Provided & Maintained by Hotel		
	• Size of Riser/Down-comer	N/A	As above	N/A
	• Number of Hydrant per floor	N/A	As above	N/A
	• Hose box.	N/A	As above	N/A
12.	Yard Hydrants.	Provided & Maintained by Hotel		
	• Total number of hydrants.	N/A	As above	N/A
	• 2. Hose box.	N/A	As above	N/A
13.	Pumping arrangements.	Provided & Maintained by Hotel		
	• Ground Level	Provided & Maintained by Hotel		
	➤ Discharge of main pump.	N/A	As above	N/A
	➤ Head of main pump.	N/A	As above	N/A
	➤ Number of main pumps.	N/A	As above	N/A
	➤ Jockey Pump output.	N/A	As above	N/A
	➤ Jockey Pump head.	N/A	As above	N/A
	➤ Standby Pump output.	N/A	As above	N/A
	➤ Standby Pump head.	N/A	As above	N/A
	➤ Auto Starting / Manual Stopping.	N/A	As above	N/A
	➤ Access to pump house	N/A	As above	N/A
	• Terrace Level	Provided & Maintained by Hotel		
	➤ Discharge of pump.	450 LPM	450 LPM	MR
	➤ Head of pump.	80 mtr	80 mtr	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	Captive water storage for Fire Fighting.	Provided & Maintained by Hotel		
	• Underground tank capacity.	N/A	As above	N/A
	➤ Draw-off connection.	N/A	As above	N/A
	➤ Fire Service Inlet.	N/A	As above	N/A
	➤ Access to tank.	N/A	As above	N/A
	• Overhead tank capacity.	Required	As above	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.	Provided & Maintained by Hotel		
	• Pressurization of lift shaft.	N/A	As above	N/A
	• Pressurization of lift lobby.	N/A	As above	N/A
	• Communication in lift car.	N/A	As above	N/A
	• Fireman's switch.	N/A	As above	N/A
	• Lift signage.	N/A	As above	N/A
17	Standby Power Supply	Required	Provided	MR
18.	Refuge Area	Provided & Maintained by Hotel		
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A

Renewal

Hype Restt at S-1, Hotel Intercontinental Eros, Nehru Place, ND

19.	Fire Control Room.	Provided & Maintained by Hotel		
	<ul style="list-style-type: none"> • Detector System Panel. • Flow Switch Panel. • PA system Panel. • Battery backup • Building floor plan 	N/A	As above	N/A
		N/A	As above	N/A
		N/A	As above	N/A
		N/A	As above	N/A
		N/A	As above	N/A
20.	Special Fire Protection System for the Protection of special Risk, if any :	Required	01 Co2 type fire extinguisher provided near electrical panel	MR

Previously the restaurant was granted FSC in the name of Third Eye Discotheque (A Unit of Ratna Vacations (P) Ltd.) by this department vide letter dated 17/01/2014 and NOC for change in name of restaurant from Third Eye Discotheque (A Unit of Ratna Vacations (P) Ltd.) to Hype (A Unit of First Face Entertainment Pvt. Ltd) was granted by this department vide letter No. F.6/DFS/MS/EH/SZ/2016/2667 dated 11/11/2016.

The Fire protection systems provided in the building were checked randomly and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F.6/DFS/MS/2014/SZ/72 Dated 17/01/2014, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

R.N. Singh
03/3/17

Signature of the Inspecting Officer
Name : R.N. Singh
Designation: ADO

Renewal

Hype Restt at S-1, Hotel Intercontinental Eros, Nehru Place, ND

Div. Officer (SD)

FSC of Eros is placed at 9/24.

Dy. CPO (S2) / an M/R

Anilash
7/3/17

CFO (S2P)

*The letter has to come through concerned dept.
Pl write letter accordingly*

*683/CFO S2
9/2.15/3/17*

DFO SZ.
out of station

U
9/3

Sir
Under sub rule (1) of rule 37 applicant may apply directly for Renewal. Kindly reconsider.

Dy. CPO (S2) / CFO (I2)

Anilash
10/3/17
DFO SZ

Pl speak
U
14/3

NFO SZ

