

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001



NO. F6/DFS/MS/School/2017/SZ/ 418

Dated: 20/03/17

FIRE SAFETY CERTIFICATE

Certified that the Fun Valley School located at RZ-H-921, Gali No. 14 Raj Nagar-II, Palam Colony, New Delhi, having two blocks comprised of ground and ground plus one upper floor have already been issued Fire Safety Certificate vide this department letter no. DFS/MS/School/2014/SW/79 dated 20.01.2014. The premises was re-inspected by the officer concerned of this department on 10.02.2017 in the presence of Smt. Manju (Principal) and found that the premises have deemed complied with fire prevention & fire safety requirements in accordance with Directorate of Education GNCT of Delhi Circular No: F/16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 and that the premises/Building is fit for occupancy class B "Educational Building" with effect from 20/03/17 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on 20/03/17 at New Delhi by


(Vipin Kental)
Chief Fire Officer


Copy to:

- 1 Deputy Director (Education) GNCT of Delhi, Old Secretariat, Delhi-110054.
- 2 Manager, Fun Valley School located at RZ-H-921, Gali No. 14 RajNagar-II, Palam Colony, New Delhi

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	The Fun Valley School, RZ-H-921, Gali No. 14, Raj Nagar-II, Palam Colony, New Delhi.		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	Renewal (Ground plus One upper floor)		
4	Details of previous NOC	F6/DFS/MS/School/2014/SW/79 Dated 20.1.2014		
5	Fire safety directives letter No	Directorate Of Education Circular. No. F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011.		
6	Date of inspection	10.2.2017		
7	Name of the inspecting Officers	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Mrs. Manju (Principal)		
9	Year of construction	2009		
10	Applicant's letter No.	Nil 20.1.2017	(Ground plus One upper floor.)	

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	D.O.E letter dated 1.3.2011	Provided at site	Remarks MR / NMR
--------	---	-----------------------------	------------------	------------------

1	Access to building			
	1) Road width	6 Mtrs.	6 Mtrs.	MR
	2) Gate width	4.5 Mtrs.	Direct Accessible from road	MR
	3) Width of internal road	N/A	N/A	N/A

2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	One	One	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.5 Mtr.	1.5 Meter.	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	N/A	N/A	N/A
	e. Width of corridor	N/A	1.25 Mtrs.	N/A
	f. Door size	1 Mtr.	1 Mtr.	MR

3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A

4	Smoke Management system.			
	basement		N/A	N/A
	upper floors	N/A	N/A	N/A

5	Fire Extinguishers			
	total numbers	1 Co2 OR ABC for every 300 Sq. Mtrs.	4 Nos.	MR
	Types	ISI Marked	ABC	MR
	ISI marking	ISI Marked	ISI Marked	MR

6	First-Aid Hose Reels.			
	total numbers on each floor	N/A	N/A	N/A
	Length of Hose reel hose	N/A	N/A	N/A
	Nozzle Diameter	N/A	N/A	N/A
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	N/A	N/A	N/A
	b. head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	N/A	N/A	N/A
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	N/A	N/A	N/A
15	Exit Signage.	N/A	N/A	N/A
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: ABC Fire exting. MR			
	Provided near electric meter.			

Fire protection systems provided in the building were checked and found functional at the time of inspection .
 keeping in view deemed compliance of the minimum standards on fire prevention and fire safety required as per D O E letter dated 1.3.2011, renewal of FSC issued vide letter no. F6/DFS/MS/School/2014/SW/79 dated 20.01.2014 is recommended.


Accordingly DFA is put up for your approval and signature please.

Sury 13/2/17
 Signature of the Inspecting Officer

Name S.P. Bhardwaj

Designation ADO (Dwarka)

86/DOCSW
 13/02/17
 23/02/17


~~DO(SW)~~ 

Where is the Conditions in FSC?

~~ADO(DWR)~~

Sir, Conditions have been printed hence DFA may please be signed.

625/CFOS2
 28/2/17/17/3

~~DO/SW~~  22/2/17

Sury
 16/2/17

~~DCFO(SZ)~~

Kanp

