

FORM- H]  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI


No. F6/DFS/MS/SCHOOL/2017/ 512

Dated: 05/04/2017

**FIRE SAFETY CERTIFICATE**

Certified that the **Govt. Girls Sr. Secondary School**, Located at, **A-Block, Saraswati Vihar, Delhi – 110034**. comprised of Five Blocks ( Four Blocks Ground floor Only & One Block Ground + 1 Upper Floor Only) was issued FSC vide Letter No. F6/DFS/MS/School/2011/3023 Dated-16/11/2011, The premises was re inspected by the officer concerned of this department on **08-03-2017** in the presence of **Mss. Sunita Sharma (Principal)** and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance DOE Circular 3298-3398 Dated 01/03/2011 and that the premises is fit for occupancy class "Educational" Group B with effect from 05/04/17 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ....05/04/17... at New Delhi by.

  
(Atul Garg)  
Chief Fire Officer  
Delhi Fire Service

Copy to:

**The Principal,**  
**Govt. Girls Sr. Secondary School, A-Block, Saraswati Vihar, Delhi – 110034.**

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

**INSPECTION REPORT**

1. Name & address of the building: **Govt. Girls Sr. Secondary School**, Located at, **A-Block, Saraswati Vihar, Delhi – 110034.**
2. Type of Occupancy : Educational Five Block ( Four Block Ground floor Only & One Block Ground + 1 Upper Floor Only)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2011/3023 Dated- 16/11/11
5. Fire Safety directives Letter No. : DOE 3298-3398 dated 01-03-2011
6. Date of inspection : 08-03-2017
7. Name of the Inspecting Officer :Udai vir singh, ADO (WP)
8. Name and designation of Officer  
from the building side :Mss. Sunita Sharma (Principal)
9. Year of Construction : 1983
10. Applicant's letter No. :GGSSS/811 dated-14/02/2017

No. of Students=734
No. of class rooms=4
Plot area=8424 sqm
Covered area=3601

S No	Minimum standards on fire prevention and fire safety U/R 33	Cr.No.3298-3398 dated 1-3-11	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	<ul style="list-style-type: none"> <li>Accessible</li> <li>Accessible</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>8m Provided</li> <li>620cm Provided</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>MR</li> <li>MR</li> <li>NA</li> </ul>
2.	Number, width, Type & Arrangements of exits			
	<ul style="list-style-type: none"> <li>a. Number of staircases</li> <li>• Upper floors</li> <li>• Basements</li> <li>b. Width of staircases</li> <li>• Upper floors</li> <li>• Basements</li> <li>c. Protection of exits</li> <li>• Fire check door</li> <li>• Pressurization</li> <li>d. No of continuous staircase to terrace</li> <li>e. Width Of Corridor</li> <li>f. Door Size</li> </ul>	<ul style="list-style-type: none"> <li>2</li> <li>NA</li> <li>1.5 mtrs</li> <li>NA</li> <li>NA</li> <li>NA</li> <li>NA</li> <li>NA</li> <li>1</li> <li>1.5m</li> <li>1 mtr</li> </ul>	<ul style="list-style-type: none"> <li>03 Provided(In 5<sup>th</sup>Bl)</li> <li>NA</li> <li>1x1.43m,1x1.75m &amp;1x1.8m</li> <li>NA</li> <li>NA</li> <li>NA</li> <li>NA</li> <li>NA</li> <li>Provided</li> <li>180cm</li> <li>Provided 2x107cm</li> </ul>	<ul style="list-style-type: none"> <li>MR</li> <li>NA</li> <li>MR</li> <li>NA</li> <li>MR</li> <li>MR</li> <li>MR</li> <li>MR</li> <li>MR</li> <li>MR</li> </ul>
3.	Compartmentation			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	<ul style="list-style-type: none"> <li>NA</li> <li>NA</li> <li>NA</li> <li>NA</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>NA</li> <li>NA</li> <li>NA</li> <li>NA</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>NA</li> <li>NA</li> <li>NA</li> <li>NA</li> <li>NA</li> </ul>
4.	Smoke managements System			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	<ul style="list-style-type: none"> <li>NA</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>NA</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>NA</li> <li>NA</li> </ul>
5.	Fire Extinguishers			







20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
-----	--------------------------------------------------------------------------	----	----	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/School/2011/3023 Dated-16/11/11 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

~~Signature~~  
Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name Vidya Vir Singh

Name


Designation ADD/WP

Designation

~~ADD/WP~~ 16/11/12  
~~ADD/WP~~ 22/11/12  
~~ADD/WP~~ 20/11/11

AT RIS

ADD/WP

Sir AT letter is put up for signature  


~~ADD/WP~~ 20/11/11

MM