

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No: F.6/DFS/MS/SCHOOL/2017/ 513

Dated: 05/04/2017

FIRE SAFETY CERTIFICATE

Certified that the building of **Kendriya Vidyalaya**, located at **Tagore Garden, New Delhi – 110027** comprised of **ground plus two upper floors**, was issued FSC vide Letter No:- F6/DFS/MS/SCHOOL/2013/WZ/1348, Dated-27/12/2013, The premises was re inspected by the officer concerned of this department on **09-03-2017** in the presence of **Ms. Jai Laxmi (Principal)** and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance with the Circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 and that the premises is fit for occupancy class "Educational" Group B with effect from 05/04/17 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on05/04/17..... at New Delhi by.

(Atul Garg)
Chief Fire Officer
Delhi Fire Service.

Copy to:-

1. The Principal,
Kendriya Vidyalaya, Tagore Garden, New Delhi - 110027.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per building bye laws.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building : **Kendriya Vidyalaya**, located at **Tagore Garden, New Delhi – 110027.**
2. Type of Occupancy : Educational (Ground + 2 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/SCHOOL/2013/WZ/1348, Dated-27/12/2013
5. SFire Safety directives Letter No. : DOE 3298-3398 dated 01/03/11
6. Date of inspection : 09-03-2017
7. Name of the Inspecting Officer : Udaivir Singh, ADO (WP)
8. Name and designation of Officer
from the building side : Ms. Jai Laxmi (Principal)
9. Year of Construction : 1969
10. Applicant's letter No. :KVTG/2017/1006 Dated 20-02-2017

Total area = 32172 Sqm
Covered area = 5856Sq
Class rooms = 60
No. of students = 2528

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE 3298-3398 dated 01/03/11	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<ul style="list-style-type: none"> Accessible Accessible NA 	<ul style="list-style-type: none"> 12m Provided 05m Provided NA 	<ul style="list-style-type: none"> MR MR NA
2.	Number, width, Type & Arrangements of exits			
	<ul style="list-style-type: none"> a. Number of staircases • Upper floors • Basements b. Width of staircases • Upper floors • Basements c. Protection of exits • Fire check door • Pressurization d. No of continuous staircase to terrace e. Width Of Corridor f. Door Size 	<ul style="list-style-type: none"> 2 NA 2x1.5m (Each Block) NA NA NA NA 1 1.5m 1 mtr 	<ul style="list-style-type: none"> Provided NA Bl A-1x176 to 218cm, 1x150cm & Bl. B-2x145cm NA NA NA NA Provided 235cm Provided Provided 	<ul style="list-style-type: none"> MR NA MR(Old Case) NA NA NA MR MR MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	<ul style="list-style-type: none"> 31 nos. 	<ul style="list-style-type: none"> 45 Provided 	<ul style="list-style-type: none"> MR

4. Details of previous NOC : F6/DFS/MS/SCHOOL/2013/WZ/1348, Dated- 27/12/2013

5. SFire Safety directives Letter No. : DOE 3298-3398 dated 01/03/11

6. Date of inspection : 09-03-2017

7. Name of the Inspecting Officer : Udaivir Singh, ADO (WP)

8. Name and designation of Officer

from the building side : Ms. Jai Laxmi (Principal)

9. Year of Construction : 1969

10. Applicant's letter No. :KVTG/2017/1006 Dated 20-02-2017

Total area = 32172 Sqm
Covered area = 5856Sq
Class rooms = 60
No. of students = 2528

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE 3298-3398 dated 01/03/11	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	12m Provided	MR
	• Gate width	Accessible	05m Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	2x1.5m (Each Block)	Bl A-1x176 to 218cm, 1x150cm & Bl. B-2x145cm	MR(Old Case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1	Provided	MR
	e. Width Of Corridor	1.5m	235cm Provided	MR
	f. Door Size	1 mtr	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	31 nos.	45 Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	2 on each floor	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR

[Handwritten signature and date]
2/1/17

7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NR	Provided	MR
9.	Public Address System	NR	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NR	Provided Down Comer	MR
	• Number of hydrants per floor	NR	Provided 2 on each floor	MR
	• Hose Box	NR	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head			
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	2x450 lpm	2x900 lpm Provided	MR
	• Terrace level	40Mtr	Provided	MR
	➤ Discharge of pump			
	➤ Head of the pump	Required	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump			
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	2x10,000Ltrs	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA

18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/SCHOOL/2013/WZ/1348, Dated-27/12/2013 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name Uday Vir Singh

Name

Designation AD/WP

Designation

AD/WP
Uday Vir Singh
27/12/17
27/12/17
27/12/17
AD/WP
Uday Vir Singh
27/12/17
AD/WP
Uday Vir Singh
27/12/17

AD/WP
Sir FY letter is up but up for sign
AD/WP
Uday Vir Singh
27/12/17