

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001


No.F6/DFS/MS/CINEMA/2017/ 477

Dated : 30/3/17

FIRE SAFETY CERTIFICATE

Certified that **Abhishek Cineplex** located at **188-89, Chandni Chowk, Delhi-110006**, comprised of **Ground + 02 Upper Floors (ground floor used as commercial)** was granted FSC by this department vide letter No. **F6/DFS/MS/Cinema/2013/184** dated **17/04/13**. the premises was re-inspected by the officer concerned of this department on **12/01/2017** in the presence of **Shri Kausar Siddiqui**, Manager of the cinema hall and found that the said cinema hall have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises/building is fit for occupancy of class **assembly (cinema)** with effect from ~~30/3/17~~ for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. mentioned below.

Issued on 30/03/17 at New Delhi by.

  
(Vipin Kental)  
Chief Fire Officer  
Delhi Fire Service  
011- 23412225

Copy to:

1. The Distt Magistrate, (Central Distt.)  
Daryaganj, New Delhi - 110002
2. The Manager, Abhishek Cineplex, 188-89,  
Chandni Chowk, Delhi-110006

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. The means of escape shall be kept unobstructed / unlocked & remain available for speedy evacuation of occupants in case of an emergency.
3. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director In form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

N/40

INSPECTION REPORT

1. Name & address of the building:- Abhishek Cineplex, 188-89, Chandni Chowk, Delhi-110006
2. Type of occupancy:- Assembly (GF – commercial use & 02 Upper floors cinema )
3. Type of case:- Renewal
4. Details of previous FSC:- No. F6/DFS/MS/CINEMA/2013/184 dated 17/04/2013.
5. Fire safety directives No.- N/A
6. Date of inspection:- 12/01/17
7. Name of the inspecting officer:- A.D.O. Mehmood
8. Name & designation of officer  
From the building side:- Shri Kausar Siddiqui, Manager
9. Year of construction:- 1978-79
10. Applicant's letter No:- Nil, Dated 13/01/17

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site PSS	Old Case Remarks MR/NMR
1.	Access to Building			
	1) Road width	6 mtr.	40 mtr.	MR
	2) Gate width	-----	Directly accessible from the road	MR
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02 No.	02 No.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.25 mtr.	1.5 mtr. & 90 cms	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace			
		01 No.	01 No.	MR
	E. Width of corridor			
		1.5 mtr	1.5 mtr	MR
	F. Door size			
		1.5 mtr.	1.54 mtr. & 1.97 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A



4/41

	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 ACPH	N/A	N/A
	2) Upper floors	12 ACPH	Provided Exhaust Fan	MR
5.	Fire Extinguishers			
	1) Total numbers	15 Nos.	Provided	MR
	2) Types	ABC & CO2	Provided	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number at each floor	05 Nos.	Provided	MR
	2) Length of hose reel hose	30 mtr.	Provided	MR
	3) Nozzle diameter	5 mm.	Provided	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Required	Provided	MR
	2) Location of main panel	Required	Provided	MR
	3) Location of repeater panel	Required	Provided	MR
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	reception	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	Required	Provided	MR
	2) Number of hydrants per floor	01 at ground floor	Provided	MR
	3) Hose box	01	Provided	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A

13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A

*Handwritten signature*



N/42


	2) Terrace level			
	a) Discharge of pump	450 LPM	Provided	MR
	b) Head of pump	40 mtr.	Provided	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	30000 ltrs.	Provided.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the guest house were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F6/DFS/MS/CINEMA/2013/184 dated 17/04/2013, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended.

DO/CD

16/3/17

  
Mehmood  
Assistant Divisional Officer

By CBO (DDZ)

16/3

14/04/2017  
20/04/2017

M.S. Cell 17/3

CEP