

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No F 6 / DFS / MS / 2017 / *school/w2/491*

Dated: *31 / 3 / 2017*

**FIRE SAFETY CERTIFICATE**

Certified that **Govt. Girls/Boys Sr. Sec. School, D-Block, Sultan Puri, Delhi-86** comprised of 02 blocks- Ground floor and G +01 upper floor owned/occupied by **Govt. Girls/Boys Sr. Sec. School** have complied with the fire prevention and fire safety requirement in accordance with Director of Education vide letter no. 3298-3398 dated 01/03/2011 and verified by the officer concerned of Fire Service on 10.03.2017 in presence of **Smt. Shashi Varun , Principal** and that the building/ premise is fit for occupancy class Group B Educational with effect from ...*31/3/17*..... for a period of three years, subject to compliance of the conditions mentioned below:

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

Issued on ..*31/3/17*..... at New Delhi

  
(Atul Garg)  
Chief Fire Officer  
Ph:-011-23414250

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi – 54
2. The Principal, Govt. Girls/Boys Sr. Sec. School, D-Block, Sultan Puri, Delhi-86.

**INSPECTION REPORT**

1. Name & address of the building : : Govt. Girls/Boys Sr. Sec. School, D-Block, Sultan Puri, Delhi-86.
2. Type of Occupancy : : Educational
3. Type of Case : : New Case (02 blocks, Ground Floor & G + 01 upper floor)
4. Details of previous NOC : : --
5. Fire Safety directives letter No : : Director of Education Circular dated 01.03.2011
6. Date of inspection : : 10/03/2017
7. Name of the Inspecting Officers : : ADO (RN)
8. Name and designation of officers  
from the building side : : Smt. Shashi Varun (Principal)
9. Year of Construction : : 1998/ 2011
10. Applicant's letter No. : : GGSSS/D-BLK/SP/1631 Dated-07.02.2017

Plot Area-4895 sq m Covered Area:1140 sqm No.of Class Room-14 No.of Student- 1043

|                      | Minimum Standards on fire prevention and fire safety U/R 33 | Circular of Director of Education | Provided at site | Remarks MR/NMR |
|----------------------|---|-----------------------------------|------------------|----------------|
| 1                    | <b>Access to building</b>                                   |                                   |                  |                |
|                      | • Road width  | 6m                                | 6m               | MR             |
|                      | • Gate width  | 4.5m                              | 4.5m             | MR             |
|                      | • Width of internal road                                    | NA                                | NA               | NA             |
| 2                    | <b>Number, Width, Type &amp; Arrangement of Exits</b>       |                                   |                  |                |
|                      | a. Number of staircases                                     |                                   |                  |                |
|                      | • Upper Floors  | 01                                | 01               | MR             |
|                      | • Basements   |                                   |                  |                |
|                      | b. Width of staircases                                      |                                   |                  |                |
|                      | • Upper Floors  | 1.50m                             | 1.50m            | MR             |
|                      | • Basements   | NA                                | NA               | NA             |
|                      | c. Protection of exits                                      |                                   |                  |                |
|                      | • Fire check door   | NA                                | NA               | NA             |
|                      | • Pressurization  | NA                                | NA               | NA             |
|                      | d. No. of continuous staircases to terrace                  | NA                                | NA               | NA             |
| e. Width of Corridor | NA  | NA                                | NA               |                |
| f. Door Size         | 01m   | 1 m with double doors             | MR               |                |
| 3                    | <b>Compartmentation.</b>                                    |                                   |                  |                |

|    |   |                 |                    |    |
|----|---|-----------------|--------------------|----|
|    | <ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul> | NA              | NA                 | NA |
|    |   | NA              | NA                 | NA |
|    |   | NA              | NA                 | NA |
|    |   | NA              | NA                 | NA |
|    |   | NA              | NA                 | NA |
| 4  | <b>Smoke Management System.</b>   |                 |                    |    |
|    | <ul style="list-style-type: none"> <li>• Basements</li> </ul>   | 30 a/c per hour | NA                 | NA |
|    | <ul style="list-style-type: none"> <li>• Upper floors</li> </ul>  | 12 a/c per hour | Natural Ventilated | MR |
| 5  | <b>Fire Extinguishers</b>   |                 |                    |    |
|    | <ul style="list-style-type: none"> <li>• Total numbers</li> </ul>   | 08nos           | 10 nos             | MR |
|    | <ul style="list-style-type: none"> <li>• Types</li> </ul>   | ABC/Co2         | ABC—10             | MR |
|    | <ul style="list-style-type: none"> <li>• ISI marking</li> </ul>   | ISI Marked      | Yes                | MR |
| 6  | <b>First-Aid Hose Reels.</b>  |                 |                    |    |
|    | <ul style="list-style-type: none"> <li>• Total numbers on each floor</li> </ul>   | NA              | NA                 | NA |
|    | <ul style="list-style-type: none"> <li>• Length of hose reel hose</li> </ul>  | NA              | NA                 | NA |
|    | <ul style="list-style-type: none"> <li>• Nozzle diameter</li> </ul>   | NA              | NA                 | NA |
| 7  | <b>Automatic fire detection and alarming system.</b>  |                 |                    |    |
|    | <ul style="list-style-type: none"> <li>• Type of detectors</li> </ul>   | NA              | NA                 | NA |
|    | <ul style="list-style-type: none"> <li>• Location of Main Panel</li> </ul>  | NA              | NA                 | NA |
|    | <ul style="list-style-type: none"> <li>• Location of Repeater Panel</li> </ul>  | NA              | NA                 | NA |
|    | <ul style="list-style-type: none"> <li>• Alternate source of power</li> </ul>   | NA              | NA                 | NA |
|    | <ul style="list-style-type: none"> <li>• Hooters' Location</li> </ul>   | NA              | NA                 | NA |
| 8  | <b>MOEFA</b>  | NA              | NA                 | NA |
| 9  | <b>Public Address System.</b>   | NA              | NA                 | NA |
| 10 | <b>Automatic Sprinkler System.</b>  |                 |                    |    |
|    | <ul style="list-style-type: none"> <li>• Basement</li> </ul>  | NA              | NA                 | NA |
|    | <ul style="list-style-type: none"> <li>• Upper Floor</li> </ul>   | NA              | NA                 | NA |
|    | <ul style="list-style-type: none"> <li>• Sprinkler above false ceiling</li> </ul>   | NA              | NA                 | NA |
| 11 | <b>Internal Hydrants</b>  |                 |                    |    |
|    | <ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> </ul>  | NA              | NA                 | NA |



|    |  |     |      |     |
|----|--|-----|------|-----|
|    | <ul style="list-style-type: none"> <li>• Communication In lift Car</li> </ul>  | N/A | N/A  | N/A |
|    | <ul style="list-style-type: none"> <li>• Fireman's Grounding Switch</li> </ul> | N/A | N/A  | N/A |
|    | <ul style="list-style-type: none"> <li>• Lift Signage</li> </ul>               | N/A | N/A  | N/A |
| 17 | <b>Standby power supply</b>  | N/A | N/A  | N/A |
| 18 | <b>Refuge Area.</b>  |     |      |     |
|    | ➤ Total Area   | N/A | N/A  | N/A |
|    | ➤ Location   | N/A | N/A  | N/A |
| 19 | <b>Fire Control Room</b>   |     |      |     |
|    | <ul style="list-style-type: none"> <li>• Detector System Panel</li> </ul>      | N/A | N/A  | N/A |
|    | <ul style="list-style-type: none"> <li>• Flow Switch Panel</li> </ul>          | N/A | N/A  | N/A |
|    | <ul style="list-style-type: none"> <li>• PA System Panel</li> </ul>            | N/A | N/A  | N/A |
|    | <ul style="list-style-type: none"> <li>• Batter backup</li> </ul>              | N/A | N/A  | N/A |
|    | <ul style="list-style-type: none"> <li>• Building Floor Plans</li> </ul>       | N/A | N/A  | N/A |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any:       | N/A | N/A. | N/A |

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection. The School Management has complied shortcomings/ observations issued by this department letter of even no. 2582 dated 14.11.2014.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, fire safety certificate is recommended.

*11/14/13*

Signature of the Inspecting Officer  
Name: - Rajesh Kumar  
Designation: - ADO/RN

*SO MWD*  
*Singh*  
*15.3.17*

*[Signature]*  
*30/8/17*