

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001


No. F6/DFS/MS/EH/2017/NDZ/465

Dated: 29/03/17

FIRE SAFETY CERTIFICATE

Certified that the Haldiram Restaurant located at G - 42 to 48 at ground floor of Cross River Mall, Plot No. 9B & 9C, C.B.D. near Karkardooma, Shahdara, Delhi owned/occupied by M/s Haldiram Restaurant Ethnic Food Pvt. Ltd. was granted FSC vide letter no. F6/DFS/MS/EH/2014/NDZ/277 dated 28/02/14. The Cross River Mall has already been issued FSC by this department vide letter no. F.6/DFS/MS/2016/NDZ/1763 dated 07/12/2016. The premises was re-inspected by the team of officers of this department on 11/03/17 in the presence of Mr. Pradeep, Manager and found that the restaurant building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 36 unless renew under rule 37 or sooner cancelled under Rule 40 and found that the restaurant building is fit for occupancy Group D "Assembly Building" with effect from 29/03/17... for a period of three years, subject to conditions, printed overleaf.

Issued on 29/03/17 at New Delhi by

  
(Vipin Kental)  
Chief Fire Officer

To,  
M/s Haldiram Ethnic Food Pvt. Ltd.  
H-154, Sector- 63, Noida, U.P.

Copy:-  
The Dy. Health Officer,  
Shahdara (South Zone, EDMC,  
Health Department, Shahdara South Zone,  
Karkardooma, Delhi

O/C  


## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.



1. Name & address of the building : Haldiram Ethnic Foods PVT. Ltd. (Restaurant cum Show room) at G-42, to 48, Cross River Mall, Plot. 9B & 9C, Central Business District Near Karkardooma, Shahdara, Delhi-110032
2. Building is comprised of : Two Basement, ground plus three upper floors  
(Restaurant on ground floor only)
3. Type of Occupancy : Assembly (Restaurant cum Show room)
4. Type of Case : **Renewal**
5. Details of Previous NOC letter : F6/DFS/MS/EH/2014/NDZ/277 dt. 28/02/14
6. Fire Safety directive letter No : Delhi Fire Service, Act 2007 & Rules 2010
7. Date of Inspection : 11/03/17
8. Name of the Inspecting officers : DO S. K. Dua & ADO Vijay Bahadur
9. Name and designation of Officer from the building side : Mr Pradeep (Manager)
10. Year of Construction : 2006
11. Applicant's letter No : Letter No.-Nil, Dated- 02/03/17

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	NBC Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			
	• Road width	06 mtr.	24 mtr.	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	06 mtr.	06 mtr.	MR
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper floor	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	c. Protection of Exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	02 mtr.	02 mtr.	MR
	g. No. of Door	02 nos.	03 nos. (2 x 2.0 mtr & 1x 1.0 mtr)	MR
03	Compartmentation.	N/A	N/A	N/A
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	Required	Provided in main building	MR
	• Upper floor	N/A	N/A	N/A
05.	Fire Extinguishers			
	• Total numbers	05 nos.	05 nos.	MR
	• Types	ABC /CO <sub>2</sub>	ABC /CO <sub>2</sub>	MR
	• IS marking	ISI marked	ISI marked	MR



06	First-Aid-Hose Reels.			
	Total numbers on each floor	01 nos (near the restaurant)	01 nos (P)	MR
	• Length of hose reel hose	30 mtr	30 mtr	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic Fire Detection and Alarming System commonly provided in the building.			
	• Type of detectors	N/A	Provided in main building	MR
	• Location of main panel	N/A	Provided in main building	MR
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	Required	Provided	MR
	• Hooter	N/A	N/A	N/A
08	MOEFA	Required	Provided	MR
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	Provided	MR
	• upper floor	N/A	Provided	MR
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants common with the Mall			
	• size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	01 no.	01 no.	MR
	• Hose box	01 no.	01 no.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level common with the Mall			
	• Discharge of main pump	N/A	2850 lpm	MR
	• Head of main pump	N/A	60 mtrs	MR
	• Number of main pumps	N/A	02 nos.	MR
	• Jockey pump out put	N/A	180 lpm	MR
	• Jockey pump head	N/A	60 mtrs	MR
	• Standby pump out put	N/A	2850 lpm	MR
	• Standby pump head	N/A	60 mtrs.	MR
	• Auto starting /manual stopping	N/A	Provided	MR
	• Pump house access	N/A	Provided	MR
	➤ Terrace Level			
	• Discharge of pump	450 lpm	450 lpm	MR
	• Head of the pump	40 mtr	40 mtrs	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting Common with the Mall			
	• Underground tank capacity	N/A	2,00,000 ltrs	MR
	• Draw-off connection	N/A	Provided	MR
	• Fire service inlet	N/A	Provided	MR
	• Access to tank	N/A	Provided	MR
	• Overhead tank capacity	10,000 ltr	50, 000 ltrs	MR
15	Exit Signage.	Required	Provided	MR



16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17	Standby Power Supply	N/A	Provided for main building	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room	Provided for main building		
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the Delhi Fire Service, Act 2007 & Rules 2010, the FSC issued vide letter no. F6/DFS/MS/EH/2014/NDZ/277 dated 28/02/14 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended to issue Fire Safety Certificate.

Signature of the Inspecting Officer  
 Name :- S. K. Dua  
 Designation :- D.O (ED)

Signature of the Inspecting Officer  
 Name :- Vijay Bahadur  
 Designation :- A.D.O (T.Pur)

DeFO(ND2)  
 21/3