

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

Fax No. 011-23412593, Ph. 011-23412225


No. F6/DFS/MS/Cinema/2017/SZ/ 516

Dated:06/04/17


FIRE SAFETY CERTIFICATE

Certified that the **M Cinemas (Sapna Cinema)** located at **54, East of Kailash, New Delhi**, building comprised of Basement, Ground + 02 upper floor was inspected by the officer concerned of this department on 27/03/2017 in the presence of Mr. Suraj Singh Rawat (Manager) of the cinemas and observed that the said building/premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "**Assembly Building, Group-D**" with effect from 06/04/2017 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 06/04/17 at New Delhi by


6/4
(Vipin Kental) -
Chief Fire Officer
pi

Copy to: -

1. The Manager, M Cinema (Sapna Cinema), 54, East of Kailash, New Delhi. 
2. The Joint Commissioner of Police (Lic.), 1st floor, PS Defence Colony, New Delhi-49

Conditions for the validity of Fire Safety Certificate

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering the fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drill be conducted at regular interval and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye Laws.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & Address of the Building	M Cinema (Sapna), 54, East of Kailash, New Delhi		
2	Type of Occupancy	Assembly Building "Group-D" (Cinema)		
3	Building Comprised of	Basements, Ground + 02 upper floor.		
4	Type of Case	New		
5	Details of Previous NOC	N/A		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	27-03-2017		
8	Name of the Inspecting Officers	ADO R.N. Singh		
9	Name & Designation of Officers from the building side	Mr. Suraj Singh Rawat (Manager)		
10	Year of construction	1979	Basement (Transformer, Elect. Panel, AHU, DG Set), Gd floor (Booking counter, Food counter) 1 st floor (Cinema Hall + offices) 2 nd floor(Balcony + Projection)	
11	Applicant letter No.	DM (SE)/DDMA (SE)/M-CINEMA/2015-16/1138 Dt 23.03.17		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	BBL-1959 requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	1. Road width	NA	9 mtr	NA
	2. Gate width	NA	6 mtr	NA
	3. Width of internal road	NA	6 mtr	NA
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	1. Upper floors	Required	2 No's	MR
	2. Basement floor	Required	2 No's	MR
	b) Width of Staircase			
	1. Upper floors	4'-6" (1.39m)	Dual staircase of 1.60m from ground floor joins half way into single staircase of 2.25m. FF to SF 1.45m & other at rear side GF to Terrace- 1.50m	MR
	2. Basement floor	4'-6"	1.80m & 1.15m (Iron)	MR
	c) Protection of exits			
	1. Fire check door	NA	NA	NA
	2. Pressurization	NA	NA	NA
	d) No. of continuous staircase to terrace	NA	NA	NA
	e) Width of corridor	4'-6"	1.39m	MR
	f) Door size / Exits	2'-8" (0.83m)	Hall- 1.69 m x 9 No's Balcony- 1.69 m x 3 No's	MR
3	Compartmentation.			
	1. Fire check door.	NA	Provided	NA
	2. Sealing of electrical shafts.	NA	Provided	NA
	3. Fire rating of shaft door.	NA	NA	NA
	4. Water curtain	NA	NA	NA
	5. Fire dampers.	NA	NA	NA
4.	Smoke Management system.			
	1. Basement	NA	Exhaust fans provided	NA
	2. Upper floors	NA	Mechanical ventilation	NA
5.	Fire Extinguishers.			
	1. Total numbers	Required	23 No's	MR
	2. Types		W.Co2-15, ABC-4, Co2-4	MR
	3. ISI Marking		Provided	MR
6.	First Aid Hose Reels.			
	1. Total numbers on each floor.	NA	1+ 2 No's in Audi	NA
	2. Length of hose-reel hose.	NA	30 m	NA
	3. Nozzle Diameter	NA	5 mm	NA

Renewal

M Cinema (Sapna), East of Kailash, New Delhi

7	Automatic fire detection & alarming system.			
	1. Type of detectors	NA	Smoke, Heat & Beam	NA
	2. Location of Main Panel	NA	NA	NA
	3. Location of Repeater Panel	NA	NA	NA
	4. Alternate source of power	NA	Provided	NA
	5. Hooter's location	NA	Each floor	NA
8.	MOEFA	NA	Provided	NA
9.	Public Address System	NA	Provided	NA
10.	Automatic Sprinkler System			
	1. Basement	NA	Provided	NA
	2. Upper floors	NA	NA	NA
	3. Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants.			
	1. Size of Riser/Down-comer	NA	NA	NA
	2. Number of Hydrant per floor	NA	NA	NA
	3. Hose box.	NA	NA	NA
12.	Yard Hydrants.			
	1. Total number of hydrants.	NA	One	NA
	2. Hose box.	NA	One	NA
13.	Pumping arrangements.			
	a) Ground Level			
	➤ Discharge of main pump.	NA	NA	NA
	➤ Head of main pump.	NA	NA	NA
	➤ Number of main pumps.	NA	NA	NA
	➤ Jockey Pump output.	NA	NA	NA
	➤ Jockey Pump head.	NA	NA	NA
	➤ Standby Pump output.	NA	NA	NA
	➤ Standby Pump head.	NA	NA	NA
	➤ Auto Starting/Manual Stopping.	NA	NA	NA
	b) Terrace Level			
	➤ Discharge of pump.	NA	900 & 180 LPM	NA
	➤ Head of pump.	NA	40 mtr	NA
	➤ Power supply.	NA	Provided	NA
	➤ Auto starting of pump.	NA	Provided	NA
14.	Captive water storage for Fire Fighting.			
	• Underground tank capacity.	NA	25,000 Ltr	NA
	➤ Draw-off connection.	NA	Provided	NA
	➤ Fire Service Inlet.	NA	Provided	NA
	➤ Access to tank.	NA	Provided	NA
	• Overhead tank capacity.	NA	25,000 Ltr	NA
15.	Exit Signage.	NA	Provided	NA
16.	Provision of Lifts.			
	1. Pressurization of lift shaft.	NA	NA	NA
	2. Pressurization of lift lobby.	NA	NA	NA
	3. Communication in lift car.	NA	NA	NA
	4. Fireman's switch.	NA	NA	NA
	5. Lift signage.	NA	NA	NA
17	Standby Power Supply	NA	Provided	NA
18.	Refuge Area			
	1. Total area	NA	NA	NA
	2. Location	NA	NA	NA

Renewal

M Cinema (Sapna), East of Kailash, New Delhi

19.	Fire Control Room. 1. Detector System Panel. 2. Flow Switch Panel. 3. PA system Panel. 4. Battery backup 5. Building floor plan	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
20.	Special Fire Protection System for the Protection of special Risk, if any:	Required	Four Co2 (22.5 kg) trolley mounted fire extinguishers provided near elect. panel	MR
Details of Seating Capacity & Exits are as below: -				
	Seats:	Exits		
Hall	292	09		
Balcony	98	03		
<p>The Fire protection systems provided in the cinema building were randomly checked/ tested and found functional at the time of inspection.</p> <p>Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules, 2010.</p> <p>Accordingly, DFA is put up for approval and signature please.</p>				
<p><i>[Signature]</i> 29/3/17</p> <p>Signature of the Inspecting Officer Name : R.N. Singh Designation: ADO</p>				

~~Renewal~~

M Cinema (Sapna), East of Kailash, New Delhi

D.O. (SD)

[Signature]
30/3/17

[Signature]
30/3

[Signature]
30/3

CFO (S2)

PI speak

DCFO S2

[Signature]
30/3

[Signature]

[Signature]
31/3

[Signature]
31/3