

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001


No. F6/DFS/MS/school/2017/NDZ/538

Dated: 12/4/17

FIRE SAFETY CERTIFICATE

Certified that the EDMC Primary Co-ed School located at Kasturba Nagar, Delhi 110032 comprised of ground plus one upper floor owned/occupied by EDMC Primary Co-ed School was issued FSC vide letter no. F6/DFS/MS/School/2013/NDZ/802 dated 26/08/13. The school building was re-inspected by the officer concerned of this department on 29/03/17 in the presence of Mr. Ghan Shyam Singh, Principal of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with circular letter no. F16/Estate/CC/Fire Safety/2011/3298 to 3398 dated- 01/03/11 issued by Director of Education and found that the school building is fit for occupancy class "B" 'Educational Building' for ground plus one upper floor with effect from 12/4/17... for a period of **three** years, subject to conditions, printed overleaf.

Issued on..... 12/4/17 ..... at New Delhi by

  
(Vipin Kental)  
Chief Fire Officer  
o/c  
by

To,  
The Principal

M/s EDMC Primary Co-ed School,  
Kasturba Nagar, Delhi 110032

Copy to:-  
The Director of Education, EDMC,  
Udyog Sadan, Plot No.419, FIE,  
Patparganj Industrial Area, Delhi-110092

### CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.



1. Name & address of the building : EDMC Primary Co-ed School,  
Kasturba Nagar, Delhi-110032
2. Building is comprised of : **Ground plus first floor only**
3. Type of Occupancy : Educational
4. Type of Case : **Renewal**
5. Details of Previous NOC letter : F6/DFS/MS/School/2013/NDZ/802 dated 26/08/13
6. Fire Safety direction letter No : F16/Estate/CC/Fire Safety/2011/3298 to 3398  
Dated 01/03/11 issued by Director of Education
7. Date of Inspection : 29/03/17
8. Name of the Inspecting officers : ADO V. B. Yadav
9. Name and designation of Officer  
from the building side : Mr. Ghan Shyam Singh, Principal
10. Year of Construction : 2002
11. Applicant's letter No : Letter No. 01, Dated-03/02/2017

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Circular Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			<b>MR</b>
	• Road width	06 mtr.	06 mtr.	<b>MR</b>
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			<b>MR</b>
	• Upper floor	01 nos.	02 nos.	<b>MR</b>
	• Basement	N/A	N/A	N/A
	b. Width of Staircases			<b>MR</b>
	• Upper floor	1.50 mtr.	1.53 mtr. & 1.21 mtr.	<b>MR</b>
	• Basement	N/A	N/A	N/A
	c. Protection of Exits			N/A
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	N/A	N/A	N/A
	e. Width of Corridor	1.50 mtr.	2.30 mtr.	<b>MR</b>
	f. Door Size	01 mtr.	01.17 mtr.	<b>MR</b>
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
05.	Fire Extinguishers			<b>MR</b>
	• Total numbers	04 nos.	04 nos.	<b>MR</b>
	• types	ABC /CO <sub>2</sub>	ABC /CO <sub>2</sub>	<b>MR</b>
	• IS marking	ISI marked	ISI marked	<b>MR</b>



06	First-Aid-Hose Reels.			
	Total numbers on each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	N/A	N/A	N/A
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-corer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of Main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting /manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	N/A	N/A	N/A
	• Head of the pump	N/A	N/A	N/A
	• Power supply	N/A	N/A	N/A
	• Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead tank capacity	N/A	N/A	N/A
15	Exit Signage.	N/A	N/A	N/A



16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17	Standby Power Supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the circular no- F16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/11 issued by Director of Education, it is recommended to issue Fire Safety Certificate.

*[Signature]*  
30/3/17

Signature of the Inspecting Officer  
Name :- V. B. Yadav  
Designation :- A.D.O (T.P)

~~DO(EU)~~ *King*  
*01/4*

~~DEFO(NDZ)~~ *[Signature]*  
*3/4*

146/cfo NDZ  
10/4/12/12/14.

*C F/O. m-scell* FTM,  
*6/4*

As approved FT fse is put up for signature please.

~~cfo(NDZ)~~ *m-scell* *12/4*

*[Signature]*  
14/4/17