

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI


No. F6/DFS/MS/SCHOOL/2017/ 62 / 534

Dated: 21 / 4 / 2017

**FIRE SAFETY CERTIFICATE**

Certified that the **Lions Public School**, Located at, **I-Block Ashok Vihar, Phase-1, Delhi - 110052**. comprised of **Ground + one upper floor** was issued FSC vide Letter No. F6/DFS/MS/08/1816 Dated-30/06/2008, The premises was re inspected by the officer concerned of this department on 18-03-2017 in the presence of **Sh. Virander Singh (Lab Assistant )** and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance Circular 262-362 Dated 17-01-2005 and that the premises is fit for occupancy class "Educational" Group B with effect from 12/4/17 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on .... 12/4/17 ..... at New Delhi by.

  
(Atul Garg)  
Chief Fire Officer  
Delhi Fire Service

Copy to:

The Principal,  
Lions Public School, I-Block Ashok Vihar, Phase-1, Delhi -110052.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. All the exit route shall be kept free from any obstruction.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

1. Name & address of the building: **Lions Public School, Located at, I-Block Ashok Vihar, Phase-1, Delhi -110052.**
2. Type of Occupancy : Educational (Ground + 1 Upper Floor)
3. Type of Case :Renewal
4. Details of previous NOC : F6/DFS/MS/08/1816 Dated- 30/06/2008
5. Fire Safety directives Letter No. : DOE circular 262-362 Dated 17/01/2005
6. Date of inspection : 18-03-2017
7. Name of the Inspecting Officer :Udai vir singh, ADO (WP)
8. Name and designation of Officer  
from the building side :Sh. Virander Singh (Lab Assistant )
9. Year of Construction :1969
10. Applicant's letter No. :LPS/F20/001/2017dated- 19/02/2017

No. of Students=1623
No. of class rooms=52
Plot area=7972.14 sqm
Covered area=2006.30sqm

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE circular 262-362 Dated 17/01/2005	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	<ul style="list-style-type: none"> <li>Accessible</li> <li>Accessible</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>12m Provided</li> <li>342cm Provided</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>MR</li> <li>MR</li> <li>NA</li> </ul>
2.	Number, width, Type & Arrangements of exits			
	<ul style="list-style-type: none"> <li>a. Number of staircases</li> <li>• Upper floors</li> <li>• Basements</li> <li>b. Width of staircases</li> <li>• Upper floors</li> <li>• Basements</li> <li>c. Protection of exits</li> <li>• Fire check door</li> <li>• Pressurization</li> <li>d. No of continuous staircase to terrace</li> <li>e. Width Of Corridor</li> <li>f. Door Size</li> </ul>	<ul style="list-style-type: none"> <li>02</li> <li>NA</li> <li>150cm</li> <li>NA</li> <li>NA</li> <li>NA</li> <li>NA</li> <li>2</li> <li>1.5m</li> <li>Old case</li> </ul>	<ul style="list-style-type: none"> <li>03 Provided</li> <li>NA</li> <li>1x110cm&amp;2x123cm</li> <li>NA</li> <li>NA</li> <li>NA</li> <li>NA</li> <li>Provided</li> <li>240cm Provided</li> <li>87cm</li> </ul>	<ul style="list-style-type: none"> <li>MR</li> <li>NA</li> <li>MR(old case)</li> <li>NA</li> <li>NA</li> <li>NA</li> <li>MR</li> <li>MR</li> <li>Old case</li> </ul>
3.	Compartmentation			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	<ul style="list-style-type: none"> <li>NA</li> <li>NA</li> <li>NA</li> <li>NA</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>NA</li> <li>NA</li> <li>NA</li> <li>NA</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>NA</li> <li>NA</li> <li>NA</li> <li>NA</li> <li>NA</li> </ul>
4.	Smoke managements System			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	<ul style="list-style-type: none"> <li>NA</li> <li>Required</li> </ul>	<ul style="list-style-type: none"> <li>NA</li> <li>Open able window &amp; Exhausts fan Provided</li> </ul>	<ul style="list-style-type: none"> <li>NA</li> <li>MR</li> </ul>
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> </ul>	<ul style="list-style-type: none"> <li>12nos.</li> <li>ABC &amp; CO<sub>2</sub></li> </ul>	<ul style="list-style-type: none"> <li>17 Provided</li> <li>Provided</li> </ul>	<ul style="list-style-type: none"> <li>MR</li> <li>MR</li> </ul>

6.	First – Aid Hose Reels			
	• Total numbers on each floor	2	02 Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	Required	02 Provided, 100mm	MR
	• Number of hydrants per floor	Required	2	MR
	• Hose Box	Required	2	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual stopping	NA	NA	NA
	➤ Pump House Access			
	• Terrace level			
	➤ Discharge of pump	450 lpm & 180 lpm	Provided	MR
	➤ Head of the pump	36 mtr	Provided	MR
	➤ Power supply	NR	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NR	25,000 ltrs	MR
	➤ Draw off connection	NR	NA	NA
	➤ Fire service inlet	NR	NA	NA
	➤ Access to tank	NR	Required	MR
	• Overhead Tank capacity	Old case	6,000 ltrs	MR(Old case)
15	Exit Signage	NA	NA	NA
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA

Handwritten signature or initials.

17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/08/1816 Dated-30/06/2008 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Uday Vir Singh

Name

Designation

ADD/WA

Designation

DD/W - What about shortcoming dated 6/6/13.  
 - Please see pumping arrangement & Work Recd.  
 21/8/12

~~DD/W~~  
 ADD(WA)

During the inspection it is observed that all the class rooms have operable window & the exhaust fans are provided as shown in photographs enclosed.

DD/W - On leave  
 21/8/12

Signature  
 28/8/12