

No. F6/DFS/MS/School/2017/SZ/ 553

Dated: 18/4/17.

FIRE SAFETY CERTIFICATE

Certified that the **Nanki Public School** located at **C-407, Gali No-9, Sangam Vihar, New Delhi**, comprised of **Ground + 1 upper floor** was granted Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2013/SZ/1350 dated 27/12/2013. The building/premises was re-inspected by officer concerned of this department on 18.03.2017 in the presence of Mr. SK Pandey (Manager) of the school and found that said school building have deemed complied with the fire prevention and fire safety arrangements in accordance with Directorate of Education circular date 01/03/2011 issued by Director of Education, Govt. of NCT of Delhi and that the building/premises is fit for occupancy class "**Educational Building, Group-B**" as above with effect from 18/4/17 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the condition under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...18/4/17..... at New Delhi by


(Vipin Kental)
Chief Fire Officer

Copy to: -

1. The Manager, Nanki Public School, C-407, Gali No-9, Sangam Vihar, New Delhi-110080
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering the fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drill be conducted at regular interval and record be maintained.
4. This Certificate cannot be treated as regularization of unauthorized construction, if any.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.


INSPECTION REPORT

1	Name & Address of the Building	Nanki Public School, C-407, Gali No-9, Sangam Vihar, New Delhi. (ID-1923361)		
2	Type of Occupancy	Educational Building "Group-B" (School)		
3	Building Comprised of	Ground + one upper floor.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2013/SZ/1350 Dt. 27/12/2013		
6	Fire Safety Directives Letter No	DOE Circular dated 01-03-2011		
7	Date of Inspection	18-03-2017		
8	Name of the Inspecting Officers	ADO R.N. Singh		
9	Name & Designation of Officers from the building side	Mr. SK Pandey (Principal)		
10	Year of construction	2011		
11	Applicant letter No.	Nil dated 03/02/2017 ODD No.1310 Dt. 06/02/2017		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old FSC Dt. 27-12-2013 requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Accessible	6 mtr	MR
	• Gate width	N/A	Directly accessible from road	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, width, type & arrangement of exits			
	a. Number of Staircase			
	➤ Upper floors	One	Two	MR
	➤ Basement floor	N/A	N/A	N/A
	b. Width of Staircase			
	➤ Upper floors	Required	1.50m & 0.75m	MR
	➤ Basement floor	N/A	N/A	N/A
	c. Protection of exits			
	➤ Fire check door	N/A	N/A	N/A
	➤ Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	One	One	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1m	1m	MR
3	Compartmentation.			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4.	Smoke Management system.			
	• Basement	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers.			
	• Total numbers	4 No's	4 No's	MR
	• Types	ISI Marked	ABC-04	MR
	• ISI Marking		Yes	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	N/A	N/A	N/A
	• Length of hose-reel hose.	N/A	N/A	N/A
	• Nozzle Diameter	N/A	N/A	N/A

Renewal

Nanki Public School, C-407, Gali No-9 Sangam Vihar, ND

7	Automatic fire detection & alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basement.	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants.			
	• Size of Riser/Down-comer	N/A	N/A	N/A
	• Number of Hydrant per floor	N/A	N/A	N/A
	• Hose box.	N/A	N/A	N/A
12.	Yard Hydrants.			
	• Total number of hydrants.	N/A	N/A	N/A
	• Hose box.	N/A	N/A	N/A
13.	Pumping arrangements.			
	a) Ground Level			
	➤ Discharge of main pump.	N/A	N/A	N/A
	➤ Head of main pump.	N/A	N/A	N/A
	➤ Number of main pumps.	N/A	N/A	N/A
	➤ Jockey Pump output.	N/A	N/A	N/A
	➤ Jockey Pump head.	N/A	N/A	N/A
	➤ Standby Pump output.	N/A	N/A	N/A
	➤ Standby Pump head.	N/A	N/A	N/A
	➤ Auto Starting / Manual Stopping.	N/A	N/A	N/A
	➤ Pump house access.	N/A	N/A	N/A
	b) Terrace Level			
	➤ Discharge of pump.	N/A	N/A	N/A
	➤ Head of pump.	N/A	N/A	N/A
	➤ Power supply.	N/A	N/A	N/A
	➤ Auto starting of pump.	N/A	N/A	N/A
14.	Captive water storage for Fire Fighting.			
	• Underground tank capacity.	N/A	N/A	N/A
	➤ Draw-off connection.	N/A	N/A	N/A
	➤ Fire Service Inlet.	N/A	N/A	N/A
	➤ Access to tank.	N/A	N/A	N/A
	• Overhead tank capacity.	N/A	N/A	N/A
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of lift shaft.	N/A	N/A	N/A
	• Pressurization of lift lobby.	N/A	N/A	N/A
	• Communication in lift car.	N/A	N/A	N/A
	• Fireman's switch.	N/A	N/A	N/A
	• Lift signage.	N/A	N/A	N/A
17	Standby Power Supply	N/A	N/A	N/A
18.	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A

19.	Fire Control Room.			
	• Detector System Panel.	N/A	N/A	N/A
	• Flow Switch Panel.	N/A	N/A	N/A
	• PA system Panel.	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for the Protection of special Risk, if any.			N/A
<p>The Fire protection systems provided in the building were randomly checked/ tested and found functional at the time of inspection.</p> <p>Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the circular of Directorate of Education dated 01/03/2011, FSC issued vide letter No. F6/DFS/MS/School/2013/SZ/1350 dated 27/12/2013, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.</p> <p>Accordingly DFA is put up for approval and signature please.</p> <div style="text-align: right;">  Signature of the Inspecting Officer Name : R.N. Singh Designation: ADO </div>				

Renewal

Nanki Public School, C-407, Gali No-9, Sangam Vihar, ND

D. O. (SD) on 2/12

dy cfo/sz

29/12

761/CFO SL
31/3/17



CFO (SY)

M-Scell

FT 10.
30/3

FT letter is put up for sign pls

cfo/sz

M-Scell

STY

Signature
03/4