

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001
Fax No. 011-23412593, Ph. 011-23412225

No. F6/DFS/MS/EH/2017/SZ/ 560

Dated: 19/4/17..

FIRE SAFETY CERTIFICATE

Certified that M/s **Suribachi (Additional) Restaurant (A Unit of Royal Eastern Hospitality Pvt Ltd.)** located at **T-540, Malviya Nagar, New Delhi-110017**, comprised of Ground floor only was granted FSC by this department vide letter No. F.6/DFS/MS/EH/2014/SZ/561 dated 02/05/2014. The premises was re-inspected by the officer concerned of this department on 15/03/2017 in the presence of Mr. Manoj Kumar (Manager) of the restaurant and observed that the said building/premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class-D "**Assembly Building**" (Restaurant) as above with effect from 19/4/17 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 19/4/17 at New Delhi by


(Vipin Kantal)
Chief Fire Officer

Copy to: -

1. M/s Suribachi (Additional) Restaurant, T-540, Malviya Nagar, New Delhi-110017 o/c
2. The Joint C.P. (Lic.), First Floor, PS Defence Colony, New Delhi-110049
3. The DHO (Central Zone), South MCD, Health Deptt, Lajpat Nagar, New Delhi-24

Conditions for the validity of Fire Safety Certificate

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering the fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drill be conducted at regular interval and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye Laws.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & Address of the Building	M/s Suribachi (Additional) Restaurant, T-540, Malviya Nagar, New Delhi-110017 (A Unit of Royal Eastern Hospitality Pvt Ltd)		
2	Type of Occupancy	Group-D Assembly Building. (Restaurant)		
3	Building comprised of	Ground floor only.		
4	Type of Case	Renewal		
5	Details of Previous NOC	No.F6/MS/DFS/EH/2014/SZ/561 Dated 02-05-2014		
6	Fire Safety Directives Letter No	No. 4/22/2004/H-III/356-359 dated 22-03-2005		
7	Date of Inspection	15/03/2017		
8	Name of the Inspecting Officers	ADO R.N. Singh		
9	Name & Designation of Officers from the building side	Mr. Manoj Kumar (Manager)		
10	Year of construction	1994	Restaurant is running in two sections under one roof	
11	Applicant letter No.	Nil Dated 27/02/2017		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Dt. 30-12-2005 requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Required	15 mtr	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, width, type and arrangements of exits.			
	a. Number of Staircase			
	• Upper floors	N/A	N/A	N/A
	• Basement floor	N/A	N/A	N/A
	b. Width of Staircase			
	• Upper floors	N/A	N/A	N/A
	• Basement floor	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	N/A	N/A	N/A
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	Required	1.40m, 1.06m, 1.04 & 0.80m	MR (old case)
3	Compartmentation.			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4.	Smoke Management system.			
	• Basement	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	N/A	N/A
5.	Fire Extinguishers.			
	• Total numbers	ISI marked	15 No's	MR
	• Types		ABC-10 & Co2-05	MR
	• ISI Marking		Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	Hose Reels	One	MR
	• Length of hose-reel hose.		30 m	MR
	• Nozzle Diameter		5 mm	MR

Renewal

M/s Suribachi (Additional) Restt. T-540, Malviya Nagar, ND

7	Automatic fire detection & alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	M/R
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants.			
	• Size of Riser/Down-comer	N/A	N/A	N/A
	• Number of Hydrant per floor	N/A	N/A	N/A
	• Hose box.	N/A	N/A	N/A
12.	Yard Hydrants.			
	• Total number of hydrants.	N/A	N/A	N/A
	• 2. Hose box.	N/A	N/A	N/A
13.	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	N/A	N/A	N/A
	➤ Head of main pump.	N/A	N/A	N/A
	➤ Number of main pumps.	N/A	N/A	N/A
	➤ Jockey Pump output.	N/A	N/A	N/A
	➤ Jockey Pump head.	N/A	N/A	N/A
	➤ Standby Pump output.	N/A	N/A	N/A
	➤ Standby Pump head.	N/A	N/A	N/A
	➤ Auto Starting / Manual Stopping.	N/A	N/A	N/A
	➤ Access to pump house	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump.	450 LPM	600 & 840 LP	MR
	➤ Head of pump.	39 mtr	26m & 23.5m	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	Captive water storage for Fire Fighting.			
	• Underground tank capacity.	N/A	N/A	N/A
	➤ Draw-off connection.	N/A	N/A	N/A
	➤ Fire Service Inlet.	N/A	N/A	N/A
	➤ Access to tank.	N/A	N/A	N/A
	• Overhead tank capacity.	5,000 Ltr	5000 Ltr.	M/R
15.	Exit Signage.	Required	Provided	M/R
16.	Provision of Lifts.			
	• Pressurization of lift shaft.	N/A	N/A	N/A
	• Pressurization of lift lobby.	N/A	N/A	N/A
	• Communication in lift car.	N/A	N/A	N/A
	• Fireman's switch.	N/A	N/A	N/A
	• Lift signage.	N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A

Renewal

M/s Suribachi (Additional) Restt. T-540, Malviya Nagar, ND

N/

19.	Fire Control Room.			
	• Detector System Panel.	N/A	N/A	N/A
	• Flow Switch Panel.	N/A	N/A	N/A
	• PA system Panel.	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for the Protection of special Risk, if any :			N/A
<p>The Fire protection systems provided in the building were tested/ checked and found functional at the time of inspection.</p> <p>Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F6/DFS/MS/EH2014/SZ/561 dated 02-05-2014, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.</p> <p>Accordingly, DFA is put up for approval and signature please.</p>				
<p><i>[Signature]</i> Signature of the Inspecting Officer Name : R.N. Singh Designation: ADO</p>				

Renewal

M/s Suribachi (Additional) Restt. T-540, Malviya Nagar, ND

Div. Officer (SD)

[Signature]
3/4/17

[Signature]
Dy. CPO (S2)

[Signature]
2/4

CPO (S2)

M-SCM

FTM.

[Signature]
7/4

FT letter is put up for sign ble.

CPO/S2

M-SCM

[Signature]
13/4

[Signature]
13/4

783/CPO S2
2/4/17/18/17

